


- NOTES:**
- SEE DRAWING E-1 FOR ELECTRICAL SYMBOL LIST AND ABBREVIATIONS. SEE DRAWING E-2 FOR ELECTRICAL GENERAL NOTES.
 - CONTRACTOR MUST INSTALL A 120V GFCI RECEPTACLE AT 15'-0" ABOVE GRADE ON LIGHTING UNIT. CONNECT RECEPTACLE TO CONTROLLER H-3.
 - STREET LIGHTING CONTROLLER RWP-1 IS LOCATED SOUTH OF 143rd STREET ON THE EAST SIDE OF LAGRANGE ROAD AT APPROXIMATE STATION 270+00.
 - CONTRACTOR TO DEENERGIZE EXISTING CONTROLLER #3 BEFORE REMOVING TEMPORARY 2-1/C #10 & 1/C #10 GND CONDUCTORS IN CONDUIT BETWEEN MULTI-USE PATH BRIDGE ABUTMENTS. EXISTING NORTHBOUND UNDERPASS LUMINAIRES FOR MULTI-USE PATH & RAILROAD BRIDGES SHALL BE PERMANENTLY CONNECTED TO CONTROLLER C115. SOUTHBOUND UNDERPASS LUMINAIRES SHALL REMAIN CONNECTED TO CONTROLLER #3. SEE DRAWING E-9 FOR UNDERPASS LIGHTING PLAN AND WIRING DIAGRAM.
 - SEE DRAWING E-10 FOR SOUTHWEST HIGHWAY UNDERPASS LIGHTING PLAN.
 - SEE DRAWING E-47 FOR PROPOSED LIGHTING UNIT DETAILS. SEE DRAWING E-46 FOR PROPOSED LIGHTING UNIT FOUNDATION DETAILS, UNLESS NOTED OTHERWISE.
 - SEE DRAWING E-44 FOR PROPOSED RETAINING WALL MOUNTED LIGHTING UNIT INSTALLATION DETAILS.
 - REFER TO STRUCTURAL DRAWINGS FOR DETAILS OF LIGHTING UNIT FOUNDATION ON WALL 016-Z004.



100 S. WACKER DR.
 SUITE 500
 CHICAGO, IL 60606
 TEL (312) 939-1000
 FAX (312) 939-4998
URS

FILE NAME = D160M62-SHT-E14.dgn	USER NAME = Anthony.Plutz	DESIGNED - MAE	REVISED -	STATE OF ILLINOIS DEPARTMENT OF TRANSPORTATION	US-45 (LaGRANGE ROAD) TEMPORARY LIGHTING PLAN: STAGE 1A	F.A.P. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.	
SHT.PLAN	PLOT SCALE = 100.000000' / in.	CHECKED - DAD	REVISED -			330	103R-5	COOK	778	338	
	PLOT DATE = 3/13/2013	DATE - 03/13/13	REVISED -			E-14		CONTRACT NO. 60M62			
						SCALE: 1"=50'	SHEET 1 OF 3 SHEETS	STA. 284+00 TO STA. 312+00	ILLINOIS FED. AID PROJECT		