


NOTES:

- SEE DRAWING E-1 FOR ELECTRICAL SYMBOL LIST AND ABBREVIATIONS. SEE DRAWING E-2 FOR ELECTRICAL GENERAL NOTES.
- CONTRACTOR MUST ROUTE CONDUIT FROM A LOCATION SPECIFIED BY COMED TO THE PRIMARY SIDE OF THE PROPOSED SERVICE TRANSFORMER. CONDUIT MATERIAL AND SIZE TO BE DETERMINED BY COMED, AND PAID FOR UNDER THE "ELECTRIC UTILITY SERVICE CONNECTION" PAY ITEM. SEPARATE PAYMENT WILL NOT BE MADE.
- CONTRACTOR SHALL INSURE THAT THERE IS A MINIMUM HORIZONTAL CLEARANCE OF 50 FEET, OR AS DIRECTED BY COMED, BETWEEN THE POLE AND THE CLOSEST COMED HIGH VOLTAGE LINE.
- SEE DRAWING E-47 FOR PROPOSED LIGHTING UNIT DETAILS. SEE DRAWING E-46 FOR PROPOSED LIGHTING UNIT FOUNDATION DETAILS, UNLESS NOTED OTHERWISE.
- SEE DRAWING E-44 FOR PROPOSED RETAINING WALL MOUNTED LIGHTING UNIT INSTALLATION DETAILS.
- CONTRACTOR TO FURNISH AND INSTALL (3) 3/2" x 36" RADIUS PVC CONDUIT RACEWAY ELBOWS IN FOUNDATION PER DRAWING E-46.



FILE NAME =	D:\60M62-SHT-E15.dgn
SHT.PLAN	

USER NAME =	Anthony.Plutz
PLOT SCALE =	100.000000' / in.
PLOT DATE =	3/13/2013

DESIGNED -	MAE
DRAWN -	WM
CHECKED -	DAD
DATE -	03/13/13

REVISED -	
REVISED -	
REVISED -	
REVISED -	

**STATE OF ILLINOIS
DEPARTMENT OF TRANSPORTATION**

US-45 (LaGRANGE ROAD) TEMPORARY LIGHTING PLAN: STAGE 1A	
SCALE: 1"=50'	SHEET 2 OF 3 SHEETS STA. 312+00 TO STA. 340+00

F.A.P. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
330	103R-5	COOK	778	339
E-15		CONTRACT NO. 60M62		
ILLINOIS FED. AID PROJECT				