


NOTES:

- SEE DRAWING E-1 FOR ELECTRICAL SYMBOL LIST AND ABBREVIATIONS. SEE DRAWING E-2 FOR ELECTRICAL GENERAL NOTES.
- CONTRACTOR MUST INSTALL A 120V GFCI RECEPTACLE AT 15'-0" ABOVE GRADE ON LIGHTING UNIT. CONNECT RECEPTACLE TO CONTROLLER H-3.
- STREET LIGHTING CONTROLLER RWP-1 IS LOCATED SOUTH OF 143rd STREET ON THE EAST SIDE OF THE ROAD AT APPROXIMATE STATION 270+00.
- CONTRACTOR TO DEENERGIZE EXISTING CONTROLLER #3 AND REMOVE 2-1/C #10 & 1/C #10 GND CONDUCTORS IN CONDUIT TO MULTI-USE PATH BRIDGE UNDERPASS LUMINAIRES. EXISTING SOUTHBOUND UNDERPASS LUMINAIRES FOR MULTI-USE PATH & RAILROAD BRIDGES SHALL BE PERMANENTLY CONNECTED TO CONTROLLER C115. SEE DRAWING E-9 FOR UNDERPASS LIGHTING PLAN AND WIRING DIAGRAM.
- SEE DRAWING E-10 FOR SOUTHWEST HIGHWAY UNDERPASS LIGHTING PLAN.
- SEE DRAWING E-47 FOR PROPOSED LIGHTING UNIT DETAILS. SEE DRAWING E-46 FOR PROPOSED LIGHTING UNIT FOUNDATION DETAILS.
- REFER TO STRUCTURAL DRAWINGS FOR DETAILS OF LIGHTING UNIT FOUNDATION ON WALL 016-2003.



100 S. WACKER DR.
 SUITE 500
 CHICAGO, IL 60606
 TEL (312) 939-1000
 FAX (312) 939-4198
URS

FILE NAME = D160M62-SHT-E23.dgn	USER NAME = Anthony.Plutz	DESIGNED - MAE	REVISED -	STATE OF ILLINOIS DEPARTMENT OF TRANSPORTATION	US-45 (LaGRANGE ROAD) PROPOSED ROADWAY LIGHTING PLAN - STAGE 3	F.A.P. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
SHT.PLAN	PLOT SCALE = 100.000000' / in.	DRAWN - WM	REVISED -			330	103R-5	COOK	778	347
	PLOT DATE = 3/13/2013	CHECKED - DAD	REVISED -			E-23		CONTRACT NO. 60M62		
		DATE - 03/13/13	REVISED -	SCALE: 1"=50'		SHEET 1 OF 3 SHEETS		STA. 284+00 TO STA. 312+00		ILLINOIS FED. AID PROJECT