


- NOTES:**
- SEE DRAWING E-1 FOR ELECTRICAL SYMBOL LIST AND ABBREVIATIONS. SEE DRAWING E-2 FOR ELECTRICAL GENERAL NOTES.
 - CONTRACTOR SHALL INSURE THAT THERE IS A MINIMUM HORIZONTAL CLEARANCE OF 50 FEET, OR AS DIRECTED BY COMED, BETWEEN THE POLE AND THE CLOSEST COMED HIGH VOLTAGE LINE.
 - SEE DRAWING E-47 FOR PROPOSED LIGHTING UNIT DETAILS. SEE DRAWING E-46 FOR PROPOSED LIGHTING UNIT FOUNDATION DETAILS.



100 S. WACKER DR.
 10TH FLOOR
 CHICAGO, IL 60606
 TEL (312) 939-1000
 FAX (312) 939-4198

URS

FILE NAME = D160M62-SHT-E24.dgn	USER NAME = Anthony.Plutz	DESIGNED - MAE	REVISED -	STATE OF ILLINOIS DEPARTMENT OF TRANSPORTATION	US-45 (LaGRANGE ROAD) PROPOSED ROADWAY LIGHTING PLAN - STAGE 3	F.A.P. RTE. 330	SECTION 103R-5	COUNTY COOK	TOTAL SHEETS 778	SHEET NO. 348	
SHT.PLAN	PLOT SCALE = 100.000000' / in.	CHECKED - DAD	REVISED -			SCALE: 1"=50'	SHEET 2 OF 3 SHEETS	STA. 312+00 TO STA. 340+00	E-24		CONTRACT NO. 60M62
	PLOT DATE = 3/13/2013	DATE - 03/13/13	REVISED -			ILLINOIS FED. AID PROJECT					