



STEEL PILE TABLE


Designation	Depth d	Flange width b _f	Web and Flange thickness t	Encasement diameter A
HP 14x117	141/4"	14 ⁷ /8"	¹³ / ₁₆ "	30"
x102	14"	14 ³ / ₄ "	11/16"	30"
x89	137/8"	143/4"	5/8"	30"
x73	13 ⁵ ⁄8"	14 ⁵ /8"	1/2"	30"
HP 12x84	121/4"	121/4"	1/16"	24"
x74	12 ¹ /8"	121/4"	5/8"	24"
x63	12"	12½"	1/2"	24"
x53	113/4"	12"	7/ ₁₆ "	24"
HP 10x57	10"	101/4"	9/16"	24"
x42	9 3/4"	101/8"	7/ ₁₆ "	24"
HP 8x36	8"	8 ½"	7/ ₁₆ "	18"




ELEVATION



H-PILE SHOE ATTACHMENT




WELDED COMMERCIAL SPLICE



ISOMETRIC VIEW

WELDED COMMERCIAL SPLICE ALTERNATE

- * Interrupt welds $\frac{1}{4}$ " from end of web and/or each flange.
- ** Remove portions of backup plates that extend outside the flanges.
- *** Weld size per pile shoe manufacturer ($\frac{5}{16}$ " min.).



<u>ELEVATION</u>

Welded wire fabric $6 \times 6-$ W4.0 x W4.0 weighing 58 # / 100 sq. ft. Bend as required to fit into wall.


Note:


Forms for encasement may be omitted when soil conditions permit.

CONTRACT NO. = MR020


<u>SECTION A-A</u>

PILE ENCASEMENT





END VIEW



ELEVATION

HP
HP

Designation	F	F _t	F _w	W	W_t	W _w
HP 14x117	121/2"	1 "	7/8"	73/4"	5/8"	1/2"
x102	121/2"	7/8"	3/4"	73/4"	5/8"	1/2"
x89	121/2"	3/4"	11/16"	73/4"	5/8"	1/2"
x73	121/2"	5/8"	⁹ /16"	73/4"	5/8"	1/2"
HP 12x84	10"	7/8"	11/16"	6 1/2"	5/8"	1/2"
x74	10"	7/8"	11/16"	6 1/2"	5/8"	1/2"
x63	10"	5/8"	1/2"	6 1/2"	1/2"	³ / ₈ "
x53	10"	5/8"	1/2"	6 1/2"	1/2"	3/8"
HP 10x57	8"	3/4"	9/16"	5 1/4"	1/2"	<i>3</i> ∕ ₈ "
x42	8"	5/8"	⁹ /16"	5 1/4"	1/2"	³ / ₈ "
HP 8x36	7"	5/8"	⁷ /16"	4 1/4"	1/2"	3/8"

WELDED PLATE FIELD SPLICE

Note:

Note:
The steel H-piles shall be according to AASHTO M270 Grade 50.

F-HP 1-27-

 DRAWN BY: LAG
 LEVEL
 BY
 DATE
 DESCRIPTION

 CHECKED BY: JKC
 1
 MAB
 3/8/13
 REVISED PER IDA COMMENTS

 DATE: 12/12
 DATE: 12/12
 DATE: 12/12

CHAMLIN A T

PERU MORRIS

MORRIS AIRPORT ACCESS ROAD CITY OF MORRIS, GRUNDY COUNTY, ILLINOIS

PILE DETAILS STRUCTURE NO. 032-7013

SHEET NO. 8 OF 10 SHEETS

APPROVED FOR CONSTRUCTION

CURRENT AS OF: 3/8/13

SCALE: AS NOTED SHEET 29

FILE NO.: 1002.86 OF 38