



PIPE CROSSINGS		
NO.	DESCRIPTION	ELEV.
1	TOP OF SANITARY SEWER	737.1
	BOTTOM OF WATER MAIN	738.6 (MIN)
2	BOTTOM OF STORM SEWER	741.6
	TOP OF WATER MAIN	740.1 (MAX)
3	BOTTOM OF STORM SEWER	741.5
	TOP OF WATER MAIN	740.0 (MAX)
4	BOTTOM OF STORM SEWER	742.5
	TOP OF SANITARY SEWER	737.8
5	BOTTOM OF STORM SEWER	741.4
	TOP OF SANITARY SEWER	736.1
6	TOP OF SANITARY SEWER	733.2
	BOTTOM OF WATER MAIN	734.7 (MIN)
7	BOTTOM OF STORM SEWER	736.6
	TOP OF WATER MAIN	735.1 (MAX)

* WATERMAIN IS TO BE ENCASED WITH WATER QUALITY PIPE 10' ON EITHER SIDE OF CROSSING

NOTE: UTILITY POLES SHOWN TO BE MOVED (M) ARE TO BE RELOCATED BY OTHERS.

