



The Contractor shall install fuses in the service disconnect that are rated for the wire size in accordance with NEC requirements (60A fuses for #6 cable).

FRONT SIDE

ELECTRIC SERVICE INSTALLATION

- Size larger as needed.
- Or as directed by Utility Company.

FILE NAME =	USER NAME = potelyj	DESIGNED -	REVISED -	STATE OF ILLINOIS DEPARTMENT OF TRANSPORTATION	ELECTRIC SERVICE INSTALLATION DETAIL	F.A.I. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
c:\pwwork\pvidot\potelyj\d0258292\0366828-eh-t-detail.dgn	DRAWN -	REVISED -	VAR			D3 OVD MESSAGE SG - 2012	VAR	50	6	
PLOT SCALE = 1/80.0000' / in.	CHECKED -	REVISED -	CONTRACT NO. 66B28							
PLOT DATE = 2/23/2012	DATE -	REVISED -	[ILLINOIS]							
SCALE: _____					SHEET NO. X OF X SHEETS		STA. _____ TO STA. _____			