F.A.I. RTE.	SECTION	4	COUNTY	TOTAL	SHEET NO.				
94	•		COOK	764	442				
STA. TO STA.									
FED. ROAD DIST. NO. ILLINOIS FED. AID PROJECT									

• (1516.1, 1717, 1818) R-5

62593 දි

## ABBREVIATIONS

Α	AMPERES	E	EXISTING UNIT TO REMAIN	LF	LINEAR FEET
AC	ALTERNATING CURRENT	EA	EACH	LP	LIGHT POLE
A/C	AERIAL CABLE	EB	EASTBOUND	L SUM	LUMP SUM
AFG	ABOVE FINISHED GRADE	ECA	ELECTRIC CABLE ASSEMBLY	LT	LEFT
ANT	ANTENNA	EL	ELEVATION	M	METER
AOBE	AS ORDERED BY THE ENGINEER	ЕМ	EXISTING UNIT TO BE MODIFIED	MA	MAST ARM
ASPH	ASPHALT		(e.g. NEW LUMINAIRE, BALLAST, OR MAST ARM)	MD	MICROWAVE DETECTOR
ATS	ATTACHED TO STRUCTURE	ER	EXISTING RELOCATED UNIT	мм	MULTI-MODE
AVE	AVENUE	ET	EXISTING TEMPORARY UNIT TO	MW	MESSENGER WIRE
BHD	BULKHEAD		REMAIN OR MODIFIED	NB	NORTHBOUND
BIT	BITUMINOUS	ETP	EMERGENCY TRAFFIC PATROL	NIC	NOT IN CONTRACT
BLK	BLOCK	ETR	EXISTING TEMPORARY RELOCATED	NM	NONMETALLIC
BR	BRIDGE	EXCAV	UNIT EXCAVATION	NO	NUMBER
С	CONDUIT, CONDUCTOR	F. FT	FOOT, FEET	NTS	NOT TO SCALE
CAB	CABINET	FDN	FOUNDATION	ОН	OVERHEAD
CBW	CONCRETE BLOCK WALL	FO	FIBER OPTIC	PEC	POLYETHYLENE CONDUIT
CC	COMMUNICATIONS CENTER	GM	GROUND MOUNTED	PH	PHASE
CCTV	CLOSED CIRCUIT TELEVISION	GND. GRD	GROUND	PIN	PROJECT IDENTIFICATION NUMBER
CDOT	CDOT-CHICAGO DEPARTMENT OF TRANSPORTATION	GR	GUARD RAIL	PL	PROPERTY LINE
COMED	COMMONWEALTH EDISON	GSC	GALVANIZED STEEL CONDUIT	PNL	PANEL
CKT	CIRCUIT	HAR	HIGHWAY ADVISORY RADIO	PROP	PROPOSED
CLF	CHAIN LINK FENCE	HD	HEAVY DUTY	PTZ	PAN-TILT-ZOOM
CNC	COILABLE NONMETALLIC CONDUIT	НН	HANDHOLE	PVC	POLYVINYL CHLORIDE
COMM	COMMUNICATIONS	HPS	HIGH PRESSURE SODIUM	PVCC	POLYVINYL CHLORIDE COATED
CONC	CONCRETE	HYD	HYDRANT	R	EXISTING UNIT TO BE REMOVED (SALVAGED UNO)
CONST	CONSTRUCTION	ID	INNERDUCT	RC	REINFORCED CONCRETE
CORR	CORRUGATED	IDOT	ILLINOIS DEPARTMENT OF	RD	ROAD
CW	CONCRETE WALL	_	TRANSPORTATION	RGC	RIGID GALVANIZED STEEL
¢.	CENTERLINE	I	INTERSTATE		CONDUIT
DB	DIRECT BURIED	IN	INCHES	RM	RAMP METER
DC	DIRECT CURRENT	J, JB	JUNCTION BOX	ROW	RIGHT OF WAY
DF	DARK FIBER	KVA	KILOVOLT-AMPERE	RR	EXISTING UNIT TO BE REMOVED AND REINSTALLED
DIA	DIAMETER	KW	KILOWATT	RT	RIGHT
DMS	DYNAMIC MESSAGE SIGN			RW	RETAINING WALL
DWG	DRAWING(S)			17.11	NETAINING WALL

## GENERAL NOTES

SB

SHT

SM

SS

ST

STA

STD

STL

STRUCT

SURF

SURV

SW

TAN

TC

TEL

TS

TSC

TYP

UD

UND

UNO

WB WM

WP

XFMR

SOUTHBOUND

SINGLE MODE

STAINLESS STEEL

SHEET

STREET

STATION

STEEL

STANDARD

STRUCTURE

SURVEILLANCE

SURFACE

SIDEWALK TEMPORARY

TANGENT

TRAY CABLE

TRAFFIC SIGNAL

TRAFFIC SYSTEMS CENTER

UNLESS NOTED OTHERWISE

TELEPHONE

TYPICAL UNIT DUCT

VOLT WATT WESTBOUND

UNDERDRAIN

WALL MOUNTED

WOOD POLE

TRANSFORMER

- SEE DRAWING EI-100 AND EI-101 FOR ELECTRICAL SYMBOLS AND ABBREVIATIONS.
- REFER TO SHEETS EI-102, 103, 106, 110, 110A AND 115 FOR DETAILS AND SHEET E-301 FOR STANDARDS.
- 3. COORDINATE ALL WORK WITH OTHER IDOT CONTRACTS 62583, 62937, 62304, 62695 AND OTHER CONTRACTS AS APPLICABLE.
- COORDINATE CONDUIT INSTALLATION WITH THE ROADWAY CONTRACTOR'S STAGE CONSTRUCTION.
- 5. UNLESS NOTED OTHERWISE, ALL ITEMS AND WORK SHOWN IN HEAVY WEIGHT ARE PROPOSED, EXCEPT ROADWAY LINES.
- 6. ARTIFICIAL LIGHTING IS USED IN NIGHT OPERATIONS, CANNOT BE ENERGIZED FROM THE DEPARTMENT'S CONTROLLERS.
- 7. THE CONTRACTOR SHALL TAKE ALL NECESSARY SAFETY PRECAUTIONS TO PROTECT AND PROVIDE ACCESS TO ABUTTING PROPERTY, UTILITIES, PEDESTRIANS, AND VEHICULAR TRAFFIC.
- 8. ALL CONNECTIONS, EXTENSIONS TO MAKE THE LIGHTING SYSTEM FUNCTIONAL ARE INCLUDED IN THIS CONTRACT.
- 9. LIGHTING AND SURVEILLANCE RACEWAYS AND DUCTBANKS SHALL BE INSTALLED IN COMMON TRENCHES WHEREVER POSSIBLE. ANY ADDITIONAL TRENCH AND BACKFILL WORK PERFORMED BY THE CONTRACTOR TO FACILITATE INSTALLATION OF LIGHTING AND SURVEILLANCE RACEWAY, DUCTBANKS OR HANDHOLES WILL NOT BE MEASURED FOR PAYMENT BUT SHALL BE INCLUDED IN THE COST OF THIS CONTRACT.

23/EI-101

BMW

CHECKED BY:

REVISIONS NAME DATE		ILLINOIS DEPARTMENT OF TRANSPORTATION F.A.I. 94 (DAN RYAN EXPRESSWAY)					
			ELEC	TRICAL	ABBRE	VIATION	s
		SCALE.	NOT TO	SCALE	ne	AWN RY:	C-IM

DATE: MARCH 1, 2006

SINGH 300 W. ADAMS ST. CHICAGO, IL 60606
SINGH & ASSOCIATES, INC.
CONSULTING ENGINEERS FAX; (312) 629-0240