



Illinois Department of Transportation

2300 South Dirksen Parkway / Springfield, Illinois / 62764

April 22, 2005

SUBJECT: FAP 304 (Illinois Route 100)
Project SBIL-3(2)
Section 00-00010-01-HP
Village of Godfrey, Clifton Terrace Park Comfort Station
Contract No. 97239
Item 127
April 29, 2005 Letting
Addendum (A)

TO PROSPECTIVE BIDDERS:

Due to clarify information necessary to revise the following:

Proposal – Revised page 27, “SANITARY SEWER LATERAL”

Prime contractors must utilize the enclosed material when preparing their bid and must include any Schedule of Prices changes in their bidding proposal. Bidders using computer-generated bids are cautioned to reflect any and all Schedule of Prices changes, if involved, into their computer programs.

Since the proposal sheets are displayed back to back, bidders are cautioned to exercise care when inserting revised and/or added special provisions into their proposals.

Please call 217-782-7806 if any of the above-described material is not included in this transmittal.

Very truly yours,

Michael L. Hine
Engineer of Design and Environment

A handwritten signature in black ink, appearing to read 'Ted B. Walschleger DE'.

By: Ted B. Walschleger
Engineer of Project Development
and Implementation

the downstream distribution lines. The vents shall extend above the ground surface and be screened with ¼ inch mesh screen or equivalent.

- 7 Surface drainage shall be directed away from the filter.

DISCHARGE BASIN

At the outfall end of the sanitary sewer lateral the Contractor shall construct an earthen discharge basin with a stone bed as shown on the plans. The basin side slope shall be 4 to 1. The stone bed shall be 1.5 feet wide by 1.0 feet deep by 10.0 feet long and shall meet the gradation requirements of Article 1004.01 of the Standard Specifications for CA-1.

SANITARY SEWER LATERAL

- Revised
4.22.05
- 1 From a point 1 foot outside the restroom building walls, between the treatment units, and extending to the discharge basin, the Contractor shall furnish and install a 4 inch * sanitary sewer lateral and cleanouts for the restroom building in accordance with the "Standard Specifications for Water and Sewer Main Construction in Illinois," 5th Edition, dated May, 1996, Section 34 and as shown on the plans.
 - 2 Pipe materials shall be PVC, SDR 26. The grade for the sewer laterals shall be as shown on the plans.

TRENCH BACKFILL

Trench backfill material for the sanitary sewer construction shall be CA-7 from four (4") inches below pipe to one (1') foot above top of pipe. CA-6 shall be used from one (1') foot above top of pipe to subgrade when crossing bicycle path or roadway and compacted to 95% of the materials standard Proctor maximum dry density. Suitable excavated material may be use from one (1') foot above top of pipe to subgrade (topsoil) at other locations.