

PEDESTRIAN GATE ARRANGEMENT

VEHICLE GATE ARRANGEMENT

PULL POST ARRANGEMENT



LINE POST ARRANGEMENT

CORNER OF END POST ARRANGEMENT

- NOTES:**
- PULL POSTS SHALL BE PLACED AT LOCATIONS DETERMINED BY THE ENGINEER THEY SHALL BE PLACED AT 660-FOOT INTERVALS BETWEEN POSTS TO WHICH THE ENDS OF THE FABRIC ARE CLAMPED OR MIDWAY BETWEEN SUCH POSTS WHEN THE DISTANCE IS LESS THAN 1320' AND GREATER THAN 660'
 - WHERE FENCE HAS A CHANGE IN DIRECTION OF 15° OR MORE, A TERMINAL POST SHALL BE PLACED AS SHOWN ABOVE.

REVISIONS


NUMBER	BY	DATE




FOOTING FOR TERMINAL POST

FOOTING FOR GATE POST


FOOTING FOR LINE POST




SIGN DETAIL



METHOD OF FASTENING STRETCHER BAR TO POST




FENCE INSTALLATION ON SLOPES



ROLLER ASSEMBLY FOR SLIDING DRIVEWAY GATE


NOTE: GATE AND ROLLERS SHALL BE MOUNTED INBOARD
 CONTRACTOR SHALL SUBMIT SHOP DRAWINGS ENCLOSED
 TRUCK ROLLER ASSEMBLY FOR SLIDING DRIVEWAY GATES.



METHOD OF TYING FABRIC TO TENSION WIRE



METHOD OF TYING FABRIC TO PIPE



PROTECTIVE ELECTRICAL GROUND

- NOTES:**
- CONTINUOUS FENCE SHALL BE GROUNDED AT INTERVALS NOT EXCEEDING 1000' EXCEPT THERE SHALL BE A GROUND NOT EXCEEDING 100 FT. FROM A GATE IN EACH SECTION OF THE FENCE ADJACENT TO THE GATE.
 - FENCE UNDER POWER LINE SHALL BE GROUNDED BY THREE GROUNDS, ONE DIRECTLY UNDER THE CROSSING AND ONE ON EACH SIDE 25 TO 50 FT. AWAY. A SINGLE GROUND SHALL BE LOCATED DIRECTLY UNDER EACH TELEPHONE WIRE OR CABLE CROSSING.
 - THE COUNTERPOISE SHALL BE USED ONLY WHERE IT IS IMPOSSIBLE TO DRIVE A GROUND ROD BECAUSE OF AN IMPERVIOUS EARTH STRUCTURES.
 - THE GROUND WIRE SHALL BE CONNECTED TO FABRIC, TENSION WIRE, AND THE GROUND ROD BY A MECHANICAL CLAMP OF CAST BRONZE BODY AND BRONZE OR STAINLESS STEEL BOLTS AND WASHERS.

**LANSING MUNICIPAL AIRPORT
 LANSING, ILLINOIS**

**NORTH QUADRANT SITEMORK - PHASE 1
 AND TAXIWAY G2 EXTENSION**

FENCING DETAILS

© Copyright CMT, Inc.
CMT
 CRAWFORD, MURPHY & TILLY, INC.
 CONSULTING ENGINEERS
 License No. 194-000613



DESIGN BY:	ARM
DRAWN BY:	JRO
CHECKED BY:	ARM
APPROVED BY:	
DATE:	03/04/05
JOB No:	03297-02
IL PROJECT:	IGQ-3329
A.I.P. PROJECT:	3-17-0121-B21
SHEET	27 OF 50 SHEETS