

DRAINAGE SHEET STA 224+00 TO STA 236+00 (SEE SHEET 91)

PIPE NUMBER	STRUCTURE		DESCRIPTION	CLASS	TYPE	SIZE (IN)	LENGTH (FT)	SLOPE (%)	TBF (CY)
	FROM	TO							
3-1	3-1	3-2	STORM SEWERS	A	1	12	48	1.00%	8
3-2	3-2	3-3	STORM SEWERS	A	2	12	55	1.00%	13
3-3	3-3	3-4	STORM SEWERS	A	2	12	5	1.00%	2
3-4	3-5	3-4	STORM SEWERS	A	1	12	6	1.00%	
3-5	3-6	3-5	STORM SEWERS	A	1	12	58	1.00%	
3-6	3-4	3-7	STORM SEWERS	A	2	15	121	0.75%	94
3-7	3-8	3-7	STORM SEWERS	A	2	12	4	1.00%	4
3-8	3-9	3-8	STORM SEWERS	A	2	12	45	1.00%	17
3-9	3-10	3-9	STORM SEWERS	A	2	12	58	1.00%	18
3-10	3-11	3-10	STORM SEWERS	WM REQ		12	25	1.00%	4
3-11	3-7	3-13	STORM SEWERS	A	2	21	110	0.75%	94
3-12	3-12	3-13	STORM SEWERS	A	1	12	8	1.00%	
3-13	3-14	3-13	STORM SEWERS	A	2	12	4	1.00%	3
3-14	3-15	3-14	STORM SEWERS	A	2	12	40	1.00%	11
3-15	3-16	3-15	STORM SEWERS	A	2	12	62	1.00%	13
3-16	3-13	3-17	STORM SEWERS	WM REQ		21	52	0.75%	46
3-17	3-17	3-18	STORM SEWERS	WM REQ		24	73	0.75%	67
3-18	3-19	3-18	STORM SEWERS	A	2	12	5	1.00%	
3-19	3-20	3-19	STORM SEWERS	A	1	12	56	1.00%	1
3-20	3-21	3-18	STORM SEWERS	A	2	15	4	1.00%	4
3-21	3-22	3-21	STORM SEWERS	A	2	15	40	1.00%	27
3-22	3-23	3-22	STORM SEWERS	A	2	12	62	1.00%	23
3-23	3-24	3-23	STORM SEWERS	A	2	12	13	1.00%	6
3-24	3-25	3-24	STORM SEWERS	WM REQ		12	63	1.00%	
3-25	3-26	3-25	STORM SEWERS	WM REQ		12	37	1.00%	8
3-26	3-18	3-27	STORM SEWERS	A	2	24	236	0.75%	213
3-27	3-28	3-27	STORM SEWERS	A	1	12	6	1.00%	2
3-28	3-27	3-29	STORM SEWERS	A	2	24	106	0.75%	
3-29	3-30	3-29	STORM SEWERS	A	2	15	4	1.00%	3
3-30	3-31	3-30	STORM SEWERS	A	2	12	68	1.00%	18
3-31	3-32	3-31	STORM SEWERS	A	2	12	42	1.00%	9
3-32	3-33	3-32	STORM SEWERS	A	1	12	14	1.00%	3
3-33	3-29	3-34	STORM SEWERS	WM REQ		27	146	0.75%	132
3-34	3-35	3-34	STORM SEWERS	A	2	12	4	1.00%	2
3-35	3-36	3-35	STORM SEWERS	A	2	12	49	1.00%	12
3-36	3-37	3-36	STORM SEWERS	A	2	12	54	1.00%	8
3-37	3-34	3-38	STORM SEWERS	A	2	30	145	0.75%	134
3-38	3-39	3-38	STORM SEWERS	A	2	12	4	1.00%	2
3-39	3-40	3-39	STORM SEWERS	A	1	12	106	1.00%	19
3-40	3-38	4-3	STORM SEWERS	A	2	36	135	0.50%	182