

AH1
STA. 4011+40
51.6' LT
4.0' SET BACK

NOTE 5
(TYP. UNLESS
NOTED
OTHERWISE)

NOTE 4

AD1
STA. 4016+82
60.3' LT
3.0' SET BACK

AC1
STA. 4019+50
51.1' LT
3.5' SET BACK

MATCH LINE STA. 4010+00

MATCH LINE STA. 4023+00

AE1
STA. 4011+40
62.0' RT
4.0' SET BACK
NOTE 11

LIGHTING CONTROLLER "A"
240/120V, 1PH, 3W
STA. 4012+51.7
75.3' RT
NOTE 10

COMBINATION LIGHTING
CONTROLLER "UG"
NOTE 9

MATCH LINE STA. 501+25
BROOKDALE RD.


AA1
STA. 4016+93
51.6' RT
4.0' SET BACK

AB1
STA. 4019+50
NOTE 8

STA. 4022+18
0.0' RT

NOTES

1. FOR SYMBOL LIST AND ABBREVIATIONS, SEE SHEET LT-01.
2. COMBINATION TRAFFIC SIGNAL - LIGHTING POLES SHALL BE INSTALLED UNDER TRAFFIC SIGNAL CONTROL WORK. SEE TRAFFIC SIGNAL PLANS. LUMINAIRE SHALL BE PAID FOR UNDER ELECTRICAL WORK.
3. UNIT DUCT, 600V, 4-1C NO.8, 1/C NO.8 GROUND, (XLP-TYPE USE), 3/4" DIA. POLYETHYLENE.
4. UNIT DUCT, 600V, 2-1C NO.8, 1/C NO.8 GROUND, (XLP-TYPE USE), 3/4" DIA. POLYETHYLENE.
5. UNIT DUCT, 600V, 4-1C NO.4, 1/C NO.6 GROUND, (XLP-TYPE USE), 1 1/4" DIA. POLYETHYLENE.
6. UNIT DUCT, 600V, 8-1C NO.4, 1/C NO.6 GROUND, (XLP-TYPE USE), 1 1/2" DIA. POLYETHYLENE.
7. POLE SET-BACK SHALL BE MEASURED FROM THE BACK OF THE CURB TO THE CENTER OF THE POLE/BASE.
8. LIGHTING UNIT INSTALLED ON LIGHT POLE FOUNDATION, SPECIAL. SEE ROADWAY DETAILS AND SCHEDULE OF QUANTITIES.
9. COMBINATION LIGHTING CONTROLLER SHALL BE ATTACHED TO TRAFFIC SIGNAL CONTROL CABINET. SEE EXACT LOCATION ON TRAFFIC SIGNAL PLANS. CONTROLLER OWNED AND MAINTAINED BY I.D.O.T..
10. CONTROLLER OWNED AND MAINTAINED BY CITY OF NAPERVILLE. POWER SHALL BE SUPPLIED BY NAPERVILLE ELECTRIC DEPARTMENT (NED) AND NED REQUIREMENTS FOR INSTALLATION SHALL BE MET.
11. PROVIDE A LOCKING-TYPE RECEPTACLE ON THE FIXTURE. INSTALL LOCKING-TYPE PHOTOELECTRIC CONTROL ON TOP OF LUMINAIRE AND WIRE IT TO THE LIGHTING CONTROLLER FOLLOWING THE CITY OF NAPERVILLE STANDARDS. PARTS AND WORK SHALL BE INCLUDED IN THE "PHOTOCELL" PAY ITEM.
12. SEE DISTRICT ONE DETAIL BE-230 FOR COMBINATION LIGHTING AND TRAFFIC SIGNAL ELECTRIC SERVICE DISCONNECT.
13. UNIT DUCT, 600V, 4-1C NO.4, 3-1C NO.10, 1/C NO.6 GROUND, (XLP-TYPE USE), 1 1/4" DIA. POLYETHYLENE.



DESIGNED MCP	REVISED - ADDENDUM A 02/22/2013	STATE OF ILLINOIS DEPARTMENT OF TRANSPORTATION	LIGHTING PLANS - ILLINOIS ROUTE 59 AND BROOKDALE ROAD		F.A.P. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.		
DRAWN MCB	REVISED -		SCALE: AS SHOWN	SHEET NO. 3 OF 8 SHEETS	STA.	TO STA.	33B	(112 & 113) WRS-6	DUPAGE	734	479
CHECKED MCP	REVISED -						LT-08		CONTRACT NO. 60R31		
DATE 09/07/2012	REVISED -						ILLINOIS FED. AID PROJECT				