



EL. +9.50

EL. -8.50

EL. -26.50

EL. -48.00

NOTE:  
 1. ALL ROOM EXCEPT ELECTRICAL CONTROL ROOM SHALL BE CLASS I, DIVISION 1, GROUP D EXPLOSION PROOF.

SECTION C-C



SCALE: 0 4 8 12

M4

REVISIONS	
NAME	DATE

ILLINOIS DEPARTMENT OF TRANSPORTATION

PUMP STATION NO. 27  
REHABILITATION

MECHANICAL SECTION

SCALE: AS SHOWN  
DATE: 04-23-10

DRAWN BY: HFF  
CHECKED BY: KHC