



Stainless steel standard grade wire cloth,  
6x6 (1/4") mesh or less with #16 gauge  
(0.062") diameter or heavier wire.

Attach with 1/2" stainless steel banding  
or tie back on itself with stainless steel wire ties.  
Finished installation must prevent rodent entry.

## WIRING DETAIL

### GENERAL NOTES

All taped splices shall use 2 layers of electrical tape over 3 layers of rubber tape as required by the Standard Specifications. Coat the finished taped splice with bonding compound.

All cable splices shall be taped unless another method has been specifically approved by the Engineer.

For example purposes the pole is shown on an anchor base. If the pole is required to be set on a breakaway base, consult the Standard Specifications.

All dimensions are in millimeters (inches) unless otherwise shown.

FILE NAME = #FILE#	USER NAME = #USER#	DESIGNED -	REVISED - Updated 7/31/08	<b>STATE OF ILLINOIS DEPARTMENT OF TRANSPORTATION</b>	<b>DETAIL: POLE HANDHOLE WIRING</b>	F.A. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
		DRAWN -	REVISED -			*	OX1-6-2K-1(K1X-1DR-4	WILLIAMSON	194	118
	PLOT SCALE = #SCALE#	CHECKED -	REVISED -			*	I-57/IL 13 (FAI 57/FAP 331)	CONTRACT NO. 78194		
	PLOT DATE = #DATE#	DATE -	REVISED -		SCALE: none	SHEET NO.	OF	SHEETS	STA.	TO STA.
ILLINOIS FED. AID PROJECT										