



- GENERAL PLAN NOTES:**
1. STREETSCAPE LIGHTING CONTROL PANEL SHALL BE PAD MOUNTED. SEE ELECTRICAL DRAWING 38.
 2. ALL LIGHTING FIXTURES AND RECEPTACLES SHALL BE CONNECTED TO THEIR RESPECTIVE STREETSCAPE LIGHTING CONTROL PANEL. SEE ELECTRICAL DRAWING 38 FOR INSTALLATION DETAILS.
 3. CONDUITS SHALL BE 4'-0" BELOW GRADE WHERE REQUIRED TO BE BELOW FOUNDATION WALL.
 4. ALL PUSHED CONDUITS SHALL BE INSTALLED AT THE SAME TIME. SEE ELECTRICAL DRAWING 37 FOR CONDUITS TO BE INSTALLED FOR COMED UTILITY FEEDERS

1 57TH STREET ELECTRICAL PLAN
1"=10'



TENG & ASSOCIATES, INC.
ENGINEERS/ARCHITECTS/PLANNERS
205 N. MICHIGAN AVE. CHICAGO, IL 60601
TELEPHONE: 312/616-0000

FILE NAME = \$FILEL\$	USER NAME = \$USER\$	DESIGNED --	REVISED -- 2 11/3/2008
		DRAWN -- IC	REVISED --
		CHECKED -- PR	REVISED --
		DATE -- 4/30/09	REVISED --
PLOT SCALE = \$SCALE\$			
PLOT DATE = 8/22/08			

**STATE OF ILLINOIS
DEPARTMENT OF TRANSPORTATION**

57TH STREET ELECTRICAL PLAN	
SCALE: AS NOTED	STA. TO STA.

F.A. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
	07-00035-00-LS	COOK	42	34
CONTRACT NO. 63059				
FED. ROAD DIST. NO. 1 ILLINOIS FED. AID PROJECT				