



NOTES:
 1. FOR GENERAL AND CONSTRUCTION NOTES SEE SHEET 287.

- LEGEND**
- PROPOSED ELECTRIC SERVICE INSTALLATION, 120V/240V, 60A
 - ▢ PROPOSED LIGHTING CONTROLLER SINGLE DOOR, B-RCS, 60A, 120V/240V
 - CIRCUIT DESIGNATION — A1 — LUMINAIRE NUMBER
 - PROPOSED UNDERPASS LUMINAIRE 70 WATT, HIGH PRESSURE SODIUM VAPOUR
 - — — CONDUIT IN TRENCH, 1" DIA., PVC SCHEDULE 40, UNLESS OTHERWISE NOTED, WITH 3-1/c NO. 10 AND 1-1/c NO. 10 GROUND (EPR-TYPE RHW)
 - [] CONDUIT EMBEDDED IN STRUCTURE 1" DIA., PVC, WITH 3-1/c NO.10 AND 1-1/c NO. 10 GROUND (EPR-TYPE RHW)
 - PROPOSED ELECTRICAL JUNCTION BOX, 4" x 4" x 3". EMBEDDED IN STRUCTURE

x:\35006\3944\engineering\documents\Lighting\p\p\h_abc\Underpass_Dun_Ip_01.dgn

FILE NAME = #FILES#	USER NAME = #USER#	DESIGNED - XXX	REVISED - ADDENDUM 6/5/09	KANE COUNTY DIVISION OF TRANSPORTATION	UNDERPASS LIGHTING PLAN DUNHAM ROAD / IL 25				F.A. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.		
		DRAWN - VLM	REVISED -		SCALE:	SHEET NO.	OF	SHEETS	STA.	TO STA.	FED. ROAD DIST. NO.	ILLINOIS FED. AID PROJECT			
		PLOT SCALE = 20.0000' / IN.	CHECKED - GHT												
		PLOT DATE = 6/4/2009	DATE - 3/31/09												
											361	06-00214-15-BR	KANE/DUPAGE	545	272
											CONTRACT NO. 63074				