

# GENERAL NOTES

ROUTE NO.	SEC.	COUNTY	TOTAL SHEETS	SHEET NO.
FAI 80	(81-1WS-2)M-1	Rock Island	18	4
FED ROAD DIST. NO.	ILLINOIS	PROJECT		
Contract #64D93				

The Contractor shall be responsible for protecting utility property during construction operations as outlined in Article 107.31 of the Standard Specifications. A minimum of 48 hours advance notice is required for non-emergency work. The JULIE number is 800-892-0123. The following listed utilities located within the project limits or immediately adjacent to the project construction limits are members of JULIE:

Mr. Dave Creen  
AT&T  
635-18<sup>th</sup> Street  
Rock Island, IL 61201  
(309)-793-4456

Mr. Matthew J. Chancellor  
MidAmerican Energy Company  
2811 5<sup>th</sup> Ave.  
Rock Island, IL 61201  
(309)-793-3833

Mr. Steve Hampton  
MidAmerican Energy Company  
2811 5<sup>th</sup> Ave.  
Rock Island, IL 61201  
(309)-793-3707

Mr. Davis Day  
Frontier / Citizens  
684 N. Broad / P.O. Box 12  
Lanark, IL 61046  
(815)-493-1101

Mr. Dennis Jarding  
Mediacom  
3900 - 26<sup>th</sup> Avenue  
Moline, IL 61265  
(309)-743-4750

Rapid City Village Office  
1204 - 4<sup>th</sup> Ave.  
Rapid City, IL 61278  
(309)-496-2321

## JULIE 1-800-892-0123

The Contractor shall seed and restore all disturbed areas within the project limits, this work shall be included in the cost of "REMOVAL" pay items. Seeding Class 1 in front of properties where the grass will be mowed.

Previously pugmilled stockpiles of "Type A" older than 1 month will not be approved for use until a moisture check is run to verify moisture content. Material shipped to projects without being tested will not be accepted.

Except for the top 75 mm (3"), all aggregate bases and subbases 300 mm (12") in thickness shall be constructed of aggregate gradation CA-2. If the specified thickness exceeds 300 mm (12"), the bases or subbases shall be constructed of topsize 150 mm (6") breaker-run crushed stone with 70% to 90% by weight, passing the 4" sieve and 15% to 40% by weight, passing the 50 mm (2") size sieve, except for the top 75 mm (3"). The breaker-run crushed stone shall be reasonably uniformly graded from coarse to fine and be taken from a quarry ledge capable of producing Class "D" quality aggregate. The top 75 mm (3") shall be gradation CA-6 or CA-10 regardless of thickness. The water necessary to achieve compaction in all but the top 75 mm (3") layer may be added after the subbase or base course is placed on the grade.

Tie bars shall be installed to tie PCC appurtenance to adjacent existing concrete pavement.

Tie the following to the existing concrete pavement		Length, size, and spacing of Tie Bars
PCC Base Course	Std. 353001	600 mm (24") long No. 20 (No. 6) @ 750 mm (30") centers
PCC Pavement	Std. 420101	600 mm (24") long No. 20 (No. 6) @ 750 mm (30") centers
Gutter or Curb & Gutter	Std. 606001	600 mm (24") long No. 20 (No. 6) @ 600 mm (24") centers

Tie bars to be installed in accordance with the applicable portions of the Article 420.05(b) of the Standard Specifications. See Highway Standard 420001 for detail on longitudinal construction joint grouted-in-place tie bar. The cost of the tie bars to be included in the cost of the PCC appurtenance adjacent to the existing pavement.

The Contractor shall be required to notify the Department of Transportation at (815)285-5474 one week prior to closing and opening of the weigh station. The Contractor shall also be required to notify the Operations Lieutenant, Darin Johnson, at (309) 752-4915, two weeks prior to closing and opening the weigh station.

Program #5  
(Arch. Size)  
Enlarge  
200%  
Enlarge 107%