

01A

Letting June 13, 2025

Notice to Bidders, Specifications and Proposal



**Illinois Department
of Transportation**

Springfield, Illinois 62764

**Contract No. MR026
Morris Municipal Airport
Morris, Illinois
Grundy County
Illinois Project No. C09-5011
SBG Project No. N/A**



1. TIME AND PLACE OF OPENING BIDS. Electronic bids are to be submitted to the electronic bidding system (iCX-Integrated Contractors Exchange). All bids must be submitted to the iCX system prior to 12:00 p.m. on June 13, 2025, at which time the bids will be publicly opened from the iCX SecureVault.

2. DESCRIPTION OF WORK. The proposed improvement is identified and advertised for bids in the Invitation for Bids as:

**Contract No. MR026
Morris Municipal Airport
Morris, Illinois
Grundy County
Illinois Project No. C09-5011
SBG Project No. N/A**

Construct Crosswind Runway 7/25

For engineering information, please contact Casey McCollom, P.E. of Chamlin & Associates at 815.942.1402.

3. INSTRUCTIONS TO BIDDERS.

- (a) This Notice, the invitation for bids, proposal and letter of award shall, together with all other documents in accordance with Article 10-23 of the Standard Specifications for Construction of Airports (Adopted March 22, 2023), become part of the contract. Bidders are cautioned to read and examine carefully all documents, to make all required inspections, and to inquire or seek explanation of the same prior to submission of a bid.
- (b) State law, and, if the work is to be paid wholly or in part with Federal-aid funds, Federal law requires the bidder to make various certifications as a part of the proposal and contract. By execution and submission of the proposal, the bidder makes the certification contained therein. A false or fraudulent certification shall, in addition to all other remedies provided by law, be a breach of contract and may result in termination of the contract.

4. AWARD CRITERIA AND REJECTION OF BIDS. This contract will be awarded within 90 calendar days to the lowest responsive and responsible bidder considering conformity with the terms and conditions established by the Department in the rules, Invitation for Bids and contract documents. The issuance of plans and proposal forms for bidding based upon a prequalification rating shall not be the sole determinant of responsibility. The Department reserves the right to determine responsibility at the time of award, to reject any or all proposals, to readvertise the proposed improvement, and to waive technicalities.

5. PRE-BID CONFERENCE. N/A

6. DISADVANTAGED BUSINESS POLICY. The DBE goal for this contract is 14.0%.

7. SPECIFICATIONS AND DRAWINGS. The work shall be done in accordance with the Standard Specifications for Construction of Airports (Adopted March 22, 2023), the Special Provisions dated April 23, 2025, and the Construction Plans dated April 23, 2025 as approved by the Illinois Department of Transportation, Division of Aeronautics.

8. BIDDING REQUIREMENTS AND BASIS OF AWARD. When alternates are included in the proposal, the following shall apply:

a. Additive Alternates

(1) Bidders must submit a bid for the Base Bid and for all Additive Alternates.

(2) Award of this contract will be made to the lowest responsible qualified bidder computed as follows:

The lowest aggregate amount of (i) the Base Bid plus (ii) any Additive Alternate(s) which the Department elects to award.

The Department may elect not to award any Additive Alternates. In that case, award will be to the lowest responsible qualified bidder of the Base Bid.

b. Optional Alternates

(1) Bidders must submit a bid for the Base Bid and for either Alternate A or Alternate B or for both Alternate A and Alternate B.

(2) Award of this contract will be made to the lowest responsible qualified bidder computed as follows:

The lower of the aggregate of either (i) the Base Bid plus Alternate A or (ii) the Base Bid plus Alternate B.

9. CONTRACT TIME. The Contractor shall complete all work within the specified contract time. Any calendar day extension beyond the specified contract time must be fully justified, requested by the Contractor in writing, and approved by the Engineer, or be subject to liquidated damages.

The contract time for this contract is 723 calendar days.

10. INDEPENDENT WEIGHT CHECKS. The Department reserves the right to conduct random unannounced independent weight checks on any delivery for bituminous, aggregate or other pay item for which the method of measurement for payment is based on weight. The weight checks will be accomplished by selecting, at random, a loaded truck and obtaining a loaded and empty weight on an independent scale. In addition, the department may perform random weight checks by obtaining loaded and empty truck weights on portable scales operated by department personnel.

11. MATERIAL COST ADJUSTMENTS. The Illinois Department of Transportation, Division of Aeronautics does not offer any material cost adjustment provisions.

12. GOOD FAITH COMPLIANCE. The Illinois Department of Transportation has made a good faith effort to include all statements, requirements, and other language required by federal and state law and by various offices within federal and state governments whether that language is required by law or not. If anything of this nature has been left out or if additional language etc. is later required, the bidder/contractor shall cooperate fully with the Department to modify the contract or bid documents to correct the deficiency. If the change results in increased operational costs, the Department shall reimburse the contractor for such costs as it may find to be reasonable.

By Order of the
Illinois Department of Transportation

Gia Biagi,
Acting Secretary

State of Illinois
Department of Transportation

SPECIAL PROVISION
FOR
EEO

Effective: July 21, 1978
Revised: November 18, 1980

The requirements of the following provisions written for federally-assisted construction contracts, including all goals and timetables and affirmative action steps, shall also apply to all State-funded construction contracts awarded by the Illinois Department of Transportation.

Notice of Requirement for Affirmative Action to Ensure
Equal Employment Opportunity (Executive Order 11246)

1. The offeror's or bidder's attention is called to the "Equal Opportunity Clause" and the "Standard Federal Equal Employment Opportunity Construction Contract Specifications" set forth herein.
2. The goals and timetables for minority and female participation, expressed in percentage terms for the Contractor's aggregate workforce in each trade on all construction work in the covered area, are as follows:

APPENDIX A

The following goal for female utilization in each construction craft and trade shall apply to all Contractors holding Federal and federally assisted construction contracts and subcontracts in excess of \$10,000. The goal is applicable to the Contractor's total on-site construction workforce, regardless of whether or not part of that workforce is performing work on a federal, federally assisted or nonfederally related construction contract or subcontract.

Area Covered (Statewide)

Goals for Women apply nationwide.

GOAL	Goal (percent)
Female Utilization	6.9

APPENDIX B

Until further notice, the following goals for minority utilization in each construction craft and trade shall apply to all Contractors holding federal and federally-assisted construction contracts and subcontracts in excess of \$10,000 to be performed in the respective geographical areas. The goals are applicable to the Contractor's total on-site construction workforce, regardless of whether or not part of that workforce is performing work on a federal, federally-assisted or nonfederally related construction contract or subcontract.

	<u>Economic Area</u>	Goal (percent)
056	Paducah, KY: Non-SMSA Counties - IL - Hardin, Massac, Pope KY - Ballard, Caldwell, Calloway, Carlisle, Crittenden, Fulton, Graves, Hickman, Livingston, Lyon, McCracken, Marshall	5.2
080	Evansville, IN: Non-SMSA Counties - IL - Edwards, Gallatin, Hamilton, Lawrence, Saline, Wabash, White IN - Dubois, Knox, Perry, Pike, Spencer KY - Hancock, Hopkins, McLean, Mublenberg, Ohio, Union, Webster	3.5
081	Terre Haute, IN: Non-SMSA Counties - IL - Clark, Crawford IN - Parke	2.5

083	Chicago, IL: SMSA Counties: 1600 Chicago, IL - IL - Cook, DuPage, Kane, Lake, McHenry, Will 3740 Kankakee, IL - IL - Kankakee Non-SMSA Counties IL - Bureau, DeKalb, Grundy, Iroquois, Kendall, LaSalle, Livingston, Putnam IN - Jasper, Laporte, Newton, Pulaski, Starke	19.6 9.1 18.4
084	Champaign - Urbana, IL: SMSA Counties: 1400 Champaign - Urbana - Rantoul, IL - IL - Champaign Non-SMSA Counties - IL - Coles, Cumberland, Douglas, Edgar, Ford, Piatt, Vermilion	7.8 4.8
085	Springfield - Decatur, IL: SMSA Counties: 2040 Decatur, IL - IL - Macon 7880 Springfield, IL - IL - Menard, Sangamon Non-SMSA Counties IL - Cass, Christian, Dewitt, Logan, Morgan, Moultrie, Scott, Shelby	7.6 4.5 4.0
086	Quincy, IL: Non-SMSA Counties IL - Adams, Brown, Pike MO - Lewis, Marion, Pike, Ralls	3.1
087	Peoria, IL: SMSA Counties: 1040 Bloomington - Normal, IL - IL - McLean 6120 Peoria, IL - IL - Peoria, Tazewell, Woodford Non-SMSA Counties - IL - Fulton, Knox, McDonough, Marshall, Mason, Schuyler, Stark, Warren	2.5 4.4 3.3
088	Rockford, IL: SMSA Counties: 6880 Rockford, IL - IL - Boone, Winnebago Non-SMSA Counties - IL - Lee, Ogle, Stephenson	6.3 4.6
098	Dubuque, IA: Non-SMSA Counties - IL - JoDaviess IA - Atlamakee, Clayton, Delaware, Jackson, Winnesheik WI - Crawford, Grant, Lafayette	0.5
099	Davenport, Rock Island, Moline, IA - IL: SMSA Counties: 1960 Davenport, Rock Island, Moline, IA - IL - IL - Henry, Rock Island IA - Scott Non-SMSA Counties - IL - Carroll, Hancock, Henderson, Mercer, Whiteside IA - Clinton, DesMoines, Henry, Lee, Louisa, Muscatine MO - Clark	4.6 3.4

107	St. Louis, MO: SMSA Counties: 7040 St. Louis, MO - IL -	14.7
	IL - Clinton, Madison, Monroe, St. Clair MO - Franklin, Jefferson, St. Charles, St. Louis, St. Louis City Non-SMSA Counties -	11.4
	IL - Alexander, Bond, Calhoun, Clay, Effingham, Fayette, Franklin, Greene, Jackson, Jasper, Jefferson, Jersey, Johnson, Macoupin, Marion, Montgomery, Perry, Pulaski, Randolph, Richland, Union, Washington, Wayne, Williamson MO - Bollinger, Butler, Cape Girardeau, Carter, Crawford, Dent, Gasconade, Iron, Lincoln, Madison, Maries, Mississippi, Montgomery, Perry, Phelps, Reynolds, Ripley, St. Francois, St. Genevieve, Scott, Stoddard, Warren, Washington, Wayne	

These goals are applicable to all the Contractor's construction work (whether or not it is federal or federally assisted) performed in the covered area. If the Contractor performs construction work in a geographical area located outside of the covered area, it shall apply the goals established for such geographical area where the work is actually performed. With regard to this second area, the Contractor also is subject to the goals for both its federally involved and nonfederally involved construction.

The Contractor's compliance with Executive Order 11246 and the regulations in 41 CFR Part 60-4 shall be based on its implementation of the Equal Opportunity Clause, specific affirmative action obligations required by the provisions and specifications set forth in its federally assisted contracts, and its efforts to meet the goals established for the geographical area where the contract resulting from this solicitation is to be performed. The hours of minority and female employment and training must be substantially uniform throughout the length of the contract, and in each trade, and the Contractor shall make a good faith effort to employ minorities and women evenly on each of its projects. The transfer of minority or female employees or trainees from Contractor to Contractor or from project to project for the sole purpose of meeting the Contractor's goals shall be a violation of the contract, the Executive Order 11246 and the regulations in 41 CFR Part 60-4. Compliance with the goals will be measured against the total work hours performed.

3. The Illinois Department of Transportation will provide written notification to the Director of the Office of Federal Contract Compliance Programs within ten working days of award of any construction contract and/or subcontract in excess of \$10,000 at any tier for construction work under the contract resulting from this solicitation. This notification will list the name, address and telephone number of the subcontractor; employer identification number; estimated dollar amount of the subcontract; estimated starting and completion dates of the subcontract; and the geographical area in which the contract is to be performed.
4. As used in this Notice, and in the contract resulting from this solicitation, the "covered area" is the entire State of Illinois for the goal set forth in APPENDIX A and the county or counties in which the work is located for the goals set forth in APPENDIX B.

STANDARD FEDERAL EQUAL EMPLOYMENT OPPORTUNITY CONSTRUCTION CONTRACT SPECIFICATIONS (EXECUTIVE ORDER 11246)

1. As used in these specifications:
 - (a) "Covered area" means the geographical area described in the solicitation from which this contract resulted;
 - (b) "Director" means Director, Office of Federal Contract Compliance Programs, United States Department of Labor, or any person to whom the Director delegates authority;
 - (c) "Employer identification number" means the Federal Social Security number used on the Employer's Quarterly Federal Tax Return, U.S. Treasury Department Form 941;
 - (d) "Minority" includes:
 - (i) Black (all persons having origins in any of the Black African racial groups not of Hispanic origin);
 - (ii) Hispanic (all persons of Mexican, Puerto Rican, Cuban, Central or South American or other Spanish Culture or origin, regardless of race);
 - (iii) Asian and Pacific Islander (all persons having origins in any of the original peoples of the Far East, Southeast Asia, the Indian Subcontinent, or the Pacific Islands); and
 - (iv) American Indian or Alaskan Native (all persons having origins in any of the original peoples of North America and maintaining identifiable tribal affiliations through membership and participation or community identification).
2. Whenever the Contractor, or any Subcontractor at any tier, subcontracts a portion of the work involving any construction trade, it shall physically include in each subcontract in excess of \$10,000. the provisions of these specifications and the Notice which contains the applicable goals for minority and female participation and which is set forth in the solicitations from which this contract resulted.
3. If the Contractor is participating (pursuant to 41 CFR 60-4.5) in a Hometown Plan approved by the U.S. Department of Labor in the covered area either individually or through an association, its affirmative action obligations on all work in the plan area (including goals and timetables) shall be in accordance with that Plan for those trades which have unions participating in the Plan. Contractors must be able to demonstrate their participation in and compliance with the provisions of any such Hometown Plan. Each Contractor or Subcontractor participating in an approved Plan is individually required to comply with its obligations under the EEO clause, and to make a good faith effort to achieve each goal under the Plan in each trade in which it has employees. The overall good faith performance by other Contractors or Subcontractors toward a goal in an approved Plan does not excuse any covered Contractor's or Subcontractor's failure to take good faith efforts to achieve the Plan goals and timetables.

4. The Contractor shall implement the specific affirmative action standards provided in paragraphs 7a through p of these specifications. The goals set forth in the solicitation from which this contract resulted are expressed as percentages of the total hours of employment and training of minority and female utilization the Contractor should reasonably be able to achieve in each construction trade in which it has employees in the covered area. Covered Construction Contractors performing construction work in geographical areas where they do not have a Federal or federally assisted construction contract shall apply the minority and female goals established for the geographical area where the work is being performed. Goals are published periodically in the Federal Register in notice form, and such notices may be obtained from any Office of Federal Contract Compliance Programs office or from Federal procurement contracting officers. The Contractor is expected to make substantially uniform progress toward its goals in each craft during the period specified.
5. Neither the provisions of any collective bargaining agreement, nor the failure by a union with whom the Contractor has a collective bargaining agreement, to refer either minorities or women shall excuse the Contractor's obligations under these specifications, Executive Order 11246, or the regulations promulgated pursuant thereto.
6. In order for the nonworking training hours of apprentices and trainees to be counted in meeting the goals, such apprentices and trainees must be employed by the Contractor during the training period, and the Contractor must have made a commitment to employ the apprentices and trainees at the completion of their training, subject to the availability of employment opportunities. Trainees must be trained pursuant to training programs approved by the U.S. Department of Labor.
7. The Contractor shall take specific affirmative actions to ensure equal employment opportunity. The evaluation of the Contractor's compliance with these specifications shall be based upon its effort to achieve maximum results from its actions. The Contractor shall document these efforts fully, and shall implement affirmative action steps at least as extensive as the following:
 - (a) Ensure and maintain a working environment free of harassment, intimidation, and coercion at all sites, and in all facilities at which the Contractor's employees are assigned to work. The Contractor, where possible, will assign two or more women to each construction project. The Contractor shall specifically ensure that all foremen, superintendents, and other on-site supervisory personnel are aware of and carry out the Contractor's obligation to maintain such a working environment, with specific attention to minority or female individuals working as such sites or in such facilities.
 - (b) Establish and maintain a current list of minority and female recruitment sources, provide written notification to minority and female recruitment sources and to community organizations when the Contractor or its unions have employment opportunities available, and maintain a record of the organizations' responses.
 - (c) Maintain a current file of the names, addresses and telephone numbers of each minority and female off-the-street applicant and minority or female referral from a union, a recruitment source or community organization and of what action was taken with respect to each such individual. If such individual was sent to the union hiring hall for referral and was not referred back to the Contractor by the union or, if referred, not employed by the Contractor, this shall be documented in the file with the reason therefor, along with whatever additional actions the Contractors may have taken.
 - (d) Provide immediate written notification to the Director when the union or unions with which the Contractor has a collective bargaining agreement has not referred to the Contractor a minority person or woman sent by the Contractor, or when the Contractor has other information that the union referral process has impeded the Contractor's efforts to meet its obligations.
 - (e) Develop on-the-job training opportunities and/or participate in training programs for the area which expressly include minorities and women, including upgrading programs and apprenticeship and trainee programs relevant to the Contractor's employment needs, especially those programs funded or approved by the Department of Labor. The Contractor shall provide notice of these programs to the sources compiled under 7b above.
 - (f) Disseminate the Contractor's EEO policy by providing notice of the policy to unions and training programs and requesting their cooperation in assisting the Contractor in meeting its EEO obligations; by including it in any policy manual and collective bargaining agreements; by publicizing it in the company newspaper, annual report, etc.; by specific review of the policy with all management personnel and with all minority and female employees at least once a year; and by posting the company EEO policy on bulletin boards accessible to all employees at each location where construction work is performed.
 - (g) Review, at least annually, the company's EEO policy and affirmative action obligations under these specifications with all employees having any responsibility for hiring, assignment, layoff, termination or other employment decisions including specific review of these items with onsite supervisory personnel such as Superintendents, General Foreman, etc., prior to the initiation of construction work at any job site. A written record shall be made and maintained identifying the time and place of these meetings, persons attending, subject matter discussed, and disposition of the subject matter.
 - (h) Disseminate the Contractor's EEO policy externally by including it in any advertising in the news media, specifically including minority and female news media, and providing written notification to and discussing the Contractor's EEO policy with other Contractors and Subcontractors with whom the Contractor does or anticipates doing business.
 - (i) Direct its recruitment efforts, both oral and written, to minority, female and community organizations, to schools with minority and female students and to minority and female recruitment and training organizations serving the Contractor's recruitment area and employment needs. Not later than one month prior to the date for the acceptance of applications for apprenticeship or other training by any recruitment source, the Contractor shall send written notification to organizations such as the above, describing the openings, screening procedures, and tests to be used in the selection process.
 - (j) Encourage present minority and female employees to recruit other minority persons and women and, where reasonable, provide after school, summer and vacation employment to minority and female youth both on the site and in other areas of a Contractor's workforce.
 - (k) Validate all tests and other selection requirements where there is an obligation to do so under 41 CFR Part 60-3.
 - (l) Conduct, at least annually, an inventory and evaluation at least of all minority and female personnel for promotional opportunities and encourage these employees to seek or to prepare for, through appropriate training, etc., such opportunities.

- (m) Ensure that seniority practices, job classifications, work assignments and other personnel practices, do not have a discriminatory effect by continually monitoring all personnel and employment related activities to ensure that the EEO policy and the Contractor's obligations under these specifications are being carried out.
 - (n) Ensure that all facilities and company activities are nonsegregated except that separate or single-user toilet and necessary changing facilities shall be provided to assure privacy between the sexes.
 - (o) Document and maintain a record of all solicitations of offers for subcontracts from minority and female construction Contractors and suppliers, including circulation of solicitations to minority and female Contractor associations and other business associations.
 - (p) Conduct a review, at least annually, of all supervisors' adherence to and performance under the Contractor's EEO policies and affirmative action obligations.
8. Contractors are encouraged to participate in voluntary associations which assist in fulfilling one or more of their affirmative action obligations (7a through p). The efforts of a Contractor association, joint Contractor-union, Contractor-community, or other similar group of which the Contractor is a member and participant, may be asserted as fulfilling any one or more of its obligations under 7a through p of these Specifications provided that the Contractor actively participates in the group, makes every effort to assure that the group has a positive impact on the employment of minorities and women in the industry, ensures that the concrete benefits of the program are reflected in the Contractor's minority and female workforce participation makes a good faith effort to meet its individual goals and timetables, and can provide access to documentation which demonstrates the effectiveness of actions taken on behalf of the Contractor. The obligation to comply, however, is the Contractor's and failure of such a group to fulfill an obligation shall not be a defense for the Contractor's noncompliance.
 9. A single goal for minorities and a separate single goal for women have been established. The Contractor, however, is required to provide equal employment opportunity and to take affirmative action for all minority groups, both male and female, and all women, both minority and non-minority. Consequently, the Contractor may be in violation of the Executive Order if a particular group is employed in a substantially disparate manner (for example, even though the Contractor has achieved its goals for women generally, the Contractor may be in violation of the Executive Order if a specified minority group of women is underutilized).
 10. The Contractor shall not use the goals and timetables or affirmative action standards to discriminate against any person because of race, color, religion, sex, or national origin.
 11. The Contractor shall not enter into any Subcontract with any person or firm debarred from Government contracts pursuant to Executive Order 11246.
 12. The Contractor shall carry out such sanctions and penalties for violation of these specifications and of the Equal Opportunity Clause, including suspension, termination and cancellation of existing subcontracts as may be imposed or ordered pursuant to Executive Order 11246, as amended, and its implementing regulations, by the Office of Federal Contract Compliance Programs. Any Contractor who fails to carry out such sanctions and penalties shall be in violation of these specifications and Executive Order 11246, as amended.
 13. The Contractor, in fulfilling its obligations under these specifications, shall implement specific affirmative action steps, at least as extensive as those standards prescribed in paragraph 7 of these specifications, so as to achieve maximum results from its efforts to ensure equal opportunity. If the Contractor fails to comply with the requirements of the Executive Order, the implementing regulations, or these specifications, the Director shall proceed in accordance with 41 CFR 60-4.8.
 14. The Contractor shall designate a responsible official to monitor all employment related activity to ensure that the company EEO policy is being carried out, to submit reports relating to the provisions hereof as may be required by the Government and to keep records. Records shall at least include for each employee the name, address, telephone numbers, construction trade, union affiliation if any, employee identification number when assigned, social security number, race, sex, status (e.g., mechanic, apprentice, trainee, helper, or laborer), dates of changes in status, hours worked per week in the indicated trade, rate of pay, and locations at which the work was performed. Records shall be maintained in an easily understandable and retrievable form; however, to the degree that existing records satisfy his requirement, Contractors shall not be required to maintain separate records.
 15. Nothing herein provided shall be construed as a limitation upon the application of other laws which establish different standards of compliance or upon the application of requirements for the hiring of local or other area residents (e.g., those under the Public Works Employment Act of 1977 and the Community Development Block Grant Program).

State of Illinois
Department of Transportation

SPECIAL PROVISION
FOR
SPECIFIC EQUAL EMPLOYMENT OPPORTUNITY RESPONSIBILITIES
NONFEDERAL-AID CONTRACTS

Effective: March 20, 1969
Revised: January 1, 1994

1. General

- a. The requirements set forth herein shall constitute the specific affirmative action requirements under this contract and supplement the non-discrimination requirements contained elsewhere in this proposal.
- b. The Contractor shall work with the Illinois Department of Transportation (IDOT) in carrying out Equal Employment Opportunity (EEO) obligations and in reviews of activities under the contract.
- c. The Contractor, and all subcontractors holding subcontracts (not including material suppliers) of \$10,000 or more, shall comply with the following minimum specific requirement activities of EEO. The Contractor shall include these requirements in every subcontract of \$10,000 or more with such modification of language as is necessary to make them binding on the subcontractor.

2. Equal Employment Opportunity Policy

The Contractor shall accept as operating policy the following statement which is designed to further the provision of EEO to all persons, and to promote the full realization of equal employment opportunity through a positive continuing program: "It is the policy of this Company to ensure that applicants are employed, and that employees are treated during employment, without regard to their race, religion, sex, color, national origin, age, or disability. Such action shall include: employment, upgrading, demotion, or transfer; recruitment or recruitment advertising; layoff or termination; rates of pay or other forms of compensation; and selection for training, including apprenticeship, pre-apprenticeship, and/or on-the-job training."

3. Equal Employment Opportunity Officer

The Contractor shall designate and make known to IDOT contracting officers an EEO Officer who will have the responsibility for and must be capable of effectively administering and promoting an active Contractor program of EEO and who must be assigned adequate authority and responsibility to do so.

4. Dissemination of Policy

- a. All members of the Contractor's staff who are authorized to hire, supervise, promote, and discharge employees, or who recommend such action, or who are substantially involved in such action, will be made fully cognizant of, and will implement, the Contractor's EEO policy and contractual responsibilities to provide EEO in each grade and classification of employment. To ensure that the above agreement will be met, the following actions will be taken as a minimum:
 - (1) Periodic meetings of supervisory and personnel office employees will be conducted before the start of work and then not less often than once every six months, at which time the Contractor's EEO policy and its implementation will be reviewed and explained. The meetings will be conducted by the EEO Officer.
 - (2) All new supervisory or personnel office employees will be given a thorough indoctrination by the EEO Officer, covering all major aspects of the Contractor's EEO obligations within thirty days following their reporting for duty with the Contractor.
 - (3) All personnel who are engaged in direct recruitment for the project will be instructed by the EEO Officer in the Contractor's procedures for locating and hiring minority and female employees.
- b. In order to make the Contractor's EEO policy known to all employees, prospective employees, and potential sources of employees, i.e., schools, employment agencies, labor unions (where appropriate), college placement officers, etc., the Contractor shall take the following actions:
 - (1) Notices and posters setting forth the Contractor's EEO policy will be placed in areas readily accessible to employees, applicants for employment and potential employees.
 - (2) The Contractor's EEO policy and the procedures to implement such policy shall be brought to the attention of employees by means of meetings, employee handbooks, or other appropriate means.

5. Recruitment

- a. When advertising for employees, the Contractor shall include in all advertisements for employees the notation: "An Equal Opportunity Employer". All such advertisements shall be published in newspapers, or other publications, having a large circulation among minority groups in the area from which the project work force would normally be derived.
- b. The Contractor shall, unless precluded by a valid bargaining agreement, conduct systematic and direct recruitment through public and private employee referral sources likely to yield qualified minority and female applicants, including, but not limited to, State employment

agencies, schools, colleges and minority and female organizations. To meet this requirement, the Contractor shall, identify sources of potential minority and female employees, and establish with such identified sources procedures whereby minority and female applicants may be referred to the Contractor for employment consideration. In the event the Contractor has a valid bargaining agreement providing for exclusive hiring hall referrals, he/she is expected to observe the provisions of that agreement to the extent that the system permits the Contractor's compliance with EEO contract provisions.

- c. The Contractor shall encourage present employees to refer minority and female applicants for employment by posting appropriate notices or bulletins in areas accessible to all such employees. In addition, information and procedures with regard to referring minority and female applicants shall be discussed with employees.

6. Personnel Actions

Wages, working conditions, and employee benefits shall be established and administered, and personnel actions of every type, including hiring, upgrading, promotion, transfer, demotion, layoff, and termination, will be taken without regard to race, color, religion, sex, national origin, age, or disability. The following procedures shall be followed:

- a. The Contractor shall conduct periodic inspections of project sites to insure that working conditions and employee facilities do not indicate discriminatory treatment of project site personnel.
- b. The Contractor shall periodically evaluate the spread of wages paid within each classification to determine any evidence of discriminatory wage practices.
- c. The Contractor shall periodically review selected personnel actions in depth to determine whether there is evidence of discrimination. Where evidence is found, the Contractor shall promptly take corrective action. If the review indicates that the discrimination may extend beyond the actions reviewed, such corrective action shall include all affected persons.
- d. The Contractor shall promptly investigate all complaints of alleged discrimination made to the Contractor in connection with the obligations under this contract, shall attempt to resolve such complaints, and shall take appropriate corrective action within a reasonable time. If the investigation indicates that the discrimination may affect persons other than the complainant, such corrective action shall include such other persons. Upon completion of each investigation, the Contractor shall inform every complainant of all of the avenues of appeal.

7. Training and Promotion

- a. The Contractor shall assist in locating, qualifying and increasing the skills of minority and female employees and applicants for employment.
- b. Consistent with the Contractor's work force requirements and as permissible under Federal and State regulations, the Contractor shall make full use of training programs, i.e., apprenticeship, and on-the-job training programs for the geographical area of contract performance.
- c. The Contractor shall advise employees and applicants for employment of available training programs and entrance requirements for each.
- d. The Contractor shall periodically review the training and promotion potential of minority and female employees and shall encourage eligible employees to apply for such training and promotion.

8. Unions

If the Contractor relies in whole or in part upon unions as a source of employees, the Contractor shall use his/her best efforts to obtain the cooperation of such unions to increase opportunities for minorities and females within the unions, and to effect referrals by such unions of minority and female employees. Actions by the Contractor, either directly or through a Contractor's association acting as agent, shall include the procedures set forth below:

- a. The Contractor shall use best efforts to develop, in cooperation with the unions, joint training programs aimed toward qualifying more minority and female employees for membership in the unions and increasing the skills of minority and female employees so that they may qualify for higher paying employment.
- b. The Contractor shall use best efforts to incorporate an EEO clause into each union agreement to the end that such union shall be contractually bound to refer applicants without regard to their race, color, religion, sex, national origin, age, or disability.
- c. The Contractor is to obtain information as to the referral practices and policies of the labor union, except that to the extent such information is within the exclusive possession of the labor union and such labor union refuses to furnish such information to the Contractor, the Contractor shall so certify to IDOT and shall set forth what efforts have been made to obtain such information.
- d. In the event the union is unable to provide the Contractor with a reasonable flow of minority and female referrals within the time limit set forth in the collective bargaining agreement, the Contractor shall, through independent recruitment efforts, fill the employment vacancies without regard to race, color, religion, sex, national origin, age, or disability; making full efforts to obtain qualified and/or qualifiable minorities and females. (The U.S. Department of Labor has held that it shall be no excuse that the union with which the Contractor has a collective bargaining agreement providing for exclusive referral failed to refer minorities or female employees). In the event the union referral practice prevents the Contractor from meeting the obligations pursuant to these Special Provisions, such Contractor shall immediately notify IDOT.

9. Selection of Subcontractors, Procurement of Materials, and Leasing of Equipment

The Contractor shall not discriminate on the grounds of race, color, religion, sex, national origin, age, or disability in the selection and retention of subcontractors, including procurement of materials and leases of equipment.

- a. The Contractor shall notify all potential subcontractors and suppliers of his/her EEO obligations under this contract.
- b. Disadvantaged business enterprises (DBE), as defined in 49 CFR Part 23, shall have equal opportunity to compete for and perform subcontracts which the Contractor enters into pursuant to this contract. The Contractor shall use best efforts to solicit bids from and to utilize DBE subcontractors or subcontractors with meaningful minority and female representation among their employees. Contractors shall obtain lists of DBE construction firms from IDOT personnel.
- c. The Contractor shall use his/her best efforts to ensure subcontractor compliance with their EEO obligations.

10. Records and Reports

The Contractor shall keep such records as necessary to document compliance with the EEO requirements. Such records shall be retained for a period of three years following completion of the contract work and shall be available at reasonable times and places for inspection by authorized representatives of IDOT.

- a. The records kept by the Contractor shall document the following:
 - (1) the number of minorities, non-minorities and females employed in each work classification on the project;
 - (2) the progress and efforts being made in cooperation with unions, when applicable, to increase employment opportunities for minorities and females;
 - (3) the progress and efforts being made in locating, hiring, training, qualifying, and upgrading minority and female employees; and
 - (4) the progress and efforts being made in securing the services of DBE subcontractors, or subcontractors with meaningful minority and female representation among their employees.
- b. The Contractor shall submit to IDOT a monthly report every month for the duration of the project, indicating the number of minority, non-minority and female employees currently engaged in each work classification required by contract work and the number of hours worked. This information is to be reported on Form SBE-956. If on-the-job training is being required by special provision, the Contractor will be required to collect and report training data.

State of Illinois
Department of Transportation

SPECIAL PROVISION
FOR
REQUIRED PROVISIONS – STATE CONTRACTS

Effective: April 1 1965
Revised: January 1, 2017

I. SELECTION OF LABOR

The Contractor shall comply with all Illinois statutes pertaining to the selection of labor.

EMPLOYMENT OF ILLINOIS WORKERS DURING PERIODS OF
EXCESSIVE UNEMPLOYMENT

Whenever there is a period of excessive unemployment in Illinois, which is defined herein as any month immediately following two consecutive calendar months during which the level of unemployment in the State of Illinois has exceeded five percent as measured by the United States Bureau of Labor Statistics in its monthly publication of employment and unemployment figures, the Contractor shall employ at least 90 percent Illinois laborers. "Illinois laborer" means any person who has resided in Illinois for at least 30 days and intends to become or remain an Illinois resident.

Other laborers may be used when Illinois laborers as defined herein are not available, or are incapable of performing the particular type of work involved, if so certified by the Contractor and approved by the Engineer. The Contractor may place no more than three of his/her regularly employed non-resident executive and technical experts, who do not qualify as Illinois laborers, to do work encompassed by this Contract during period of excessive unemployment.

This provision applies to all labor, whether skilled, semi-skilled, or unskilled, whether manual or non-manual.

II. EQUAL EMPLOYMENT OPPORTUNITY

In the event of the Contractor's noncompliance with the provisions of this Equal Employment Opportunity Clause, the Illinois Human Rights Act or the Illinois Department of Human Rights Rules and Regulations, the Contractor may be declared ineligible for future contracts or subcontracts with the State of Illinois or any of its political sub-divisions or municipal corporations, and the contract may be cancelled or voided in whole or in part, and such other sanctions or penalties may be imposed or remedies invoked as provided by statute or regulation.

During the performance of this Contract, the Contractor agrees as follows:

1. That it will not discriminate against any employee or applicant for employment because of race, color, religion, sex, sexual orientation, marital status, order of protection status, national origin or ancestry, citizenship status, age, physical or mental disability unrelated to ability, military status, or an unfavorable discharge from military service; and further that it will examine all job classifications to determine if minority persons or women are underutilized and will take appropriate affirmative action to rectify any such underutilization.
2. That, if it hires additional employees in order to perform this contract or any portion hereof, it will determine the availability (in accordance with the Illinois Department of Human Rights Rules and Regulations) of minorities and women in the area(s) from which it may reasonably recruit and it will hire for each job classification for which employees are hired in such a way that minorities and women are not underutilized.
3. That, in all solicitations or advertisements for employees placed by it or on its behalf, it will state that all applicants will be afforded equal opportunity without discrimination because of race, color, religion, sex, sexual orientation, marital status, order of protection status, national origin or ancestry, citizenship status, age, physical or mental disability unrelated to ability, military status, or an unfavorable discharge from military service.
4. That it will send to each labor organization or representative of workers with which it has or is bound by a collective bargaining or other agreement or understanding, a notice advising such labor organization or representative of the Contractor's obligations under the Illinois Human Rights Act and the Illinois Department of Human Rights Rules and Regulations. If any labor organization or representative fails or refuses to cooperate with the Contractor in its efforts to comply with such Act and Rules and Regulations, the Contractor will promptly so notify the Illinois Department of Human Rights and IDOT and will recruit employees from other sources when necessary to fulfill its obligations thereunder.
5. That it will submit reports as required by the Illinois Department of Human Rights Rules and Regulations, furnish all relevant information as may from time to time be requested by the Illinois Department of Human Rights or IDOT, and in all respects comply with the Illinois Human Rights Act and the Illinois Department of Human Rights Rules and Regulations.
6. That it will permit access to all relevant books, records, accounts and work sites by personnel of IDOT and the Illinois Department of Human Rights for purposes of investigation to ascertain compliance with the Illinois Human Rights Act and the Illinois Department of Human Rights Rules and Regulations.
7. That it will include verbatim or by reference the provisions of this clause in every subcontract it awards under which any portion of the contract obligations are undertaken or assumed, so that the provisions will be binding upon the subcontractor. In the same manner as with other provisions of this contract, the Contractor will be liable for compliance with applicable provisions of this clause by subcontractors; and further it will promptly notify IDOT and the Illinois Department of Human Rights in the event any subcontractor fails or refuses to comply with these provisions. In addition, the Contractor will not utilize any subcontractor declared by the Illinois Human Rights Commission to be ineligible for contracts or subcontracts with the State of Illinois or any of its political subdivisions or municipal corporations.

III. SUBLETTING OR ASSIGNING THE CONTRACT

1. The Contractor shall perform with his/her own organization contract work amounting to not less than 51 percent of the original total contract price, except that any items designated by the State as "Specialty Items" may be performed by subcontract and the amount of any such "Specialty Items" so performed may be deducted from the original total contract price before computing the amount of work required to be performed by the Contractor with his/her own organization.
 - a. "His/her own organization" shall be construed to include only worker employed and paid directly by the Contractor and equipment owned or rented by him/her, with or without operators.
 - b. "Specialty Items" shall be construed to be limited to work that requires specialized knowledge, craftsmanship or equipment not ordinarily available in contracting organizations qualified to bid on the contract as a whole and in general are to be limited to minor components of the overall contract.
2. In addition to the 51 percent requirement set forth in paragraph 1 above, the Contractor shall furnish (a) a competent superintendent or foreman who is employed by him/her, who has full authority to direct performance of the work in accordance with the contract requirements, and who is in charge of all construction operations (regardless of who performs the work), and (b) such other of his/her own organizational capability and responsibility (supervision, management, and engineering services) as the State highway department contracting officer determines is necessary to assure the performance of the contract.
3. The Contractor shall not sublet, sell, transfer, assign or otherwise dispose of the contract or contracts or any portion thereof, or of his/her right, title or interest therein, without written consent of the Engineer. In case such consent is given, the Contractor will be permitted to sublet a portion thereof, but shall perform with the Contractor's own organization, work amounting to not less than 51 percent of the total contract cost, except that any items designated in the contract as "specialty items" may be performed by subcontract and the cost of any such specialty items so performed by subcontract may be deducted from the total cost before computing the amount of work required to be performed by the Contractor with his/her own organization. Materials purchased or produced by the Contractor must be incorporated into the project by the Contractor's own organization if their cost is to be applied to the 50 percent requirement.

No subcontracts, or transfer of contract, shall in any case release the Contractor of his/her liability under the contract and bonds. All transactions of the Engineer shall be with the Contractor. The Contractor shall have representative on the job at all times when either contract or subcontract work is being performed.

All requests to subcontract shall contain a certification that the subcontract agreement exists in writing and physically contains the required Federal and State Equal Employment Opportunity provisions and Labor compliance provisions, including the contract minimum wage requirements. The Contractor shall permit Department or Federal representatives to examine the subcontract agreements upon notice.

4. Any items that have been selected as "Specialty Items" for the contract are listed as such in the Special Provisions, bid schedule, or elsewhere in the contract documents.
5. No portion of the contract shall be sublet, assigned or otherwise disposed of, except with the written consent of the State highway department contracting officer, or his/her authorized representative, and such consent when given shall not be construed to relieve the Contractor of any responsibility for the fulfillment of the contract. Request for permission to sublet, assign or otherwise dispose of any portion of the contract shall be in writing and accompanied by (a) a showing that the organization which will perform the work is particularly experienced and equipped for such work, and (b) an assurance by the Contractor that the labor standards provisions set forth in this contract shall apply to labor performed on all work encompassed by the request.

IV. COMPLIANCE WITH THE PREVAILING WAGE ACT

1. **Prevailing Wages.** All wages paid by the Contractor and each subcontractor shall be in compliance with The Prevailing Wage Act (820 ILCS 130), as amended, except where a prevailing wage violates a federal law, order, or ruling, the rate conforming to the federal law, order, or ruling shall govern. The Contractor shall be responsible to notify each subcontractor of the wage rates set forth in this contract and any revisions thereto. If the Department of Labor revises the wage rates, the Contractor will not be allowed additional compensation on account of said revisions. Current wage rate information shall be obtained by visiting the Department of Labor website at <http://www.illinois.gov/idol/Pages/default.aspx>. It is the responsibility of the Contractor to review the rates applicable to the work of this contract at regular intervals in order to insure the timely payment of current rates. Provision of this information to the Contractor by means of the Department of Labor website satisfies the notification of revisions by the Department to the Contractor pursuant to the Act, and the Contractor agrees that no additional notice is required.
2. **Payroll Records.** The Contractor and each subcontractor shall make and keep, for a period of three years from the later of the date of final payment under the contract or completion of the contract, records of the wages paid to his/her workers. The payroll records shall include each worker's name, address, telephone number, social security number, classification, rate of pay, number of hours worked each day, starting and ending times of work each day, total hours worked each week, itemized deductions made, and actual wages paid. Upon seven business days' notice, these records shall be available at a location within the State, during reasonable hours, for inspection by the Department or the Department of Labor; and Federal, State, or local law enforcement agencies and prosecutors.
3. **SUBMISSION OF PAYROLL RECORDS (BDE)**

Effective: April 1, 2021

Revised: November 2, 2023

Submission of Payroll Records. The Contractor and each subcontractor shall, no later than the 15th day of each calendar month, file a certified payroll for the immediately preceding month to the Illinois Department of Labor (IDOL) through the Illinois Prevailing Wage Portal in compliance with the State Prevailing Wage Act (820 ILCS 130). The portal can be found on the IDOL website at <https://www2.illinois.gov/idol/Laws-Rules/CONMED/Pages/Prevailing-Wage-Portal.aspx>. Payrolls shall be submitted in the format prescribed by the IDOL.

In addition to filing certified payroll(s) with the IDOL, the Contractor and each subcontractor shall certify and submit payroll records to the Department each week from the start to the completion of their respective work, except that full social security numbers shall not be included on weekly submittals. Instead, the payrolls shall include an identification number for each employee (e.g., the last four digits of the employee's

social security number). In addition, starting and ending times of work each day may be omitted from the payroll records submitted. The submittals shall be made using LCPTracker Pro software. The software is web-based and can be accessed at <https://lcptracker.com/>. When there has been no activity during a work week, a payroll record shall still be submitted with the appropriate option ("No Work", "Suspended", or "Complete") selected."

4. Employee Interviews. The Contractor and each subcontractor shall permit his/her employees to be interviewed on the job, during working hours, by compliance investigators of the Department or the Department of Labor.

V. NONSEGREGATED FACILITIES

(Applicable to State Financed Construction Contracts and related subcontracts exceeding \$10,000 which are not exempt from the Equal Opportunity clause).

By submission of this bid, the execution of this contract or subcontract, or the consummation of this material supply agreement, as appropriate, the bidder, construction Contractor, subcontractor, or material supplier, as appropriate, certifies that (s)he does not maintain or provide for his/her employees any segregated facilities at any of his/her establishments, and that (s)he does not permit his/her employees to perform their services at any location, under his/her control, where segregated facilities are maintained. (S)He certifies further that (s)he will not maintain or provide for his/her employees any segregated facilities at any of his/her establishments, and that (s)he will not permit his/her employees to perform their services at any location, under his/her control, where segregated facilities are maintained. (S)He agrees that a breach of this certification is a violation of the Equal Opportunity clause in this contract. As used in this certification, the term "segregated facilities" means any waiting rooms, work areas, restrooms and washrooms, restaurants and other eating areas, time clocks, locker rooms and other storage or dressing areas, parking lots, drinking fountains, recreation or entertainment areas, transportation, and housing facilities provided for employees which are segregated by explicit directive or are in fact segregated on the basis of race, creed, color, or national origin, because of habit, local custom, or otherwise. (S)He agrees that (except where he/she has obtained identical certifications from proposed subcontractors and material suppliers for specific time periods), he/she will obtain identical certifications from proposed subcontractors or material suppliers prior to the award of subcontracts or the consummation of material supply agreements, exceeding \$10,000 which are not exempt from the provisions of the Equal Opportunity clause, and that (s)he will retain such certifications in his/her files.

State of Illinois
Department of Transportation

SPECIAL PROVISION
FOR
SECTION 80 PROSECUTION AND PROGRESS

This Special Provision amends the provisions of the Standard Specifications for Construction of Airports (Adopted March 22, 2023) and shall be construed to be a part thereof, superseding any conflicting provisions thereof applicable to the work under the contract.

80-09 Failure to complete on time.

ADD:

Schedule of Deductions for Each Day of Overrun in Contract Time			
Original Contract Amount		Daily Charges	
From More Than	To and Including	Calendar Day	Work Day
\$ 0	\$ 100,000	\$ 475	\$ 675
100,000	500,000	750	1,050
500,000	1,000,000	1,025	1,425
1,000,000	3,000,000	1,275	1,725
3,000,000	6,000,000	1,425	2,000
6,000,000	12,000,000	2,300	3,450
12,000,000	And over	6,775	9,525

State of Illinois
Department of Transportation

SPECIAL PROVISION
FOR
SECTION 90 MEASUREMENT AND PAYMENT

This Special Provision amends the provisions of the Standard Specifications for Construction of Airports (Adopted March 22, 2023) and shall be construed to be a part thereof, superseding any conflicting provisions thereof applicable to the work under the contract.

90-07 Partial payments.

DELETE: The entire section.

ADD: Partial payments will be made to the Contractor at least once each month as the work progresses. The payments will be based upon estimates, prepared by the Resident Engineer, of the value of the work performed and materials complete and in place in accordance with the contract, plans, and specifications. Such partial payments may also include the delivered actual cost of those materials stockpiled and stored in accordance with the Section 90-08 PAYMENT FOR MATERIALS ON HAND. From the amount of partial payment so determined on Federal-Aid projects, there shall be deducted an amount up to ten percent of the cost of the completed work which shall be retained until all conditions necessary for financial closeout of the project are satisfied. The amount of the estimate approved as due for payment will be vouchered by the Department and presented to the State Comptroller for payment. No amount less than \$1,000.00 will be approved for payment other than the final payment. A final voucher for under \$5.00 shall not be paid except through electronic funds transfer. (15 ILCS 405/9(b-1))

It is understood and agreed that the Contractor shall not be entitled to demand or receive partial payment based on quantities of work in excess of those provided in the proposal or covered by approved change orders, except when such excess quantities have been determined by the Engineer to be a part of the final quantity for the item of work in question.

No partial payment shall bind the Department to the acceptance of any materials or work in place as to quality or quantity. All partial payments are subject to correction at the time of final payment as provided in Section 90-09 ACCEPTANCE AND FINAL PAYMENT.

Progress payments may be reduced by liens filed pursuant to Section 23(c) of the Mechanics Lien Act, 770 ILCS 60/23(c).

If a Contractor or subcontractor has defaulted on a loan issued under the Department's Disadvantaged Business Revolving Loan Program (20 ILCS 2705/2705-610) progress payments may be reduced pursuant to the terms of that loan agreement. In such cases, the amount of the estimate related to the work performed by the Contractor or subcontractor, in default of the loan agreement, will be offset, in whole or in part, and vouchered by the Department to the Working Capital Revolving Fund or designated escrow account. Payment for the work shall be considered as issued and received by the Contractor or subcontractor on the date of the offset voucher. Further, the amount of the offset voucher shall be a credit against the Department's obligation to pay the Contractor, the Contractor's obligation to pay the subcontractor, and the Contractor's or subcontractor's total loan indebtedness to the Department. The offset shall continue until such time as the entire loan indebtedness is satisfied. The Department will notify the Contractor and Fund Control Agent in a timely manner of such offset. The Contractor or subcontractor shall not be entitled to additional payment in consideration of the offset.

In accordance with 49 USC § 47111, the Department will not make payments totaling more than 90 percent of the contract until all conditions necessary for financial closeout of the project are satisfied.

The failure to perform any requirement, obligation, or term of the contract by the Contractor shall be reason for withholding any progress payments until the Department determines that compliance has been achieved.

90-09 Trust agreement option.

DELETE: The entire section.

STATE OF ILLINOIS

SPECIAL PROVISIONS

The following Special Provisions supplement the Standard Specifications for Construction of Airports (Adopted March 22, 2023) and the Special Provisions included herein which apply to and govern the airport improvement of: Construct Crosswind Runway 7/25 at Morris Municipal, Contract MR026, and in case of conflict with any part or parts of said Specifications, the said Special Provisions shall take precedence and shall govern.

SPECIAL PROVISION FOR COMPLETION TIME VIA CALENDAR DAYS

It being understood and agreed that the completion within the time limit is an essential part of the contract, the bidder agrees to complete the work within **458 calendar days**, unless additional time is granted by the Engineer in accordance with the provisions of the specifications. In case of failure to complete the work on or before the time named herein, or within such extra time as may have been allowed by extensions, the bidder agrees that the Department of Transportation shall withhold from such sum as may be due him/her under the terms of this contract, the costs, as set forth in Section 80-09 Failure to Complete on Time of the Standard Specifications, which costs shall be considered and treated not as a penalty but as damages due to the State from the bidder by reason of the failure of the bidder to complete the work within the time specified in the contract.

CONSTRUCTION AIR QUALITY – DIESEL VEHICLE EMISSIONS CONTROL (BDE)

Effective: April 1, 2009

Revised: January 2, 2012

Diesel Vehicle Emissions Control. The reduction of construction air emissions shall be accomplished by using cleaner burning diesel fuel. The term "equipment" refers to any and all diesel fuel powered devices rated at 50 hp and above, to be used on the project site in excess of seven calendar days over the course of the construction period on the project site (including any "rental" equipment).

All equipment on the jobsite, with engine ratings of 50 hp and above, shall be required to: use Ultra Low Sulfur Diesel fuel (ULSD) exclusively (15 ppm sulfur content or less).

Diesel powered equipment in non-compliance will not be allowed to be used on the project site, and is also subject to a notice of non-compliance as outlined below.

The Contractor shall certify that only ULSD will be used in all jobsite equipment. The certification shall be presented to the Department prior to the commencement of the work.

If any diesel powered equipment is found to be in non-compliance with any portion of this specification, the Engineer will issue the Contractor a notice of non-compliance and identify an appropriate period of time, as outlined below under environmental deficiency deduction, in which to bring the equipment into compliance or remove it from the project site.

Any costs associated with bringing any diesel powered equipment into compliance with these diesel vehicle emissions controls shall be considered as included in the contract unit prices bid for the various items of work involved and no additional compensation will be allowed. The Contractor's compliance with this notice and any associated regulations shall also not be grounds for a claim.

Environmental Deficiency Deduction. When the Engineer is notified, or determines that an environmental control deficiency exists, he/she will notify the Contractor in writing, and direct the Contractor to correct the deficiency within a specified time period. The specified time-period, which begins upon Contractor notification, will be from 1/2 hour to 24 hours long, based on the urgency of the situation and the nature of the deficiency. The Engineer shall be the sole judge regarding the time period.

The deficiency will be based on lack of repair, maintenance and diesel vehicle emissions control.

If the Contractor fails to correct the deficiency within the specified time frame, a daily monetary deduction will be imposed for each calendar day or fraction thereof the deficiency continues to exist. The calendar day(s) will begin when the time period for correction is exceeded and end with the Engineer's written acceptance of the correction. The daily monetary deduction will be \$1,000.00 for each deficiency identified.

If a Contractor or subcontractor accumulates three environmental deficiency deductions in a contract period, the Contractor will be shutdown until the deficiency is corrected. Such a shutdown will not be grounds for any extension of contract time, waiver of penalties, or be grounds for any claim.

CONSTRUCTION AIR QUALITY – IDLING RESTRICTION (BDE)

Effective: April 1, 2009

Idling Restrictions. The Contractor shall establish truck-staging areas for all diesel powered vehicles that are waiting to load or unload material at the jobsite. Staging areas shall be located where the diesel emissions from the equipment will have a minimum impact on adjacent sensitive receptors. The Department will review the selection of staging areas, whether within or outside the existing highway right-of-way, to avoid locations near sensitive areas or populations to the extent possible. Sensitive receptors include, but are not limited to, hospitals, schools, residences, motels, hotels, daycare facilities,

elderly housing and convalescent facilities. Diesel powered engines shall also be located as far away as possible from fresh air intakes, air conditioners, and windows. The Engineer will approve staging areas before implementation.

Diesel powered vehicle operators may not cause or allow the motor vehicle, when it is not in motion, to idle for more than a total of 10 minutes within any 60 minute period, except under any of the following circumstances:

- 1) The motor vehicle has a gross vehicle weight rating of less than 8000 lb (3630 kg).
- 2) The motor vehicle idles while forced to remain motionless because of on-highway traffic, an official traffic control device or signal, or at the direction of a law enforcement official.
- 3) The motor vehicle idles when operating defrosters, heaters, air conditioners, or other equipment solely to prevent a safety or health emergency.
- 4) A police, fire, ambulance, public safety, other emergency or law enforcement motor vehicle, or any motor vehicle used in an emergency capacity, idles while in an emergency or training mode and not for the convenience of the vehicle operator.
- 5) The primary propulsion engine idles for maintenance, servicing, repairing, or diagnostic purposes if idling is necessary for such activity.
- 6) A motor vehicle idles as part of a government inspection to verify that all equipment is in good working order, provided idling is required as part of the inspection.
- 7) When idling of the motor vehicle is required to operate auxiliary equipment to accomplish the intended use of the vehicle (such as loading, unloading, mixing, or processing cargo; controlling cargo temperature; construction operations, lumbering operations; oil or gas well servicing; or farming operations), provided that this exemption does not apply when the vehicle is idling solely for cabin comfort or to operate non-essential equipment such as air conditioning, heating, microwave ovens, or televisions.
- 8) When the motor vehicle idles due to mechanical difficulties over which the operator has no control.
- 9) The outdoor temperature is less than 32 °F (0 °C) or greater than 80 °F (26 °C).

When the outdoor temperature is greater than or equal to 32 °F (0 °C) or less than or equal to 80 °F (26 °C), a person who operates a motor vehicle operating on diesel fuel shall not cause or allow the motor vehicle to idle for a period greater than 30 minutes in any 60 minute period while waiting to weigh, load, or unload cargo or freight, unless the vehicle is in a line of vehicles that regularly and periodically moves forward.

The above requirements do not prohibit the operation of an auxiliary power unit or generator set as an alternative to idling the main engine of a motor vehicle operating on diesel fuel.

Environmental Deficiency Deduction. When the Engineer is notified, or determines that an environmental control deficiency exists based on non-compliance with the idling restrictions, he/she will notify the Contractor, and direct the Contractor to correct the deficiency.

If the Contractor fails to correct the deficiency a monetary deduction will be imposed. The monetary deduction will be \$1,000.00 for each deficiency identified.

SPECIAL PROVISION FOR DISADVANTAGED BUSINESS ENTERPRISE PARTICIPATION

Effective: September 1, 2000

Revised: January 2, 2025

1. OVERVIEW AND GENERAL OBLIGATION. The Department of Transportation, as a recipient of federal financial assistance, is required to take all necessary and reasonable steps to ensure nondiscrimination in the award and administration of contracts. Consequently, the federal regulatory provisions of 49 CFR Part 26 apply to this contract concerning the utilization of disadvantaged business enterprises. For the purposes of this Special Provision, a disadvantaged business enterprise (DBE) means a business certified in accordance with the requirements of 49 CFR Part 26 and listed in the Illinois Unified Certification Program (IL UCP) DBE Directory. Award of the contract is conditioned on meeting the requirements of 49 CFR Part 26, and failure by the Contractor to carry out the requirements of Part 26 is a material breach of the contract and may result in the termination of the contract or such other remedies as the Department deems appropriate.
2. CONTRACTOR ASSURANCE. All assurances set forth in FHWA 1273 are hereby incorporated by reference and will be physically attached to the final contract and all subcontracts.
3. CONTRACT GOAL TO BE ACHIEVED BY THE CONTRACTOR. The Department has determined the work of this contract has subcontracting opportunities that may be suitable for performance by DBE companies and that, in the absence of unlawful discrimination and in an arena of fair and open competition, DBE companies can be expected to perform 14.0% of the work. This percentage is set as the DBE participation goal for this contract. Consequently, in addition to the other award criteria established for this contract, the Department will only award this contract to a bidder who makes a good faith effort to meet this goal of DBE participation in the performance of the work in accordance with the requirements of 49 CFR 26.53 and SBE Memorandum No. 24-02.
4. IDENTIFICATION OF CERTIFIED DBE. Information about certified DBE Contractors can be found in the Illinois UCP Directory. Bidders can obtain additional information and assistance with identifying DBE-certified companies at the Department's website or by contacting the Department's Bureau of Small Business Enterprises at (217) 785-4611.
5. BIDDING PROCEDURES. Compliance with this Special Provision and SBE Policy Memorandum 24-02 is a material bidding requirement. The following shall be included with the bid.
 - (a) DBE Utilization Plan (form SBE 2026) documenting enough DBE participation has been obtained to meet the goal, or a good faith effort has been made to meet the goal even though the efforts did not succeed in obtaining enough DBE participation to meet the goal.
 - (b) Applicable DBE Participation Statement (form SBE 2023, 2024, and/or 2025) for each DBE firm the bidder has committed to perform the work to achieve the contract goal.

The required forms and documentation shall be submitted as a single .pdf file using the "Integrated Contractor Exchange (iCX)" application within the Department's "EBids System".

The Department will not accept a bid if it does not meet the bidding procedures set forth herein and the bid will be declared non-responsive. A bidder declared non-responsive for failure to meet the bidding procedures will not give rise to an administrative reconsideration. In the event the bid is

declared non-responsive, the Department may elect to cause the forfeiture of the penal sum of the bidder's proposal guaranty and may deny authorization to bid the project if re-advertised for bids.

6. **UTILIZATION PLAN EVALUATION.** The contract will not be awarded until the Utilization Plan is approved. All information submitted by the bidder must be complete, accurate, and adequately document the bidder has committed to DBE participation sufficient to meet the goal, or that the bidder has made good faith efforts to do so, in the event the bidder cannot meet the goal, in order for the Department to commit to the performance of the contract by the bidder.

The Utilization Plan will be approved by the Department if the Utilization Plan documents sufficient commercially useful DBE work to meet the contract goal or the Department determines, based upon the documentation submitted, that the bidder has made a good faith effort to meet the contract goal pursuant to 49 CFR Part 26, Appendix A and the requirements of SBE 2026.

If the Department determines that a good faith effort has not been made, the Department will notify the responsible company official designated in the Utilization Plan of that determination in accordance with SBE Policy Memorandum 24-02.

7. **CALCULATING DBE PARTICIPATION.** The Utilization Plan values represent work the bidder commits to have performed by the specified DBEs and paid for upon satisfactory completion. The Department is only able to count toward the achievement of the overall goal and the contract goal the value of payments made for the work actually performed by DBE firms. In addition, a DBE must perform a commercially useful function on the contract to be counted. A commercially useful function is generally performed when the DBE is responsible for the work and is carrying out its responsibilities by actually performing, managing, and supervising the work involved. The Department and Contractor are governed by the provisions of 49 CFR Part 26.55(c) on questions of commercially useful functions as it affects the work. Specific guidelines for counting goal credit are provided in 49 CFR Part 26.55. In evaluating Utilization Plans for award the Department will count goal credit as set forth in Part 26 and in accordance with SBE Policy Memorandum 24-02.
8. **CONTRACT COMPLIANCE.** The Contractor must utilize the specific DBEs listed to perform the work and supply the materials for which each DBE is listed in the Contractor's approved Utilization Plan, unless the Contractor obtains the Department's written consent to terminate the DBE or any portion of its work. The DBE Utilization Plan approved by SBE is a condition-of-award, and any deviation to that Utilization Plan, the work set forth therein to be performed by DBE firms, or the DBE firms specified to perform that work, must be approved, in writing, by the Department in accordance with federal regulatory requirements. Deviation from the DBE Utilization Plan condition-of-award without such written approval is a violation of the contract and may result in termination of the contract or such other remedy the Department deems appropriate. The following administrative procedures and remedies govern the compliance by the Contractor with the contractual obligations established by the Utilization Plan.
- (a) **NOTICE OF DBE PERFORMANCE.** The Contractor shall provide the Engineer with at least three days advance notice of when all DBE firms are expected to perform the work committed under the Contractor's Utilization Plan.
 - (b) **SUBCONTRACT.** If awarded the contract, the Contractor is required to enter into written subcontracts with all DBE firms indicated in the approved Utilization Plan and must provide copies of fully executed DBE subcontracts to the Department upon request. Subcontractors shall ensure that all lower tier subcontracts or agreements with DBEs to supply labor or materials be performed in accordance with this Special Provision.
 - (c) **PAYMENT TO DBE FIRMS.** The Department is prohibited by federal regulations from crediting the participation of a DBE included in the Utilization Plan toward either the contract goal or the Department's overall goal until the amount to be applied toward the goal has been paid to the DBE. The Contractor shall document and report all payments for work performed by DBE certified firms in accordance with Article 109.11 of the Standard Specifications. All records of payment for work performed by DBE certified firms shall be made available to the Department upon request.
 - (d) **FINAL PAYMENT.** After the performance of the final item of work or trucking, or delivery of material by a DBE and final payment to the DBE by the Contractor, but not later than 30 calendar days after payment has been made by the Department to the Contractor for such work or material, the Contractor shall submit a DBE Payment Agreement (form SBE 2115) to the Engineer. If the Contractor does not have the full amount of work indicated in the Utilization Plan performed by the DBE companies indicated in the Utilization Plan and after good faith efforts are reviewed, the Department may deduct from contract payments to the Contractor the amount of the goal not achieved as liquidated and ascertained damages.
 - (g) **ENFORCEMENT.** The Department reserves the right to withhold payment to the Contractor to enforce the provisions of this Special Provision. Final payment shall not be made on the contract until such time as the Contractor submits sufficient documentation demonstrating achievement of the goal in accordance with this Special Provision or after liquidated damages have been determined and collected.

SPECIAL PROVISION FOR WEEKLY DBE TRUCKING REPORTS (BDE)

Effective: June 2, 2012

Revised: January 2, 2025

The following applies to all Disadvantaged Business Enterprise (DBE) trucks on the project, whether they are utilized for DBE goal credit or not.

The Contractor shall notify the Engineer at least three days prior to DBE trucking activity.

The Contractor shall submit a weekly report of DBE trucks hired by the Contractor or subcontractors (i.e. not owned by the Contractor or subcontractors) to the Resident Engineer on Division of Aeronautics Form "AER 723" within ten business days following the reporting period. The reporting period shall be Sunday through Saturday for each week reportable trucking activities occur.

Any costs associated with providing weekly DBE trucking reports shall be considered as included in the contract unit prices bid for the various items of work involved and no additional compensation will be allowed.

SPECIAL PROVISION FOR SUBCONTRACTOR MOBILIZATION PAYMENTS

Effective: November 2, 2017

Revised: April 1, 2019

To account for the preparatory work and the operations necessary for the movement of subcontractor personnel, equipment, supplies, and incidentals to the project site and for all other work or operations that must be performed or costs incurred when beginning work approved for subcontracting according to Section 80-01 of the Standard Specifications, the Contractor shall make a mobilization payment to each subcontractor.

This mobilization payment shall be made at least seven days prior to the subcontractor starting work. The amount paid shall be at the following percentage of the amount of the subcontract reported on form AER 260A submitted for the approval of the subcontractor's work.

Value of Subcontract Reported on Form AER 260A	Mobilization Percentage
Less than \$10,000	25%
\$10,000 to less than \$20,000	20%
\$20,000 to less than \$40,000	18%
\$40,000 to less than \$60,000	16%
\$60,000 to less than \$80,000	14%
\$80,000 to less than \$100,000	12%
\$100,000 to less than \$250,000	10%
\$250,000 to less than \$500,000	9%
\$500,000 to \$750,000	8%
Over \$750,000	7%

The mobilization payment to the subcontractor is an advance payment of the reported amount of the subcontract and is not a payment in addition to the amount of the subcontract; therefore, the amount of the advance payment will be deducted from future progress payments.

This provision shall be incorporated directly or by reference into each subcontract approved by the Department.

SPECIAL PROVISION FOR PAYMENTS TO SUBCONTRACTORS

Effective: November 2, 2017

Federal regulations found at 49 CFR §26.29 mandate the Department to establish a contract clause to require Contractors to pay subcontractors for satisfactory performance of their subcontracts and to set the time for such payments.

State law also addresses the timing of payments to be made to subcontractors and material suppliers. Section 7 of the Prompt Payment Act, 30 ILCS 540/7, requires that when a Contractor receives any payment from the Department, the Contractor shall make corresponding, proportional payments to each subcontractor and material supplier performing work or supplying material within 15 calendar days after receipt of the Department payment. Section 7 of the Act further provides that interest in the amount of two percent per month, in addition to the payment due, shall be paid to any subcontractor or material supplier by the Contractor if the payment required by the Act is withheld or delayed without reasonable cause. The Act also provides that the time for payment required and the calculation of any interest due applies to transactions between subcontractors and lower-tier subcontractors and material suppliers throughout the contracting chain.

This Special Provision establishes the required federal contract clause, and adopts the 15 calendar day requirement of the State Prompt Payment Act for purposes of compliance with the federal regulation regarding payments to subcontractors. This contract is subject to the following payment obligations.

When progress payments are made to the Contractor according to Article 90-07 of the Standard Specifications, the Contractor shall make a corresponding payment to each subcontractor and material supplier in proportion to the work satisfactorily completed by each subcontractor and for the material supplied to perform any work of the contract. The proportionate amount of partial payment due to each subcontractor and material supplier throughout the contracting chain shall be determined by the quantities measured or otherwise determined as eligible for payment by the Department and included in the progress payment to the Contractor. Subcontractors and material suppliers shall be paid by the Contractor within 15 calendar days after the receipt of payment from the Department. The Contractor shall not hold retainage from the subcontractors. These obligations shall also apply to any payments made by subcontractors and material suppliers to their subcontractors and material suppliers; and to all payments made to lower tier subcontractors and material suppliers throughout the contracting chain. Any payment or portion of a payment subject to this provision may only be withheld from the subcontractor or material supplier to whom it is due for reasonable cause. If reasonable cause is asserted, written notice shall be provided to the applicable subcontractor and/or material supplier and the Engineer within five days of the Contractor receiving payment. The written notice shall identify the contract number, the subcontract or material purchase agreement, a detailed reason for refusal, the value of payment being withheld, and the specific remedial actions required of the subcontractor and/or material supplier so that payment can be made.

This Special Provision does not create any rights in favor of any subcontractor or material supplier against the State or authorize any cause of action against the State on account of any payment, nonpayment, delayed payment, or interest claimed by application of the State Prompt Payment Act. The Department will not approve any delay or postponement of the 15 day requirement except for reasonable cause shown after notice and hearing pursuant to Section 7(b) of the State Prompt Payment Act. State law creates other and additional remedies available to any subcontractor or material supplier, regardless of tier, who has not been paid for work properly performed or material furnished. These remedies are a lien against public funds set forth in Section 23(c) of the Mechanics Lien Act, 770 ILCS 60/23(c), and a recovery on the Contractor's payment bond according to the Public Construction Bond Act, 30 ILCS 550.

SPECIAL PROVISION FOR SUBCONTRACTOR AND DBE PAYMENT REPORTING (BDE)

Effective: April 2, 2018

Subcontractor and Disadvantaged Business Enterprise Payment Reporting

The Contractor shall report all payments made to the following parties:

- (a) first tier subcontractors;
- (b) lower tier subcontractors affecting disadvantaged business enterprise (DBE) goal credit;

- (c) material suppliers or trucking firms that are part of the Contractor's submitted DBE utilization plan.

The report shall be made through the Department's on-line subcontractor payment reporting system within 21 days of making the payment.

SPECIAL PROVISION FOR NPDES CERTIFICATION

In accordance with the provisions of the Illinois Environmental Protection Act, the Illinois Pollution Control Board Rules and Regulations (35 Ill. Adm. Code, Subtitle C, Chapter I), and the Clean Water Act, and the regulations thereunder, this certification is required for all construction contracts that will result in the disturbance of one or more acres total land area.

The bidder certifies under penalty of law that he/she understands the terms and conditions of the general National Pollutant Discharge Elimination System (NPDES) permit (ILR100000) that authorizes the storm water discharges associated with industrial activity from the construction site identified as part of this certification.

The Airport Owner or its Agent will:

- 1) prepare, sign and submit the Notice of Intent (NOI)
- 2) conduct site inspections and complete and file the inspection reports
- 3) submit Incidence of Non-Compliance (ION) forms
- 4) submit Notice of Termination (NOT) form

Prior to the issuance of the Notice-to-Proceed, for each erosion control measure identified in the Storm Water Pollution Prevention Plan, the contractor or subcontractor responsible for the control measure(s) must sign the above certification (forms to be provided by the Department).

ILLINOIS WORKS APPRENTICESHIP INITIATIVE – STATE FUNDED CONTRACTS (BDE)

Effective: June 2, 2021

Revised: April 2, 2024

Illinois Works Jobs Program Act (30 ILCS 559/20-1 et seq.). For contracts having an awarded contract value of \$500,000 or more, the Contractor shall comply with the Illinois Works Apprenticeship Initiative (30 ILCS 559/20-20 to 20-25) and all applicable administrative rules. The goal of the Illinois Apprenticeship Works Initiative is that apprentices will perform either 10% of the total labor hours actually worked in each prevailing wage classification or 10% of the estimated labor hours in each prevailing wage classification, whichever is less. Of this goal, at least 50% of the labor hours of each prevailing wage classification performed by apprentices shall be performed by graduates of the Illinois Works Pre-Apprenticeship Program, the Illinois Climate Works Pre-Apprenticeship Program, or the Highway Construction Careers Training Program.

The Contractor may seek from the Department of Commerce and Economic Opportunity (DCEO) a waiver or reduction of this goal in certain circumstances pursuant to 30 ILCS 559/20-20(b). The Contractor shall ensure compliance during the term of the contract and will be required to report on and certify its compliance. An apprentice use plan, apprentice hours, and a compliance certification shall be submitted to the Engineer on forms provided by the Department and/or DCEO.

SPECIAL PROVISION FOR SUBMISSION OF BIDDERS LIST INFORMATION (BDE)

Effective: January 2, 2025

Revised: March 2, 2025

In accordance with 49 CFR 26.11(c) all DBE and non-DBEs who bid as prime contractors and subcontractors shall provide bidders list information, including all DBE and non-DBE firms from whom the bidder has received a quote or bid to work as a subcontractor, whether or not the bidder has relied upon that bid in placing its bid as the prime contractor.

The bidders list information shall be submitted with the bid using the link provided within the "Integrated Contractor Exchange (iCX)" application of the Department's "EBids System".

REVISIONS TO THE ILLINOIS PREVAILING WAGE RATES

The Prevailing rates of wages are included in this Contract proposal. The rates have been ascertained and certified by the Illinois Department of Labor for the locality in which the work is to be performed and for each craft or type of work or mechanic needed to execute the work of the Contract. As required by Prevailing Wage Act ([820 ILCS](#) 130/0.01, et seq.) and this Proposal, not less than the rates of wages ascertained by the Illinois Department of Labor and as revised during the performance of a Contract shall be paid to all laborers, workers and mechanics performing work under the Contract. Post the scale of wages in a prominent and easily accessible place at the site of work.

If the Illinois Department of Labor revises the prevailing rates of wages to be paid as listed in the specification of rates, the contractor shall post the revised rates of wages and shall pay not less than the revised rates of wages. Current wage rate information shall be obtained by visiting the Illinois Department of Labor web site at <https://www2.illinois.gov/idol/Laws-Rules/CONMED/Pages/Rates.aspx> or by calling 312-793-2814. It is the responsibility of the contractor to review the rates applicable to the work of the contract at regular intervals in order to insure the timely payment of current rates. Provision of this information to the contractor by means of the Illinois Department of Labor web site satisfies the notification of revisions by the Department to the contractor pursuant to the Act, and the contractor agrees that no additional notice is required. The contractor shall notify each of its subcontractors of the revised rates of wages.

Special Provisions
Morris Municipal Airport

Illinois Project No. C09-5011

ITEM NO. 01A

MR026

**SECTION III
SPECIAL PROVISIONS**

FOR

CONSTRUCT CROSSWIND RUNWAY 7/25

ILLINOIS PROJECT NO. C09-5011

AIP NO. N/A

CONTRACT NO. MR026

ITEM NO. 01A

June 13, 2025 IDOT LETTING DATE

AT

**MORRIS MUNICIPAL AIRPORT
THE CITY OF MORRIS, ILLINOIS**

April 23, 2025

PREPARED BY:



Chamlin & Associates
Peru • Morris • Ottawa • Mendota
www.chamlin.com

Chamlin & Associates, Inc.
221 W. Washington Street
Morris, Illinois 60450
Phone: (815) 941-1402



Expires 11/2025

INDEX TO SPECIAL PROVISIONS

GENERAL.....	3
SCOPE OF WORK.....	3
GOVERNING SPECIFICATIONS AND RULES AND REGULATIONS	3
ILLINOIS STEEL PRODUCTS PROCUREMENT PROVISIONS	3
PART 1 – GENERAL CONTRACT PROVISIONS:	4
Section 40 - Scope Of Work	4
Section 50 - Control Of Work.....	5
Section 60 - Control Of Materials.....	6
Section 70 - Legal Regulations And Responsibility To Public	7
Section 80 - Prosecution And Progress.....	9
PART 2 – GENERAL CONSTRUCTION ITEMS:	10
Item 102 Temporary Air And Water Pollution, Soil Erosion, And Siltation Control	10
Item 105 Mobilization.....	11
PART 3 – SITEWORK:.....	12
Item 101 Preparation/Removal Of Existing Pavements:	12
Item 152 Excavation, Subgrade, And Embankment:.....	13
PART 4 – BASE COURSES:	14
Item 209 Crushed Aggregate Base Course	14
PART 6 – FLEXIBLE PAVEMENTS:	15
Item 401 Asphalt Mix Pavement Surface Course.....	15
PART 9 – MISCELLANEOUS:	18
Item 602 Emulsified Asphalt Prime Coat:	18
Item 603 Emulsified Asphalt Tack Coat:.....	19
Item 620 Pavement Marking.....	20
PART 11 – DRAINAGE:	22
Item 701 Pipe for Storm Drains and Culverts.....	22
Item 705 Pipe Underdrains For Airports	23
Item 751 Manholes, Catch Basins, Inlets And Inspection Holes:.....	24
Item AR 751570 Manhole – Special.....	25
Item 752 Concrete Culverts, Headwalls, And Miscellaneous Drainage Structures	26
Item 754 Concrete Gutters, Ditches, And Flumes	27
PART 12 – TURFING:	28
Item 901 Seeding:	28
Item 908 Mulching.....	29
PART 13 – LIGHTING INSTALLATION:	30
Item 108 Underground Power Cable For Airports	30
Item 109 Installation Of Airport Transformer Vault And Vault Equipment	31
Item 110 Airport Underground Electrical Duct Banks And Conduits.....	50
Item 125 Installation Of Airport Lighting Systems	51

GENERAL

These Special Provisions, together with applicable Standard Specifications for Construction of Airports including Supplemental Specifications and Recurring Special Provisions, Rules and Regulations, Contract Requirements for Airport Improvement Projects, Payroll Requirements and Minimum Wage Rates which are hereto attached or which by reference are herein incorporated, cover the requirements of the State of Illinois, Department of Transportation (IDOT), Division of Aeronautics (Division), Federal Aviation Administration (FAA), and the representatives of the Morris Municipal Airport for the project entitled "Construct Runway 7/25" and associated improvements at the Morris Municipal Airport, Morris, Illinois.

SCOPE OF WORK

Project consists of the Construction of Crosswind Runway 7/25, including parallel Taxiway "B" and Taxiway "C", all connecting taxiways, associated vault modifications, airfield lighting items, removal items, aggregate base course, Bituminous surface course, bituminous base course, water borne pavement marking, storm sewer, pipe underdrain, storm structures, landscape restoration items, and other necessary and related work.

GOVERNING SPECIFICATIONS AND RULES AND REGULATIONS

The Standard Specifications for Construction of Airports, State of Illinois, Department of Transportation, Division of Aeronautics, adopted March 22, 2023 shall govern the project except as otherwise noted in these Special Provisions. All references to IDOT specifications refer to the Standard Specifications for Road and Bridge Construction, Illinois Department of Transportation, adopted January 1, 2022, as revised.

In the event of inconsistencies between the Standard Specifications and the Special Provisions, the Special Provisions shall govern.

ILLINOIS STEEL PRODUCTS PROCUREMENT PROVISIONS

It will be the responsibility of the Contractor to provide all certifications, waivers or any necessary documents required on behalf of the Morris Municipal Airport in order to maintain compliance with the current Illinois Steel Products Procurement Act requirements.

PART 1 – GENERAL CONTRACT PROVISIONS:

Section 40 - Scope Of Work

40-05 Maintenance of Traffic.

Add the following:

Jeff Vogen, acting as the Airport Manager, will give proper notice to the nearest Flight Service Stations and the Airways Facilities Chief of the Federal Aviation Administration prior to beginning construction.

The Contractor will notify the Airport Manager, Jeff Vogen, phone (815) 942-1600, seven (7) days in advance of the proposed date for commencement of work.

END SECTION 40

Section 50 - Control Of Work

50-06 Construction Layout and Stakes.

Add the following to this section:

All construction layout necessary for the construction of the various pay items will be the responsibility of the Contractor. Horizontal and vertical control as shown in the plans will be furnished by the Engineer. Any extension of the control network provided in the plans will also be the responsibility of the Contractor.

END SECTION 50

Section 60 - Control Of Materials

60-01 Source of Supply and Quality Requirements.

Add the following to this section:

The Contractor will furnish the Engineer with certification documents or other evidence of compliance prior to the installation of any material item into this project. The Resident Engineer will not report undocumented quantities for payment and the Engineer may request them to be removed from the project.

60-05 Resident Engineer's Field Office.

Revise this section to read:

The Contractor will not be required to furnish a Resident Engineer's Field Office for this project. The Resident Engineer will use the facilities at the airport that can be made available for this use.

END SECTION 60

Section 70 - Legal Regulations And Responsibility To Public

70-11 Protection and Restoration of Property and Landscape.

Add the following paragraphs to this section:

The Contractor shall take special care when working in the vicinity of existing airport lighting systems not to damage them. Should the Contractor damage any of the lighting systems, he shall immediately make any necessary repairs or replacement to place them in working order. No electrical circuit will be allowed to remain out of service overnight. The cost of equipment and making the repairs will be the responsibility of the Contractor. If during the course of construction, it is necessary to interrupt any electrical circuits temporary cables shall be installed as needed to make the circuit operational.

Active areas shall be kept broom clean at all times.

The Contractor shall maintain the premises in reasonably clean condition and shall not allow any sizeable accumulation of rubbish on the premises.

The Contractor shall leave the premises in broom clean condition upon completion of the project.

70-16 Contractor's Responsibility for Utility Service and Facilities of Others.

Add the following to this section:

The Contractor is responsible for contacting all utility companies and organizations that have lines or conduits in the proposed work area. All lines and conduits shall be located and identified for depth before any excavation begins. The Contractor shall call JULIE (1-800-892-0123) to accomplish these requirements. The Contractor is also responsible for identifying all non-JULIE utilities located within the proposed construction limits. These utilities are also to be located prior to the start of construction at the expense of the Contractor, if applicable.

70-21 Environmental Protection.

Add the following to this section:

The Contractor will be required to minimize air pollution from dust by watering disturbed areas at whatever frequency necessary in order to control the creation of airborne dust. The furnishing and distribution of the water will be considered as an incidental item to the contract, and no additional compensation will be allowed.

Add this section to Section 70:

70-26 Site Inspection.

The Contractor shall be responsible for an on-site inspection or being familiar with the project construction site prior to submitting a bid on this project. Upon receipt of a bid, it shall be assumed that the Contractor is fully familiar with the construction site.

Add this section to Section 70:

70-27 Barricades, Warning Signs and Hazard Markings.

When the Contractor's vehicles are on the airport property, they shall be properly marked. The markings shall consist of a three (3') foot square flag consisting of a checkered pattern of international orange and white squares of not less than one (1') foot per side, displayed in full view above the vehicle. The flags are not required for vehicles used for continuous hauling of materials to the project from off of the airport property. The Contractor shall make two flags available for use by the Resident Engineer and staff.

The Contractor will be responsible for placing barricades and/or traffic cones at any location directed by the Airport Manager and Resident Engineer. It will be the Contractor's responsibility to furnish and maintain the barricades, equipped with red flashing lights throughout the duration of this project. The barricades and their maintenance will be considered as an incidental item to the contract and no additional compensation will be allowed. Any cost of labor and equipment necessary to ensure safety at the airport during the duration of the project will be considered incidental to the contract and no additional reimbursement for these items of work will be received.

END SECTION 70

Section 80 - Prosecution And Progress

80-13 Work Area, Storage Area and Sequence of Operations.

Add the following to this section:

The Contractor will use only the designated construction entrance, equipment parking area and airport access as shown in the construction plans. The Contractor's personnel and equipment shall not traverse outside the designated work areas to other locations on the airport.

The Contractor shall be responsible for providing a haul road as necessary to prevent tracking mud and other deleterious materials onto the aggregate base course or pavement. The Contractor shall designate a location for a haul road prior to starting the placement of the aggregate base course. The designated location shall conform with the Contractor's workflow, means and methods and shall be approved by the Engineer. The material, installation, and removal of the haul road will not be paid for separately but should be included in the cost of Unclassified Excavation.

Barricades and road closed signs are the responsibility of the Contractor at no additional cost to the contract.

All haul route areas and equipment parking areas shall be restored to the pre-construction condition or proposed condition and to the satisfaction of the Engineer upon completion of their continued use for the Project.

END SECTION 80

PART 2 – GENERAL CONSTRUCTION ITEMS:

Item 102 Temporary Air And Water Pollution, Soil Erosion, And Siltation Control

MATERIALS

102-2.8

Replace this section with the following:

Temporary ditch checks. Temporary ditch checks shall be constructed with rolled excelsior from a manufacturer on the Department's approved list.

BASIS OF PAYMENT

102-5.1

ADD:

Payment will be made under:

Item AR156511 – Ditch Check – per each.

Item AR156530 – Temporary Seeding – per acre.

END OF ITEM 102

Item 105 Mobilization

ITEM 105 MOBILIZATION is modified as follows:

BASIS OF PAYMENT

105-3.1

ADD:

Payment will be made under:

Item AR150520 – Mobilization – per lump sum.

END OF ITEM 105

PART 3 – SITEWORK:

Item 101 Preparation/Removal Of Existing Pavements:

BASIS OF PAYMENT

101-5.1

ADD:

Payment will be made under:

Item AR401900 – Remove Bituminous Pavement – per square yard.

END OF ITEM 101

Item 152 Excavation, Subgrade, And Embankment:

BASIS OF PAYMENT

152-5.1

REMOVE:

Section **152-1.3 d.**

ADD:

Payment will be made under:

Item AR152410 – Unclassified Excavation – per cubic yard.

Item AR152540 – Soil Stabilization Fabric – per square yard.

END OF ITEM 152

PART 4 – BASE COURSES:

Item 209 Crushed Aggregate Base Course

BASIS OF PAYMENT

209-5.1

ADD:

Payment will be made under:

Item AR209606 – Crushed Aggregate Base Course – 6” – per square yard.

END OF ITEM 209

PART 6 – FLEXIBLE PAVEMENTS:

Item 401 Asphalt Mix Pavement Surface Course

DESCRIPTION

401-1.1

ADD:

The surface course shall be laid in lifts not exceeding two (2) inches.

COMPOSITION

401-3.3 - JOB MIX FORMULA (JMF).

ADD:

Asphalt Design Criteria shall indicate the Design Parameters on a Runway or Taxiway for Aircraft weighing under 60,000 lbs.

401-3.5

ADD:

A Bituminous Test Section is required for the surface course.

CONSTRUCTION METHODS

401-4.2 h.

ADD:

Profile testing of the final surface will be required on this project in accordance with this section.

BASIS OF PAYMENT

401-8.1

ADD:

Payment will be made under:

Item AR401614 – Bit. Surf. Cse. – Method II, Superpave – per ton.

Item AR401630 – Bituminous Surface Test Section – per each.

END OF ITEM 401

Item 403 Asphalt Mix Pavement Base Course:

DESCRIPTION

403-1.1

ADD:

The base course shall be laid in two lifts consisting of 2.5”

COMPOSITION

403-3.3 - JOB MIX FORMULA (JMF).

ADD:

Asphalt Design Criteria shall indicate the Design Parameters on a Runway or Taxiway for Aircraft weighing under 60,000 lbs.

403-3.5

ADD:

A Bituminous Test Section is required for the base course.

BASIS OF PAYMENT

403-8.1

ADD:

Payment will be made under:

Item AR403614 – Bit. Base Cse. – Method II, Superpave – per ton.

Item AR403630 – Bituminous Base Test Section – per each.

END OF ITEM 403

PART 9 – MISCELLANEOUS:

Item 602 Emulsified Asphalt Prime Coat:

BASIS OF PAYMENT

602-5.1

ADD:

Payment will be made under:

Item AR602510 – Bituminous Prime Coat – per gallon.

END OF ITEM 602

Item 603 Emulsified Asphalt Tack Coat:

BASIS OF PAYMENT

603-5.1

ADD:

Payment will be made under:

Item AR603510 – Bituminous Tack Coat – per gallon.

END OF ITEM 603

Item 620 Pavement Marking

DESCRIPTION

620-1.1

ADD:

All paint shall be waterborne.

MATERIALS

620-2.2

ADD:

All paint shall be waterborne for this project.

620-2.4

ADD:

Reflective media glass beads shall be applied to all painted surfaces except on the black border.

620-3.5

ADD:

All pavement markings shall consist of two applications of paint, one coat in each direction.

BASIS OF PAYMENT

620-5.1

ADD:

The quantity of permanent markings to be paid for shall be the number of square feet of completed markings, measured only once, regardless of the number of applications.

Payment will be made under:

Item AR620520 -- Pavement Marking - Waterborne – per square foot

Item AR620525 -- Pavement Marking – Black Border – per square foot

The quantity of pavement markings to be removed shall be paid for per square foot of marking removed.

Payment will be made under:

Item AR620900 – Pavement Marking Removal – per square foot

END OF ITEM 603

PART 11 – DRAINAGE:

Item 701 Pipe for Storm Drains and Culverts

701-2.2

ADD:

Pipe shall be reinforced concrete pipe class IV and shall be in accordance with Section 550 the Illinois Department of Transportation's Standard Specifications for Road and Bridge Construction in Illinois, latest edition.

701-5.1

ADD:

Payment will be made under:

Item AR701512 – 12" RCP, CLASS IV – per linear foot.

Item AR701515 – 15" RCP, CLASS IV – per linear foot.

Item AR701518 – 18" RCP, CLASS IV – per linear foot.

Item AR701524 – 24" RCP, CLASS IV – per linear foot.

Item AR701536 – 36" RCP, CLASS IV – per linear foot.

Item AR701548 – 48" RCP, CLASS IV – per linear foot.

END OF ITEM 701

Item 705 Pipe Underdrains For Airports

MATERIALS

705-2.1

ADD:

Underdrains shall be Type 1.

705-2.2

ADD:

Pipe shall be Type 2.

BASIS OF PAYMENT

705-5.1

ADD:

Payment will be made under:

Item AR705526 –6” Perforated Underdrain w/sock – per linear foot.

Item AR705640 – Underdrain Cleanout – per each.

END OF ITEM 705

Item 751 Manholes, Catch Basins, Inlets And Inspection Holes:

CONSTRUCTION METHODS

751-3.3

DELETE entire section

751-3.4

DELETE entire section

751-3.5

ADD:

All structures provided on this project shall be precast concrete structures.

751-3.6

DELETE entire section

BASIS OF PAYMENT

751-5.1

ADD:

Payment will be made under:

Item AR751540 – Manhole, 4’ – per each.

END OF ITEM 751

Item AR 751570 Manhole – Special

DESCRIPTION

This work shall consist of the installation of the stormwater management outlet control structure in accordance with the requirements of ITEM AR 751540 special provision and the details in the plans.

CONSTRUCTION REQUIREMENTS

The Contractor shall supply a precast structure in accordance with the Outlet Control Structure detail provided in the plans. The structure shall include all flow limiting devices, weir walls, secondary frames and flat top lids as required in the details.

BASIS OF PAYMENT

Payment will be made under:

Item AR751570 – Manhole, Special – per each.

END OF ITEM AR 751570

Item 752 Concrete Culverts, Headwalls, And Miscellaneous Drainage Structures

BASIS OF PAYMENT

752-5.1

ADD:

Payment will be made under:

- Item AR752412 – Precast Reinforced Concrete Flared End Section, 12” – per each.**
- Item AR752415 – Precast Reinforced Concrete Flared End Section, 15” – per each.**
- Item AR752418 – Precast Reinforced Concrete Flared End Section, 18” – per each.**
- Item AR752424 – Precast Reinforced Concrete Flared End Section, 24” – per each.**
- Item AR752436 – Precast Reinforced Concrete Flared End Section, 36” – per each.**
- Item AR752448 – Precast Reinforced Concrete Flared End Section, 48” – per each.**

Item 754 Concrete Gutters, Ditches, And Flumes

BASIS OF PAYMENT

754-5.1

ADD:

Payment will be made under:

Item AR754610 – Paved Ditch – per linear foot.

PART 12 – TURFING:

Item 901 Seeding:

BASIS OF PAYMENT

901-5.1

ADD:

Payment will be made under:

Item AR901510 – Seeding – per acre.

END OF ITEM 901

Item 908 Mulching

MATERIALS

908-2.1

ADD:

All mulch material shall be Light-Duty Hydraulic Mulch.

BASIS OF PAYMENT

908-5.1

ADD:

Payment will be made under:

Item AR908510 – Mulching – per acre.

END OF ITEM 908

PART 13 – LIGHTING INSTALLATION:

Item 108 Underground Power Cable For Airports

BASIS OF PAYMENT

108-5.1

ADD:

Payment will be made under:

Item AR108066 – REIL Cable - per linear foot.

Item AR108158 – 1/C #8 5KV UG Cable in UD – per linear foot.

END OF ITEM 108

Item 109 Installation Of Airport Transformer Vault And Vault Equipment

DESCRIPTION

109-1.1

Delete this paragraph and replace with the following:

This item shall consist of furnishing and installing electrical equipment and modifying the existing electrical vault to accommodate the proposed addition of Runway 7/25 as shown on the Plans and as specified herein. This item shall include all labor, materials, transportation, equipment, wiring, raceways, grounding, warranties, tools, coordination, relocations, operational instructions, labeling, testing, and all incidentals required to place the vault and associated equipment into proper working order as a completed unit to the satisfaction of the Owner and Resident Engineer. The existing vault was prefabricated to accommodate the addition of the 2-10 KW regulators.

Included under this item shall be the following:

- a Field verification of existing site conditions to determine complexity of the proposed work.
- b Coordinating all work with the Airport Manager and the Resident Engineer.
- c Furnishing and installing all associated electrical equipment, support hardware, raceways, conduits, cable, wiring, grounding, and accessories as detailed on the Plans and specified herein.
- d Furnishing and installing all pull boxes, junction boxes, wireways, raceways, conduits, conduit fittings, and ducts within or at the vault.
- e Furnishing and installing all necessary cable and wiring within or at the vault, as specified herein.
- f Furnishing and installing all grounding and surge protection as required by the governing codes and equipment manufactures.
- g All work shall be coordinated with the Airport Manager and shall provide a minimum of 72 hour notice prior to a shutdown of any runway lighting or NAVAID equipment.
- h Furnishing catalog cuts of supplied materials and equipment.
- i Testing, adjusting, and retesting (where applicable) all new equipment and modifications to existing systems for proper operation.
- j Labeling all electrical equipment and incidentals necessary to place all of the equipment in operation as a complete unit acceptable to the Owner and Resident Engineer.

- k Furnishing operation, maintenance, and installation manuals for all new equipment."

Add the following section:

109-1.2 References.

- a ANSI C80.1 -- Rigid Steel Conduit, Zinc Coated.
- b ANSI C80.4 -- Fittings Rigid Metal Conduit and EMT.
- c ANSI Z535.4-2011 - American National Standard for Product Safety Signs and Labels.
- d ASTM Specification B3 -- Standard Specification for Soft or Annealed Copper Wire.
- e ASTM Specification B8 -- Standard Specification for Concentric-Lay-Stranded Copper Conductors, Hard, Medium-Hard, or Soft.
- f Federal Specification A-A-59544 Cable and Wire, Electrical (Power, Fixed Installation).
- g FAA AC No. 150/5340-26C "MAINTENANCE OF AIRPORT VISUAL AID FACILITIES."
- h FAA AC No. 150/5340-30J "DESIGN AND INSTALLATION DETAILS FOR AIRPORT VISUAL AIDS."
- i FAA AC No. 150/5345-7F, (or latest edition) "SPECIFICATIONS FOR L-824 UNDERGROUND ELECTRICAL CABLE FOR AIRPORT LIGHTING CIRCUITS."
- j FAA AC No. 150/5345-53 "AIRPORT LIGHTING EQUIPMENT CERTIFICATION PROGRAM" (most current issue) and FAA AC No. 150/5345-53D, AIRPORT LIGHTING EQUIPMENT CERTIFICATION PROGRAM, Appendix 1 Addendum.
- k FAA AC No. 150/5370-2G (or more current issue) "OPERATIONAL SAFETY ON AIRPORTS DURING CONSTRUCTION."
- l FAA-STD-019f dated October 18, 2017, Department of Transportation, Federal Aviation Administration Standard, LIGHTNING AND SURGE PROTECTION, GROUNDING, BONDING, AND SHIELDING REQUIREMENTS FOR FACILITIES AND ELECTRONIC EQUIPMENT.
- m NFPA 70 -- National Electrical Code (most current issue in force).
- n NFPA 70E -- Standard for Electrical Safety in the Workplace.

- o OSHA 29 CFR Part 1910 Occupational Safety and Health Standards for electrical safety and lockout/tagout procedures.
- p UL Standard 6 -- Rigid Metal Conduit.
- q UL Standard 44 -- Thermoset-Insulated Wires and Cables.
- r UL Standard 83 -- Thermoplastic-Insulated Wires and Cables.
- s UL Standard 467 -- Grounding and Bonding Equipment.
- t UL Standard 486A-486B Wire Connectors.
- u UL Standard 514B -- Conduit, Tubing and Cable Fittings.

Add the following section:

109-1.4 Shop drawings.

The Contractor shall furnish shop drawings for approval before ordering equipment and/or materials. Shop drawings are required for equipment and materials to be used on the project. **Shop drawings shall be clear and legible. Copies that are illegible will be rejected.** Contractor shall submit sufficient copies of shop drawings to meet the needs of his personnel, sub-contractor personnel, and equipment suppliers plus four (4) copies to be retained by the Project Engineer. Shop Drawings shall clearly indicate proposed items, capacities, characteristics, and details in conformance with the Plans and Specifications. The respective manufacturer shall certify capacities, dimensions, special features, etc. When a submittal is marked "Revise and Resubmit", "Rejected", and/or "Not Approved", do not proceed with that part of the work covered by the submittal, including purchasing, fabrication, delivery, or other activity. Revise or prepare a new submittal in accordance with the notations, resubmit, and repeat if necessary to obtain a different action mark such as "No Exceptions Taken" or "Furnish as Corrected." Contractor is responsible for compliance with the specified characteristics. Contractor's responsibility for error and omissions in submittals is not relieved by the Engineer's review of submittals. Accompany each submittal with a transmittal letter that includes the date, project title and number, Contractor's name and address, the number of Shop Drawings, product data and/or samples submitted, notification of any deviations from the Contract, and any other pertinent information. Shop drawings shall include the following information:

- a In order to expedite the shop drawing review, inspection and/or testing of materials and equipment, the Contractor shall furnish complete statements to the Project Engineer as to the origin and manufacturer of all materials and equipment to be used in the work. Such

statements shall be furnished promptly after execution of the contract but, in all cases, prior to delivery of such materials and equipment.

- b Provide cut sheets for the power conductors.
- c Cut sheets with part number and specifications for each provided component.

EQUIPMENT AND MATERIALS

109-2.1 General.

Add the following to this section:

- g. FAA approval of airport lighting equipment and subsequent inclusion in FAA AC 150/5345-1 "Approved Airport Equipment", and or FAA AC 150/5345-53 "Airport Lighting Equipment Certification Program" only means that the test data satisfied the applicable Specification requirements. This does not ensure that the approved equipment will satisfactorily operate when connected power-wise and/or control-wise to other approved airport lighting equipment or "off the shelf" equipment not requiring FAA approval.
- h. The Contractor shall ascertain that all lighting system components furnished by him (including FAA-approved equipment) are compatible in all respects with each other and the remainder of the new system. Any non-compatible components furnished by the Contractor shall be replaced by him, at no additional cost to the Airport Sponsor, with a similar unit approved by the Engineer (different model or different manufacturer) that is compatible with the remainder of the airport lighting system.
- i. All materials and equipment used to construct this item shall be submitted to the Engineer for approval prior to ordering the equipment. Submittals consisting of marking catalog sheets or shop drawings shall be provided. Submittal data shall be presented in a clear, precise and thorough manner. Original catalog sheets are preferred. Photocopies are acceptable provided they are as good a quality as the original. Clearly and boldly mark each copy to identify pertinent products or models applicable to this project. Indicate all optional equipment and delete non-pertinent data. Submittals for components of electrical equipment and systems shall identify the equipment for which they apply on each submittal sheet. Markings shall be boldly and clearly made with arrow or circles (highlighting is not acceptable). Contractor is solely responsible for delays in project accruing directly or indirectly from late submissions or resubmissions of submittals.

The data submitted shall be sufficient, in the opinion of the Engineer, to determine compliance with the Plans and Specifications. The Contractor's submittals (five (5) copies) shall be neatly bound in a properly sized 3-ring binder, tabbed by specification

section. The Engineer reserves the right to reject any and all equipment, materials or procedures, which, in the Engineer's opinion, does not meet the system design and the standards and codes, specified herein.

All equipment and materials furnished and installed under this section shall be guaranteed against defects in materials and workmanship for a period of at least twelve (12) months from final acceptance by the Owner. The defective materials and/or equipment shall be repaired or replaced, at the Owner's discretion, with no additional cost to the Owner.

- j. Except as specified otherwise, all new equipment shall be provided by the Contractor and shall be tested for Specification conformance as part of the Aviation Lighting Equipment Certification Program. Certification of Conformance, as tested by the respective testing laboratory, shall be provided by the manufacturer for all items submitted for approval."

109-2.6 Brick.

Delete this section.

109-2.7 Rigid steel conduit.

Add the following:

"GRSC shall be heavy wall, hot-dipped, galvanized steel pipe bearing the UL label and conforming to UL-6 and ANSI Specification C80.1. Couplings, connectors and fittings for rigid steel conduit shall be threaded, galvanized steel, or galvanized malleable iron specifically designed and manufactured for the purpose. Fittings shall conform to ANSI C80.4 and UL-514B. Set screw type fittings are not acceptable. Steel used to manufacture conduits shall be 100 percent domestic steel. Contractor shall provide certification that the respective steel conduits used on this project are manufactured from 100 percent domestic steel."

109-2.12 Paint.

Delete this section.

109-2.16 Vault pre-fabricated metal housing.

Delete this section.

109-2.18 Other electrical equipment.

Add the following:

"Switches, cutouts, relays, lighting connectors, terminal blocks, circuit breakers, and all other regularly used commercial items of electrical equipment not covered by FAA equipment specifications shall conform to the applicable rulings and standards of the Institute of Electrical and Electronic Engineers or the National Electric Manufacturers Association. When specified, test reports from a testing laboratory indicating that the equipment meets the specifications shall be supplied. In all cases, equipment shall be new and a first-grade product. This equipment can be supplied in the quantities required for the specific project and shall incorporate the electrical and mechanical characteristics specified in the Plans or in the proposal. Contractor shall confirm quantity for all electrical equipment with the Plans. Equipment and materials shall be manufactured in the United States to comply with the Airport Improvement Program Buy American Requirements and the Buy American Act. Proposed electrical equipment for the vault shall be as follows:

a Junction and Pull Boxes. Junction and pull boxes shall be sized, as required for conductors and splices and per NEC Article 314. Boxes shall be UL-listed. Special boxes made to suit conditions shall be used to accommodate the respective application, or where required by the NEC, even though they might not be indicated on the Drawings. Surface-mounted exterior junction and pull boxes located in non-hazardous, non-classified areas shall be NEMA

b Constant Current Regulators

1. Two each - L828 Constant Current Regulators, 240 Volt Input, 6.6A Output, 10KW (DCF - Ferroresonant design). (Internal Control Interface cards interchangeable with existing CCR currently on site.)

Each cell is 24 inch x 25.25 inch x 40 inch. It provides full access to all interior equipment through front door and includes the following items:

- a) DCF Ferroresonant Sine Wave Design, Maximum Current THD 5% or less at any load or output setting, interchangeable with existing CCR installed.
- b) 10 kW Output transformer.
- c) Contactor 3-pole, 200 Amp Interrupting Capacity.
- d) Brightness level indicating via Digital Display.
- e) Status level indicating LED lights.
- f) Load isolator (LDT).

- g) Safety door interlocks.
- h) Integral structural design features that allow regulators to be close-coupled and mounted in a side by side or back to back configuration.
- i) Removable lift-off interchangeable door, containing all regulating and control components - simplifies troubleshooting and maintenance. All doors from 4KW to 20KW are Ferro topology interchangeable.
- j) 10) Standard 3 brightness step design, each step fully field adjustable over the full range allowing 3 and 5 step control from the same regulator, Actual Current Set Point accuracy $\pm 0.010A$, by front panel configuration of Firmware.
- k) Overcurrent surges set point and quantities are programmable from 1 to 10 events.
- l) Output Ammeter via Digital Display.
- m) Output Voltmeter via Digital Display.
- n) Elapsed Time Meter via Digital Display.
- o) Power Factor via Digital Display.
- p) Load Power via Digital Display.
- q) VA set points programmable.
- r) Lamp failure set points programmable.
- s) Internal Meggering - Insulation Resistance Monitoring, readout via Main Display.

109-2.19 Electric wire and cable

Add the following to Section a. Control circuits:

"THWN Wire. Cable shall comply with Underwriters' Laboratories Standard UL-83 and Federal Specification A-A-59544. Conductor shall be soft-annealed, uncoated Copper and shall comply with ASTM B3 and B8. Insulation shall be rated for 600-volt. Insulation shall be polyvinyl chloride conforming to Underwriters' Laboratories requirements for Type THW. The outer covering shall be nylon-conforming to Underwriters' Laboratories for type THHN or THWN. Cable shall be UL listed and marked THWN."

Delete paragraphs 1, 2, and 3 under Paragraph 2.19.b - Power Circuits.

Add the following:

"Power Cable (600-Volt and Below). All power wiring, 600-volt and below, shall be the type, size, and number of conductors as noted on the Plans.

THWN Wire. Cable shall comply with Underwriters' Laboratories Standard UL-83 and Federal Specification A-A-59544. Conductor shall be soft-annealed, uncoated Copper and shall comply with ASTM B3 and B8. Insulation shall be rated for 600-volt. Insulation shall be polyvinyl-chloride conforming to Underwriters' Laboratories requirements for Type THW. The outer covering shall be nylon-conforming to Underwriters' Laboratories for type THHN or THWN. Cable shall be UL-listed and marked THWN-2. Power and control wiring shall be Type THWN-2, or approved equal. **Note where THWN wiring is referenced on the Plans, it shall be THWN-2.**

Series Circuit 5,000-Volt Cable. Cable for use with series circuit airfield lighting shall be FAA-L-824, dual rated, MV-90, 5KV, XLP, Type C cable complying with Item 108. L-824 cable shall be FAA approved and listed in the current FAA AC No. 150/5345-53D, AIRPORT LIGHTING EQUIPMENT CERTIFICATION PRORAM, Appendix 3 Addendum. Cable furnished on this project shall comply with the requirements of the Airport Improvement Program Buy American Requirements and the "Buy American Act." Circuits for use with constant current regulator outputs (runway or taxiway lighting circuits) shall use 5000-volt rated cable.

Grounding electrode conductors and/or bonding jumpers shall be the size and type, as detailed on the Plans. Ground wire for bonding constant current regulator housings, cutout enclosures, and other vault equipment frames to the vault ground bus shall be #6 AWG stranded Copper."

INSTALLATION OF EQUIPMENT IN VAULT OR PREFABRICATED METAL HOUSING

109-4.1 General.

Add the following to this section:

"The Contractor shall furnish and install all materials necessary for complete and operational installation of the equipment, as specified herein and as shown on the Plans. The complete installation and wiring shall be done in a neat, workmanlike manner. All

electrical work shall comply with the requirements of the NFPA 70 - National Electric Code (NEC) most current issue in force, and all other applicable local codes, laws, ordinances, and requirements in force. Electrical equipment shall be installed in conformance with the respective manufacturer's directions and recommendations for the respective application. Any installations which void the UL listing, ETL listing (or other third party listing), and/or the manufacturer's warranty of a device will not be permitted.

- a. Contractor shall keep a copy of the latest NEC in force on site at all times during construction for use as a reference.
- b. Contractor shall keep a copy of the Plans, Special Provision Specifications including any addenda, and copies of any change orders on site at all times during construction.
- c. Contractor shall coordinate work and any power outages with the Airport Manager and the Resident Engineer. Any shutdown of existing systems shall be scheduled with and approved by the Airport Manager prior to shutdown. Once shut down, the circuits shall be labeled as such to prevent accidental energizing of the respective circuits. All personnel shall follow U.S. Department of Labor Occupational Safety & Health Administration (OSHA) 29 CFR Part 1910 Occupational Safety and Health Standards for electrical safety and lockout/tagout procedures including, but not limited to, 29 CFR section 1910.147 The Control of Hazardous Energy (lockout/tagout).
- d. Contractor shall comply with the applicable requirements of NFPA 70E - Standard for Electrical Safety in the Workplace.
- e. All electrical equipment installed by the Contractor shall be properly labeled, and all cables must be tagged.
- f. All changes to the airfield lighting system control wiring will be documented by the Contractor and provided to the Resident Engineer.
- g. Locate Existing Underground Utilities and Cables. The location, size, and type of material of existing underground and/or aboveground utilities indicated on the Plans are not represented as being accurate, sufficient, or complete. Neither the Owner nor the Engineer assumes any responsibility whatever in respect to the accuracy, completeness, or sufficiency of the information. There is no guarantee, either expressed or implied, that the locations, size and type of material of existing underground utilities indicated are representative of those to be encountered in the construction. It shall be the Contractor's responsibility to determine the actual location of all such facilities, including service connections to underground utilities. Prior to construction, the Contractor shall notify the utility companies of his

operational plans, and shall obtain, from the respective utility companies, detailed information and assistance relative to the location of their facilities and the working schedule of the companies for removal or adjustment, where required. In the event an unexpected utility interference is encountered during construction, the Contractor shall immediately notify the utility company of jurisdiction. The Owner's Representative and/or the Resident Engineer shall also be immediately notified. Any damage to such mains and services shall be restored to service at once and paid for by the Contractor at no additional cost to the Contract. All utility cables and lines shall be located by the respective utility. **Contact JULIE (Joint Utility Location Information for Excavators) for utility information, phone: 1-800-892-0123.** Contact the FAA (Federal Aviation Administration) for assistance in locating FAA cables and utilities. Location of FAA power, control, and communication cables shall be coordinated with and/or located by the FAA. Also contact Airport Manager and Airport Personnel for assistance in locating underground airport cables and/or utilities. Also coordinate work with all aboveground utilities.

- h. Contractor shall comply with the requirements of FAA AC No. 150/5370-2G (or most current issue) "OPERATIONAL SAFETY ON AIRPORTS DURING CONSTRUCTION."
- i. Secure, identify, and place any temporary exposed wiring in conduit to prevent electrocution and fire ignition sources."

109-4.3 Switchgear and panels.

Add the following to this section:

- a. Installation of Circuit Breakers in Panelboards. Install circuit breakers in panelboards in conformance with the respective manufacturer's directions. Connect only one (1) wire/cable to each breaker terminal. Update circuit directory to identify the respective device fed by each new circuit breaker.

109-4.4 Duct and conduit.

Add the following to this section:

- a. Conduit shall be installed in accordance with the following:
 - 1. All service, feeder, branch circuit, and control circuit conduits associated with the vault shall be galvanized rigid steel conduit as detailed on the Plans.
 - 2. Schedule 40 PVC conduits shall be used for individual grounding electrode conductors and/or bonding jumpers.

b. Conduit Runs:

1. All conduits shall be sized, as indicated on the Drawings, or if conduit sizes not shown shall be in accordance with the NEC. All conduit systems shall be mechanically and electrically continuous from source of current to all outlets and grounded in accordance with the NEC.
2. Run all exposed conduit parallel to building walls using right angle bends. Exposed diagonal runs of conduit will not be permitted. Do not install conduit on roof surfaces unless specifically indicated on the Drawings.
3. Ream conduit after threads are cut. Cut ends square and butt solidly into couplings.
4. Prevent the accumulation of water, foreign matter, or concrete in the conduits during the execution of the work. Temporarily plug conduit, blowout, and swab before wires are pulled.
5. Fasten conduits to all sheet metal boxes and cabinets with two (2) locknuts in accordance with the NEC where insulated bushings are used and where bushings cannot be brought into firm contact with the metal enclosures; otherwise, use at least a single locknut and bushing.
6. Seal each underground joint and make water-tight.
7. Where building construction or other conditions make it impossible to use standard threaded couplings, install water-tight, threaded unions.
8. Make changes in direction of runs with symmetrical bends or cast-metal fittings. Make field-made bends and offsets with conduit bending machine to avoid changing the internal diameter of the conduit and not damage its protective coating either inside or outside. Individual bends shall not exceed 90 degrees, and not more than 270 degrees total bends will be allowed in any one (1) conduit run. Where more bends are necessary, and conduit runs exceed 150 linear feet, install a suitable pull box or junction box.
9. Provide empty conduits installed with a pull wire. Pull wire shall be No. 14 AWG, zinc-coated steel or of plastic having not less than 200 lb. tensile strength. Leave not less than 12 inches of slack at each end of the pull wire.
10. Use liquid-tight, flexible metal conduit for final connection to motors, constant current regulators, transformers, portable equipment, and for equipment subject

to vibration and noise transmission. For each conduit size up to 1-inch trade size, flexible conduit shall be minimum length of 12 inches and a maximum length of 36 inches and for conduit sizes above 1-inch trade size, flexible conduit shall be minimum length of 20 inches and maximum length of 48 inches. Liquid-tight flexible metal conduit and associated fitting shall be UL listed to meet the requirements of NEC 350.6. Liquid-tight flexible metal conduit that is used for flexibility (including connections to motors, constant current regulators, and transformers) shall require an external bonding jumper or internal equipment grounding conductor per NEC 350.60. Do not install liquid-tight flexible metal conduit that is not UL listed.

11. Provide duct seal at conduit terminations inside enclosures where the respective conduit is from below grade.
12. Provide NEMA 4 hubs at conduit entrances for equipment rated NEMA 3R to maintain a watertight seal.

c. Raceway Support and Hangers:

1. Securely fasten raceways in-place and support from ceiling or walls at spacing not exceeding:

Maximum Spacing	Material of Supports
1/2-in. through 1-in. trade size conduit	6 ft.
1-1/4-in. through 1-1/2-in. trade size conduit	8 ft.
2-in. to 4-in. trade size conduit	10 ft.
Liquid-tight, flexible metal conduit	4-1/2 ft.
Metal wireway	10 ft

2. Support rigid conduits within 3 feet of every outlet box, junction box, pull box, cabinet, or termination. Support flexible conduit within 12 inches on each side of every outlet box or fitting.
3. Support conduits by pipe straps, wall brackets, hangers, or ceiling trapeze. The use of perforated iron or wire for supporting conduits is prohibited. Fasten with wood screws or screw nails to wood; by toggle bolts on hollow masonry units,

by concrete inserts, or expansion bolts on concrete or spring-tension or threaded C-clamps for rigid steel conduits on steel. Do not weld conduits or pipe straps to steel structures unless specifically indicated.

4. The load applied to fasteners shall not exceed one-third the proof test load of the fasteners.
5. Fasteners attached to concrete shall be vibration and shock-resistant.
6. All screws, bolts, washers, and miscellaneous hardware used for conduit supports shall be fabricated from rust-resisting metal. Trapeze hangers shall have hanger assemblies protected with galvanized finish."

109-4.5 Wiring and connections.

Add the following to this section:

"Low-voltage wiring shall maintain separation from high-voltage wiring. Low-voltage and high-voltage wiring shall not be installed in the same raceway. Low-voltage and high voltage wiring shall not be installed in the same handhole or junction box."

109-4.6 Marking and labeling.

Add the following to this section:

- c. Legend plates shall be provided for all equipment. Legend plates shall be provided to identify the equipment controlled, the power source, and the function of each device. Legend plates shall be weatherproof and abrasion-resistant phenolic/plastic engraved material and fastened with contact type permanent adhesive, screws, or rivets. Installation shall not break, crack, or deform the legend plate. Lettering shall be ¼ inch high, black on a white background, unless noted otherwise.
- d. Identify control wiring at each termination point and in junction/terminal boxes with wire number corresponding to the respective control wiring diagram or respective terminal numbering arrangement. Each individual control wire shall have unique identification and shall maintain that same identification from its point of origin to its final termination point. Wire markers shall be permanent pressure sensitive label with suitable numbers of letters for easy recognition. Where new control wiring is

interfaced to existing control wiring it shall also match the color coding of the existing control wiring.

- e. Each individual circuit breaker, control panel, terminal panel, safety switch, etc. shall be furnished with a phenolic-engraved legend plate that identifies the respective device, the power source, and the respective voltage, phase, and wire. Furnish additional phenolicengraved legend plates as detailed on the Plans and/or where required by code.
- f. At electrical handholes, identify each cable originating in the vault with respect to the system or device served.
- g. Color-code phase and neutral conductor insulation for No. 6 AWG or smaller. Provide colored marking tape for phase and neutral conductors for No. 4 AWG and larger. Insulated ground conductors shall have green colored insulation for all conductor sizes (AWG and/or KCMIL) to comply with NEC 250.119. Neutral conductors shall have white colored insulation for No. 6 AWG and smaller to meet the requirements of NEC 200.6. Standard colors for power wiring and branch circuits shall be as follows:

120/240 VAC, 1-Phase, 3-Wire System	
Phase A	Black
Phase B	Red
Neutral	White
Ground	Green

- h. Furnish and install weatherproof warning label for each meter socket, enclosed circuit breaker, disconnect switch, switchboard, cutout, panelboard, load center, motor control center, and control panel to warn persons of potential electric arc flash hazards, per the requirements of NEC 110.16 "Flash Protection." Labels shall also conform to ANSI Z535.4-2011 "American National Standard for Product Safety Signs and Labels." NEC 110.16 requires that switchboards, panelboards, industrial control panels, meter socket enclosures, and motor control centers that are likely to require examination, adjustment, servicing, or maintenance while energized shall be field marked to warn qualified persons of potential arc flash hazards. The markings shall be located so as to be clearly visible to qualified persons before examination, adjustment, servicing, or maintenance of the equipment. This new requirement is intended to help reduce the occurrence of serious injury or death due to arcing faults to those working on or near energized electrical equipment. The warning labels are to indicate to a qualified worker who intends to open the equipment for analysis of work that a serious hazard exists and that the work should follow appropriate work practices and wear appropriate personal protective equipment (PPE) for the specific hazard. Labels shall be as detailed on the Plans or shall include at least the following

information: "Warning - Potential Arc-Flash Hazards exist while working on this energized equipment. Appropriate PPE Required."

- i. Furnish and install "DANGER -- HIGH VOLTAGE" signs or labels on all fixed electrical equipment where potentials of 500-volts or more terminal-to-ground are exposed (including, but not limited to, constant current regulators, series circuit cutout enclosures, high voltage junction boxes, and high voltage wireways) in accordance with FAA AC No. 150/5340-26C "MAINTENANCE OF AIRPORT VISUAL AID FACILITIES." Place signs in a conspicuous location, usually on the outside of equipment.

109-4.8 Testing

Add the following:

Tests shall include resistance, voltage, and current reading, as applicable for the respective equipment. When tests disclose any unsatisfactory workmanship or equipment furnished under this contract, correct defects and retest. Repeat tests until satisfactory results are obtained. When any wiring or equipment is damaged by tests, the wiring or equipment shall be repaired or replaced at no additional cost to the contract. Test repaired or replaced items to ensure satisfactory operation. Submit three (3) copies of all test reports to the Engineer. All test reports shall be assembled and bound in a folder or binder. Each test report shall include the following information:

- Project number
- Project title and location
- Device or system tested
- Test performed
- Date performed
- Test equipment used
- Respective Contractor's name, address and telephone number
- Testing firm's name, address and telephone number if other than the Contractor
- Names of individuals performing tests
- Names of individuals observing tests
- Statement verifying each test
- Nameplate data from respective equipment tested
- Test results
- Retest results after correction of defective components or systems (where applicable)

The Contractor shall be required to schedule an on-site visit from the regulator equipment manufacturer prior to energizing the system. A complete evaluation shall be completed

by the manufacturer of all regulator equipment (new and existing) to ensure that the equipment is working properly.

Add the following section:

109-4.9 Grounding requirements.

Grounding shall conform to the following as applicable: The Contractor shall furnish and install all grounding as shown on the Plans and/or as may be necessary or required to make a complete grounding system, as required by the latest NEC (NFPA 70) in force. The reliability of the grounding system is dependent on careful, proper installation, and choice of materials. Improper preparation of surfaces to be joined to make an electrical path, loose joints, or corrosion can introduce impedance that will seriously impair the ability of the ground path to protect personnel and equipment and to absorb transients that can cause noise in communication circuits. The following functions are particularly important to ensure a reliable ground system:

- a. All products associated with the grounding system shall be UL-listed and labeled.
- b. All bolted or mechanical connections shall be coated with a corrosion preventative/conductive grease and lubricant suitable for electrical connections and grounding connections, before joining. Sanchem, Inc. "NO-OX-ID A-Special" compound, Burndy Penetrox E, or approved equal.
- c. Metallic surfaces to be joined shall be prepared by the removal of all non-conductive material, per 2011 NEC Article 250.12. All Copper bus bars must be cleaned prior to making connections to remove surface oxidation.
- d. Metallic raceway fittings shall be made up tight to provide a permanent low impedance path for all circuits. Metal conduit terminations in enclosures shall be bonded to the enclosure with UL-listed fittings suitable for grounding. Provide grounding bushings with bonding jumpers for all metal conduits entering service equipment (meter base, CT cabinet, main service breaker enclosure, etc.), generator breaker enclosures, and automatic transfer switch enclosures. Provide grounding bushings with bonding jumpers for all metal conduits entering an enclosure through concentric or eccentric knockouts that are punched or otherwise formed so as to impair the electrical connection to ground. Standard lockouts or bushings shall not be the sole means for bonding where a conduit enters an enclosure through a concentric or eccentric knockout.
- e. All connections, located above grade, between the different types of grounding conductors shall be made using UL-listed, double-compression, crimp-type connectors or UL-listed, bolted ground connectors. For ground connections to enclosures, cases, and frames of electrical equipment not supplied with ground lugs,

the Contractor shall drill required holes for mounting a bolted, ground connector. All bolted, ground connectors shall be Burndy, Thomas and Betts, or equal. Tighten connections to comply with tightening torques in UL Standard 486A to ensure permanent and effective grounding.

- f. All metal equipment enclosures, conduits, cabinets, boxes, receptacles, etc. shall be bonded to the respective grounding system. Provide grounding bushings at all conduits entering service entrance equipment (meter bases, service disconnects, service panelboards, etc.) and distribution panels or load centers and ground wire from bushing to ground bus in the respective service entrance equipment or distribution panel.
- g. Each feeder circuit and/or branch circuit shall include an equipment ground wire. Metal raceway or conduit shall not meet this requirement. The equipment ground wire from equipment shall not be smaller than allowed by 2011 NEC Table 250.122 "Minimum Size Conductors or Grounding Raceway and Equipment." When conductors are adjusted in size to compensate for voltage drop, equipment-grounding conductors shall be adjusted proportionately according to circular mil area. All equipment ground wires shall be Copper, either bare or insulated green in color. Where the equipment grounding conductors are insulated, they shall be identified by the color green, and shall be the same insulation type as the phase conductors.
- h. Bond the main electrical service neutral to ground at the main service disconnect. Bond the service neutral to ground at one (1) location only per the NEC. A grounding connection shall not be made to any neutral circuit conductor on the load side of the service disconnecting means, except as permitted by 2011 NEC 250.24.
- i. The secondary neutral of all transformers (separately derived system transformers) shall be grounded in accordance with the NEC. The respective grounding electrode conductor shall be connected to the neutral point of the transformer between the transformer and the output disconnecting means. Size of the grounding electrode conductor shall be in accordance with 2011 NEC Article 250.66 and Table 250.66 unless shown larger on the Plans. A bond shall be provided between the neutral and transformer case, or other metal that is part of the AC equipment grounding system, so as to complete a circuit for fault current to the transformer winding from the AC equipment grounding system. Size of the neutral bonding conductor shall be in accordance with 2011 NEC Article 250.102.
- j. All exterior metal conduits, where not electrically continuous because of manholes, handholes, non-metallic junction boxes, etc. shall be bonded to all other metal conduit in the respective duct run, and at each end, with a Copper-bonding jumper sized in conformance with 2011 NEC 250.102. Where metal conduits terminate in an

enclosure (such as a motor control center, switchboard, etc.) where there is not electrical continuity with the conduit and the respective enclosure, provide a bonding jumper from the respective enclosure ground bus to the conduit sized per 2011 NEC 250.102.

- k. Install grounding electrode conductors and/or individual ground conductors in Schedule 40 or Schedule 80 PVC conduit. Where grounding electrode conductors or individual ground conductors are run in PVC conduit, do not completely encircle conduit with ferrous and/or magnetic materials. Use non-metallic, reinforced fiberglass strut support. Where metal conduit clamps are installed, use nylon bolts, nuts, washers, and spacers to interrupt a complete metallic path from encircling the conduit.
- l. Individual ground conductors and/or grounding electrode conductors shall not be run in metallic conduit and shall not be encircled by metallic clamps. If local codes dictate that grounding conductors must be run in metal conduit or raceway, then the conduit or raceway must be bonded to the grounding conductor at both ends with a bonding jumper sized in accordance with NEC 250.64(E). All such installations requiring individual grounding conduits to be run in metal conduit or raceway shall be verified and reviewed with the Resident Engineer. This does not apply to AC equipment ground wires run with AC circuits.

METHOD OF MEASUREMENT

109-5.4.

- a. The quantity of vault modifications, equipment, and materials to be paid for under Item AR109210 Vault Modification shall consist of furnishing and installing all electrical equipment and performing the necessary modifications to the existing vault, as detailed on the Plans and specified herein. This item shall include all labor, equipment, grounding, materials, tools, operational instructions, coordination, and testing required to place the modifications and associated electrical equipment into proper working order. Conduit entries, elbows, and fittings located at, adjacent to, or beneath the structure shall be considered incidental to this item and no additional compensation will be allowed.
- b. Constant current regulators will be measured for payment per each unit installed and connected as specified, completed, ready for operation and accepted by the Engineer.

BASIS OF PAYMENT

Special Provisions
Morris Municipal Airport

Illinois Project No. C09-5011

109-6.1

Add the following:

Payment will be made under:

Item AR109210 Vault Modification - Per Lump Sum.

Item AR109321 10 Kw Regulator, Style 1 – Per Each

END OF ITEM 109

Item 110 Airport Underground Electrical Duct Banks And Conduits

BASIS OF PAYMENT

110-5.1

ADD:

Payment will be made under:

Item AR110101 – Cable Marker – per each.

Item AR110102 – Duct Marker – In Pavement – per each.

Item AR110502 – 2-Way Concrete Encased Duct – per linear foot.

END OF ITEM 110

Item 125 Installation Of Airport Lighting Systems

DESCRIPTION

125.1.1

ADD:

Also included in this work shall be the removal of airfield lighting, guidance signs, splice cans and other associated appurtenances in accordance with the plans and specifications.

Special attention is called to the following standards related to all electrical work on the airfield lighting systems:

- a. OSHA 29 CFR Part Number 1910; Occupational Safety and Health Standards, Standard Number 1910.147; The control of hazardous energy (lockout/tagout)
- b. NFPA 70E – Standard for Electrical Safety in the Workplace
- c. FAA AC No. 150/5370-2G “Operational Safety on Airports During Construction (current edition)

EQUIPMENT AND MATERIALS

125-2.8 d

ADD:

Taxiway A shall have taxiway edge lights that are Type L-861T Medium intensity Taxiway Edge Light.

Taxiway B, Taxiway C, and their associated connecting taxiways shall have taxiway edge lights that are Type L-861T(L) Medium Intensity Taxiway Edge Light with LED (Light Emitting Diode) illumination.

Runway 7/25 shall have runway edge lights that are Type L-861(L) Medium Intensity Runway Edge Light with LED (Light Emitting Diode) illumination.

Runway 7/25 shall have runway threshold/end lights that are Type L-861E(L) Medium Intensity End Light with LED (Light Emitting Diode) illumination.

Runway 18/36 shall have runway edge lights that are Type L-861 Medium Intensity Runway Edge Light.

125-2.9

ADD:

All runway and taxiway guidance signs shall be Size 2, Style 2, Class 2, and Mode 2.

ADD:

125-2.16

Sign panels to be replaced in existing taxiway guidance signs shall be in accordance with the requirements of 125-2.9. The Contractor shall be responsible for verifying the provided sign panel's compatibility with the existing guidance sign.

CONSTRUCTION METHODS

125-3.1

ADD:

The Contractor shall check with the Airport Sponsor to see what, if any, components the Sponsor would like to keep from the existing stake mounted light after removal by the Contractor. The Contractor shall dispose of any unwanted components off site.

ADD:

125-3.5 Removal of Electrical Items. The Contractor shall be responsible for the removal of items designated for removal on the plans or as directed by the resident engineer. The removal of items shall be performed with qualified electrical professionals with experience in medium voltage, series circuit systems.

The Contractor shall be responsible for coordinating the shut down of the airfield electrical systems a minimum of 72 hour prior to system shutdown and shall also be responsible for the verification of the safe shutdown and subsequent lockout of the system. The Contractor shall familiarize himself with the airfield circuitry and perform all necessary tests for verification of system safety prior to initiating any work on the existing system.

Interruptions to the operation of the airfield lighting system should be limited in duration. In instances where temporary connections are necessary to limit interruption, the Contractor shall furnish temporary cable and connector kits as necessary to place the system back into service. All temporary connection shall be left in a manner consistent with all applicable referenced standards. Temporary work will not be paid separately but shall be included in the cost of the associated removal item.

Lights and guidance signs shall be removed in their entirety, including but not limited to stakes, concrete bases, transformers, foundations, and all other related appurtenances. Any cabling that is to remain shall be verified to be fully disconnected from the system and shall be buried a minimum of 18" below grade. Any necessary splicing of cable to remain for the continued operation of the existing system shall be completed in accordance with the plan details and specifications.

All removed fixtures and stakes shall be returned to the Airport Manager. Care should be taken in the removal process so as not to damage the items that will be returned. In instances where the Engineer determines that damage to salvaged items is excessive or avoidable, the Contractor will not be paid for the removal of that item.

All other removed items, including splice cans, foundations, and removed cable shall be disposed of by the Contractor off-site in accordance with all applicable laws governing the disposal of construction debris. The cost of this disposal shall be included in the cost of the associated removal item.

BASIS OF PAYMENT

125-5.1

ADD:

Payment will be made under:

- Item AR125410 – MITL – Stake Mounted – per each.**
- Item AR125415 – MITL – Base Mounted – per each.**
- Item AR125441 – Taxiway Guidance Sign, 1 Character – per each.**
- Item AR125442 – Taxiway Guidance Sign, 2 Character – per each.**
- Item AR125443 – Taxiway Guidance Sign, 3 Character – per each.**
- Item AR125444 – Taxiway Guidance Sign, 4 Character – per each.**
- Item AR125505 – MIRL – Stake Mounted – per each.**
- Item AR125510 – MIRL – Base Mounted – per each.**
- Item AR125565 – Splice Can – per each.**
- Item AR125610 – REIL – per pair.**
- Item AR125901 – Remove Stake Mounted Light – per each.**
- Item AR125902 – Remove Base Mounted Light – per each.**
- Item AR125904 – Remove Taxiway Guidance Sign – per each.**
- Item AR125906 – Remove Splice Can – per each.**
- Item AR125932 – Replace Sign Panel – per each.**

Special Provisions
Morris Municipal Airport

Illinois Project No. C09-5011

END OF ITEM 125