

SUMMARY OF QUANTITIES

ITEM NO.	DESCRIPTION	UNIT	TOTAL QUANTITIES	AS BUILT QUANTITIES
AR108158	1/C #8 5 KV UG CABLE IN UD	L.F.	4,756	
AR108554	2/C #4 600 V UG CABLE IN UD	L.F.	1,965	
AR108656	3/C #6 600 V UG CABLE IN UD	L.F.	4,446	
AR108658	3/C #8 600 V UG CABLE IN UD	L.F.	976	
AR110014	4" DIRECTIONAL BORE	L.F.	310	
AR110502	2-WAY CONCRETE ENCASED DUCT	L.F.	55	
AR110504	4-WAY CONCRETE ENCASED DUCT	L.F.	130	
AR110610	ELECTRICAL HANDHOLE	EA.	2	
AR110710	ELECTRICAL MANHOLE	EA.	6	
AR125565	SPLICE CAN	EA.	1	
AR125610	REILS	PR.	1	
AR125901	REMOVE STAKE MOUNTED LIGHT	EA.	1	
AR125966	RELOCATE SPLICE CAN	EA.	1	
AR125961	RELOCATE STAKE MOUNTED LIGHT	EA.	16	
AR125962	RELOCATE BASE MOUNTED LIGHT	EA.	3	
AR125964	RELOCATE TAXI GUIDANCE SIGN	EA.	2	
AR150510	ENGINEER'S FIELD OFFICE	L.S.	1	
AR150520	MOBILIZATION	L.S.	1	
AR150540	HAUL ROUTE	L.S.	1	
AR152410	UNCLASSIFIED EXCAVATION	C.Y.	2,964	
AR155540	BY-PRODUCT LIME	TON	41	
AR155612	SOIL PROCESSING - 12"	S.Y.	1,505	
AR156510	SILT FENCE	L.F.	300	
AR156520	INLET PROTECTION	EA.	2	
AR156521	HEADWALL PROTECTION	EA.	2	
AR156530	TEMPORARY SEEDING	AC.	1.6	
AR156531	EROSION CONTROL BLANKET	S.Y.	334	
AR209510	CRUSHED AGGREGATE BASE COURSE	TON	524	
AR401613	BIT. SURF. CSE.-METHOD I, SUPERPAVE	TON	353	
AR401900	REMOVE BITUMINOUS PAVEMENT	S.Y.	1,884	
AR602510	BITUMINOUS PRIME COAT	GAL.	525	
AR603510	BITUMINOUS TACK COAT	GAL.	222	
AR620520	PAVEMENT MARKING - WATERBORNE	S.F.	795	
AR620525	PAVEMENT MARKING - BLACK BORDER	S.F.	865	
AR620900	PAVEMENT MARKING REMOVAL	S.F.	93	
AR701512	12" RCP, CLASS IV	L.F.	207	
AR701900	REMOVE PIPE	L.F.	207	
AR705900	REMOVE UNDERDRAIN	L.F.	82	
AR705904	REMOVE UNDERDRAIN CLEANOUT	EA.	1	
AR751410	INLET	EA.	1	
AR751900	REMOVE INLET	EA.	1	
AR752412	PRECAST REINFORCED CONC. FES 12"	EA.	1	
AR752900	REMOVE END SECTION	EA.	1	
AR901510	SEEDING	AC.	1.6	
AR908510	MULCHING	AC.	1.5	

UTILITY NOTE

THE LOCATION, SIZE, AND TYPE OF MATERIAL OF EXISTING UNDERGROUND AND/OR ABOVEGROUND UTILITIES INDICATED ON THE PLANS ARE NOT REPRESENTED AS BEING ACCURATE, SUFFICIENT OR COMPLETE. NEITHER THE OWNER NOR THE ENGINEER ASSUMES ANY RESPONSIBILITY WHATEVER IN RESPECT TO THE ACCURACY, COMPLETENESS, OR SUFFICIENCY OF THE INFORMATION. THERE IS NO GUARANTEE, EITHER EXPRESSED OR IMPLIED, THAT THE LOCATIONS, SIZE AND TYPE OF MATERIAL OF EXISTING UNDERGROUND UTILITIES INDICATED ARE REPRESENTATIVE OF THOSE TO BE ENCOUNTERED IN THE CONSTRUCTION. IT SHALL BE THE CONTRACTOR'S RESPONSIBILITY TO DETERMINE THE ACTUAL LOCATION OF ALL SUCH FACILITIES, INCLUDING SERVICE CONNECTIONS TO UNDERGROUND UTILITIES. PRIOR TO CONSTRUCTION, THE CONTRACTOR SHALL NOTIFY THE UTILITY COMPANIES OF HIS OPERATIONAL PLANS AND SHALL OBTAIN FROM THE RESPECTIVE UTILITY COMPANIES DETAILED INFORMATION AND ASSISTANCE RELATIVE TO THE LOCATION OF THEIR FACILITIES AND THE WORKING SCHEDULE OF THE COMPANIES FOR REMOVAL OR ADJUSTMENT WHERE REQUIRED. IN THE EVENT AN UNEXPECTED UTILITY INTERFERENCE IS ENCOUNTERED DURING CONSTRUCTION, THE CONTRACTOR SHALL IMMEDIATELY NOTIFY THE UTILITY COMPANY OF JURISDICTION. THE OWNER'S REPRESENTATIVE AND/OR THE RESIDENT ENGINEER SHALL ALSO BE IMMEDIATELY NOTIFIED. ANY DAMAGE TO SUCH MAINS AND SERVICES SHALL BE RESTORED TO SERVICE AT ONCE AND PAID FOR BY THE CONTRACTOR AT NO ADDITIONAL COST TO THE CONTRACT. ALL UTILITY CABLES AND LINES SHALL BE LOCATED BY THE RESPECTIVE UTILITY. **CONTACT JULIE (JOINT UTILITY LOCATION INFORMATION FOR EXCAVATORS) FOR UTILITY INFORMATION, PHONE: 1-800-892-0123.** CONTACT THE FAA (FEDERAL AVIATION ADMINISTRATION) FOR ASSISTANCE IN LOCATING FAA CABLES AND UTILITIES. LOCATION OF FAA POWER, CONTROL, AND COMMUNICATION CABLES SHALL BE COORDINATED WITH AND/OR LOCATED BY THE FAA. ALSO CONTACT AIRPORT DIRECTOR/MANAGER AND AIRPORT PERSONNEL FOR ASSISTANCE IN LOCATING UNDERGROUND AIRPORT CABLES AND/OR UTILITIES. ALSO COORDINATE WORK WITH ALL ABOVEGROUND UTILITIES.

INDEX TO SHEETS

SHEET NO.	DESCRIPTION
1	COVER SHEET
2	SUMMARY OF QUANTITIES AND INDEX TO SHEETS
3	PROPOSED SAFETY PLAN
4	PROPOSED CONSTRUCTION PLAN
5	PROPOSED CONSTRUCTION NOTES
6	PROPOSED STORMWATER POLLUTION PREVENTION PLAN
7	PROPOSED STORMWATER POLLUTION PREVENTION DETAILS
8	PROPOSED TAXIWAY A PLAN & PROFILE STA. 0+00 TO STA. 4+00
9	PROPOSED DRAINAGE REMOVAL PLAN
10	PROPOSED DRAINAGE PLAN
11	PROPOSED STAKING PLAN
12	PROPOSED MARKING PLAN
13	PROPOSED CROSS-SECTIONS FOR TAXIWAY A STA. 0+38 TO STA. 0+60
14	PROPOSED CROSS-SECTIONS FOR TAXIWAY A STA. 1+00 TO STA. 1+50
15	PROPOSED CROSS-SECTIONS FOR TAXIWAY A STA. 2+00 TO STA. 2+50
16	PROPOSED CROSS-SECTIONS FOR TAXIWAY A STA. 3+00 TO STA. 3+47
17	PROPOSED CROSS-SECTIONS FOR TAXIWAY A STA. 3+83
18	EXISTING ELECTRICAL PLAN
19	PROPOSED LIGHTING LAYOUT FOR TAXIWAY A
20	PROPOSED LIGHTING LAYOUT FOR TAXIWAY B
21	PROPOSED LIGHTING LAYOUT FOR TAXIWAY C
22	PROPOSED CABLE LAYOUT FOR RUNWAY 18-38 NAVAIDS
23	PROPOSED CABLE LAYOUT FOR RUNWAY 9-27 NAVAIDS
24	PROPOSED CABLE LAYOUT FOR WIND CONE
25	PROPOSED LAYOUT FOR RUNWAY 27 REILS
26	PROPOSED CABLE LAYOUT IN VAULT AREA
27	ELECTRICAL DETAILS SHEET 1
28	ELECTRICAL DETAILS SHEET 2
29	ELECTRICAL DETAILS SHEET 3
30	ELECTRICAL DETAILS SHEET 4
31	4' X 4' X 4' ELECTRICAL MANHOLE
32	REIL DETAILS AND NOTES
33	ELECTRICAL NOTES SHEET 1
34	ELECTRICAL NOTES SHEET 2
35	ELECTRICAL LEGEND AND ABBREVIATIONS
36	EXISTING ELECTRICAL ONE-LINE FOR VAULT AND AIRFIELD NAVAIDS
37	PROPOSED ELECTRICAL ONE-LINE FOR VAULT AND AIRFIELD NAVAIDS
38	PROPOSED ELECTRICAL ONE-LINE FOR AIRFIELD NAVAIDS
39	RUNWAY 27 REIL CONTROL WIRING SCHEMATIC
40	HIGH VOLTAGE WIRING SCHMATIC
41	GROUNDING DETAILS
42	GROUNDING NOTES

CERTIFIED PAYROLLS

THE RESIDENT ENGINEER CANNOT FORWARD CONSTRUCTION REPORTS TO THE ILLINOIS DIVISION OF AERONAUTICS FOR PROCESSING UNTIL ALL CERTIFIED PAYROLLS FOR THE PERIOD HAVE BEEN RECEIVED.

MATERIAL CERTIFICATION

COMPLETED WORK CANNOT BE PLACED ON A CONSTRUCTION REPORT UNTIL ALL MATERIAL CERTIFICATIONS FOR THAT PAY ITEM HAVE BEEN RECEIVED, REVIEWED AND ACCEPTED BY THE RESIDENT ENGINEER.

02/05/13	REVISED AS PER IDA REVIEW
----------	---------------------------

LITCHFIELD MUNICIPAL AIRPORT  
LITCHFIELD, ILLINOIS

IL PROJ.: 31F-4194 BLOCK GRANT PROJ.: 3-17-0063-B19

12A0062D	G-002-FLP.cwg	NOT TO SCALE	01/11/13
LAYOUT	CAH	06/11/12	
DRAWN	BAK	06/11/12	
REVIEWED	CAH	01/10/13	



HANSON Professional Services Inc. 2013  
1525 South Sixth Street  
Springfield, Illinois 62703-2986  
Ph: (217) 788-2450 Fax: (217) 788-2503  
www.hanson-inc.com  
Offices Nationwide

SUMMARY OF QUANTITIES  
AND INDEX TO SHEETS