

THE LOCATION, SIZE, AND TYPE OF MATERIAL OF EXISTING UNDERGROUND AND/OR ABOVEGROUND UTILITIES INDICATED ON THE PLANS ARE NOT REPRESENTED AS BEING ACCURATE, SUFFICIENT OR COMPLETE. NEITHER THE OWNER NOR THE ENGINEER ASSUMES ANY RESPONSIBILITY WHATEVER IN RESPECT TO THE ACCURACY, COMPLETENESS, OR SUFFICIENCY OF THE INFORMATION. THERE IS NO GUARANTEE, EITHER EXPRESSED OR IMPLIED, THAT THE LOCATIONS, SIZE AND TYPE OF MATERIAL OF EXISTING UNDERGROUND UTILITIES INDICATED ARE REPRESENTATIVE OF THOSE TO BE ENCOUNTERED IN THE CONSTRUCTION. IT SHALL BE THE CONTRACTOR'S RESPONSIBILITY TO DETERMINE THE ACTUAL LOCATION OF ALL SUCH FACILITIES, INCLUDING SERVICE CONNECTIONS TO UNDERGROUND UTILITIES. PRIOR TO CONSTRUCTION, THE CONTRACTOR SHALL NOTIFY THE UTILITY COMPANIES OF HIS OPERATIONAL PLANS AND SHALL OBTAIN FROM THE RESPECTIVE UTILITY COMPANIES DETAILED INFORMATION AND ASSISTANCE RELATIVE TO THE LOCATION OF THEIR FACILITIES AND THE WORKING SCHEDULE OF THE COMPANIES FOR REMOVAL OR ADJUSTMENT WHERE REQUIRED. IN THE EVENT AN UNEXPECTED UTILITY INTERFERENCE IS ENCOUNTERED DURING CONSTRUCTION, THE CONTRACTOR SHALL IMMEDIATELY NOTIFY THE UTILITY COMPANY OF JURISDICTION. THE OWNER'S REPRESENTATIVE AND/OR THE RESIDENT ENGINEER SHALL ALSO BE IMMEDIATELY NOTIFIED. ANY DAMAGE TO SUCH MAINS AND SERVICES SHALL BE RESTORED TO SERVICE AT ONCE AND PAID FOR BY THE CONTRACTOR AT NO ADDITIONAL COST TO THE CONTRACT.

ALL UTILITY CABLES AND LINES SHALL BE LOCATED BY THE RESPECTIVE UTILITY. **CONTACT JULIE (JOINT UTILITY LOCATION INFORMATION FOR EXCAVATORS) FOR UTILITY INFORMATION, PHONE: 1-800-892-0123.** CONTACT THE FAA (FEDERAL AVIATION ADMINISTRATION) FOR ASSISTANCE IN LOCATING FAA CABLES AND UTILITIES. LOCATION OF FAA POWER, CONTROL, AND COMMUNICATION CABLES SHALL BE COORDINATED WITH AND/OR LOCATED BY THE FAA. ALSO CONTACT AIRPORT DIRECTOR/MANAGER AND AIRPORT PERSONNEL FOR ASSISTANCE IN LOCATING UNDERGROUND AIRPORT CABLES AND/OR UTILITIES. ALSO COORDINATE WORK WITH ALL ABOVEGROUND UTILITIES.

NOTE TO CONTRACTOR:



ONLY THE EXISTING AND PROPOSED ELECTRICAL CABLES (FOR RWY 18-36 & TAXIWAY "C") IDENTIFIED ON THIS SHEET HAVE BEEN SHOWN FOR CLARITY. ALL OTHER EXISTING AND PROPOSED ELECTRICAL CABLES HAVE NOT BEEN SHOWN. WHILE INSTALLING THESE CABLES THE CONTRACTOR SHALL BE AWARE THAT THE OTHER EXISTING AND PROPOSED ELECTRICAL CABLES, EVEN THOUGH NOT SHOWN, ARE STILL PRESENT. WHEN IN DOUBT THE CONTRACTOR SHOULD REFER TO THE OTHER PROPOSED CABLE LAYOUT SHEETS TO DETERMINE LOCATION OF OTHER EXISTING AND PROPOSED CABLES.

THE CONTRACTOR WILL HAVE TO KEEP THE TAXIWAY "C"/RUNWAY 18-36 LIGHTING CIRCUIT ACTIVE (AT LEAST AT THE END OF EACH CONSTRUCTION DAY) WHILE THE PROPOSED TAXIWAY "C" HOMERUNS ARE BEING INSTALLED AND TAXIWAY "A" RE-ALIGNED.

THE CONTRACTOR MAY HAVE TO INSTALL A JUMPER CABLE FROM THE TWO EXISTING HOMERUN LIGHTS TO THE EXISTING HIGH VOLTAGE HANDHOLE THAT LEADS TO THE EXISTING ELECTRICAL VAULT. IF THE JUMPER CABLES ARE INSTALLED ABOVE GROUND THEY WILL HAVE TO BE IN A DUCT IN ACCORDANCE WITH FAA AC 150/5370-2F "OPERATIONAL SAFETY ON AIRPORTS DURING CONSTRUCTION". THE CABLE USED FOR THE TEMPORARY JUMPERS CAN BE NO. 8, 5 KV UG CABLE ALREADY REMOVED BY THE CONTRACTOR ON THIS PROJECT OR ANOTHER PROJECT.

THE INSTALLATION, MAINTENANCE AND REMOVAL OF ANY JUMPER CABLES WILL BE CONSIDERED AS AN INCIDENTAL ITEM TO THE CONTRACT AND NO ADDITIONAL COMPENSATION WILL BE ALLOWED.

- LEGEND**
- EXISTING PAVEMENT
 - PROPOSED IMPROVEMENTS
 - EXISTING ELECTRICAL DUCT
 - PROPOSED ELECTRICAL DUCT
 - PROPOSED 1/C #8 AWG, FAA L-824, 5000 V TYPE C UNDERGROUND CABLE IN UNIT DUCT
 - EXISTING UNDERDRAIN
 - EXISTING STORM SEWER
 - PROPOSED STORM SEWER
 - RELOCATED STAKE MOUNTED TAXIWAY LIGHT
 - RELOCATED BASE MOUNTED TAXIWAY LIGHT
 - PROPOSED ELECTRICAL HANDHOLE, MANHOLE
 - EXISTING STAKE MOUNTED RUNWAY THRESHOLD LIGHT
 - RELOCATED TAXI GUIDANCE SIGN
 - PROPOSED INLET
 - PROPOSED END SECTION



REVISION	DATE

**LITCHFIELD MUNICIPAL AIRPORT
LITCHFIELD, ILLINOIS**

IL PROJ.: 31F-4194 BLOCK GRANT PROJ.: 3-17-0063-B19

Hanson Proj. No. 12A0062D	FILENAME: E-142-3-ELEC.dwg	Scale 1" = 20'	Date 01/11/13
LAYOUT	CAH	06/11/12	
DRAWN	BAK	06/11/12	
REVIEWED	CAH/KNL	01/10/13	

HANSON
 © Copyright Hanson Professional Services Inc. 2013
Hanson Professional Services Inc.
 1525 South Sixth Street
 Springfield, Illinois 62703-2986
 Ph: (217) 788-2450 Fax: (217) 788-2503
 www.hanson-inc.com
 Offices Nationwide

REALIGN TAXIWAY "A"

PROPOSED LIGHTING LAYOUT FOR TAXIWAY C

FEB 06, 2013 10:02 AM H:\GLO\00382
 p:\s\sp\svr306\hanson\dom\hanson\Projects\Documents\12A0062\12A0062D\CAD\litchfield\litchfield\14-486-31ELEC.dwg