



Illinois Department of Transportation

2300 South Dirksen Parkway / Springfield, Illinois / 62764

June 5, 2007

SUBJECT: FAI Route 55
Project IM-055-6 (225) 265
Section 99 (1 & 2) WRS-3
Will County
Contract No. 60B47
Item No. 174, June 15, 2007 Letting
Addendum A

NOTICE TO PROSPECTIVE BIDDERS:

Attached is an addendum to the plans or proposal. This addendum involves revised and/or added material.

1. Revised pages 1, 2 & 7 of the Schedule of Prices.
2. Revised pages ii & iii of the Table of Contents to the Special Provisions.
3. Revised pages 60 – 69 of the Special Provisions.
4. Added pages 164 & 165 to the Special Provisions.
5. Revised sheets 2, 3, 6, 9, 10 & 19 of the Plans.

Prime contractors must utilize the enclosed material when preparing their bid and must include any Schedule of Prices changes in their bidding proposal.

Bidders using computer-generated bids are cautioned to reflect any and all Schedule of Prices changes, if involved, into their computer programs.

Very truly yours,

Eric E. Harm
Interim Bureau Chief
Bureau of Design and Environment

A handwritten signature in black ink, reading 'Ted B. Walschleger' with a small 'P.E.' to the right.

By: Ted B. Walschleger, P. E.
Engineer of Project Management

cc: Diane O'Keefe, Region 1, District 1; N. R. Stoner; Roger Driskell; R. E. Anderson; Estimates; Design & Environment File

TBW:MS:jc

**ILLINOIS DEPARTMENT OF TRANSPORTATION
SCHEDULE OF PRICES**

Page 1
6/5/2007

**CONTRACT
NUMBER -**

60B47

State Job # - C-91-349-06
PPS NBR - 1-74984-1400
County Name - WILL - -
Code - 197 - -
District - 1 - -
Section Number - 99(1&2)WRS-3

Project Number
IM-055-6/225/265

Route
FAI 55

Item Number	Pay Item Description	Unit of Measure	Quantity	x	Unit Price	=	Total Price
XX000582	WINGWALL REPAIR COMP	L SUM	1.000				
XX001874	PERM DITCH CHECKS	EACH	3.000				
XX002870	AGGREGATE SHLDS B SPL	SQ YD	8,207.000				
X0322054	REM PRC FL END SEC	EACH	5.000				
X0322256	TEMP INFO SIGNING	SQ FT	1,622.000				
X0322323	WEED CONTROL TEASEL	GALLON	3.000				
* X0322729	MATL TRANSFER DEVICE	TON	28,583.000				
X0323426	SED CONT DR ST INL CL	EACH	47.000				
X0323574	MAINTAIN LIGHTING SYS	CAL MO	18.000				
X0323973	SED CONT SILT FENCE	FOOT	1,800.000				
X0323974	SED CONT SILT FN MAIN	FOOT	429.000				
X0324045	SED CON STAB CON EN R	EACH	8.000				
X0324114	DR ST T8X3 W/2 T20F&G	EACH	2.000				
X0324181	DISCON SN LTG/RM WIRE	EACH	1.000				
X0324685	TEST STRIP SMA	EACH	2.000				
			* REVISED : JUNE 5, 2007				

**ILLINOIS DEPARTMENT OF TRANSPORTATION
SCHEDULE OF PRICES**

Page 2
6/5/2007

**CONTRACT
NUMBER -**

60B47

State Job # - C-91-349-06
PPS NBR - 1-74984-1400
County Name - WILL - -
Code - 197 - -
District - 1 - -
Section Number - 99(1&2)WRS-3

Project Number
IM-055-6/225/265

Route
FAI 55

Item Number	Pay Item Description	Unit of Measure	Quantity	x	Unit Price	=	Total Price
X0324774	SED CON STAB CONST EN	SQ YD	1,867.000				
X0324775	SED CON STAB CON EN M	SQ YD	467.000				
X0325732	CB TA 6 DIA T20 F&G	EACH	9.000				
X0325733	TEMP ASPHALT WEDGE	SQ YD	2,809.000				
X0484300	MEDIAN INLET BOX REM	EACH	9.000				
X4066580	POL HMA SC SMA N80	TON	15,622.000				
X4066685	POL HMA BC SMA N80	TON	12,961.000				
* X4421000	PARTIAL DEPTH PATCH	TON	70.000				
* X4422025	PARTIAL DEPTH REM 2	SQ YD	627.000				
X6020166	DR STR T1 SP 2T20F&G	EACH	2.000				
X6063401	COMB CC&G TM4.12	FOOT	400.000				
X6370940	CONC BAR 2F 42HT	FOOT	11,977.000				
X6700410	ENGR FLD OFF A SPL	CAL MO	18.000				
X6700600	ENGR FIELD LAB SPL	CAL MO	18.000				
X7011015	TR C-PROT EXPRESSWAYS	L SUM	1.000				
X7013820	TR CONT SURVEIL EXPWY	CAL DA	360.000				
Z0001050	AGG SUBGRADE 12	SQ YD	56,385.000				
			* REVISED : JUNE 5, 2007				

ILLINOIS DEPARTMENT OF TRANSPORTATION
SCHEDULE OF PRICES
CONTRACT
NUMBER -

60B47

Page 7
6/5/2007

State Job # - C-91-349-06
PPS NBR - 1-74984-1400
County Name - WILL - -
Code - 197 - -
District - 1 - -
Section Number - 99(1&2)WRS-3

Project Number
IM-055-6/225/265

Route
FAI 55

Item Number	Pay Item Description	Unit of Measure	Quantity	x	Unit Price	=	Total Price
48101600	AGGREGATE SHLDS B 8	SQ YD	3,334.000				
* 50102400	CONC REM	CU YD	132.200				
50104400	CONC HDWL REM	EACH	3.000				
* 50300225	CONC STRUCT	CU YD	33.900				
50300255	CONC SUP-STR	CU YD	25.400				
* 50300260	BR DECK GROOVING	SQ YD	598.000				
* 50300300	PROTECTIVE COAT	SQ YD	3,874.000				
* 50800205	REINF BARS, EPOXY CTD	POUND	6,280.000				
52000320	NEOPRENE EXPAN JT 2	FOOT	43.000				
54213669	PRC FLAR END SEC 24	EACH	3.000				
54214509	PRC FL END S EQ RS 24	EACH	1.000				
54247130	GRATING-C FL END S 24	EACH	3.000				
54248130	GRT-C FL END S EQV 24	EACH	1.000				
55019500	SS 1 RCP CL 4 12	FOOT	2,053.000				
55019600	SS 1 RCP CL 4 15	FOOT	828.000				
			* REVISED : JUNE 5, 2007				

CHAIN LINK FENCE REMOVAL	39
RETROREFLECTIVE SHEETING, NONREFLECTIVE SHEETING, AND TRANSLUCENT OVERLAY FILM FOR HIGHWAY SIGNS	39
ENGINEER'S FIELD OFFICE TYPE A (SPECIAL) AND LABORATORY (SPECIAL)	39
SEEDING, CLASS 4B (MODIFIED).....	41
WEED CONTROL, TEASEL	42
GENERAL REQUIREMENTS FOR WEED CONTROL SPRAYING	43
PROTECTION OF EXISTING DRAINAGE FACILITIES DURING CONSTRUCTION	45
MEDIAN INLET BOX REMOVAL.....	46
REMOVAL OF PRECAST FLARED END SECTION	46
BACKFILLING STORM SEWER UNDER ROADWAY	46
CLEANING EXISTING DRAINAGE STRUCTURES	47
BOX CULVERTS TO BE CLEANED	47
CATCH BASINS, TYPE A, 6' DIAMETER, TYPE 20 FRAME AND GRATES	47
DRAINAGE STRUCTURES, TYPE 1 (SPECIAL) WITH TWO TYPE 20 FRAME AND GRATES	48
DRAINAGE STRUCTURES, TYPE 8' X 3' WITH TWO TYPE 20 FRAME AND GRATES.....	48
WINGWALL REPAIR COMPLETE	48
GUTTER OUTLET REMOVAL.....	48
PERMANENT DITCH CHECKS	49
EROSION AND SEDIMENT CONTROLS	49
EROSION AND SEDIMENT CONTROL CALL OUT	57
EROSION AND SEDIMENT CONTROL SCHEDULE	58
GEOTEXTILE FABRIC MATERIALS.....	58
SURFACE ROUGHENING	59
NATIONAL POLLUTANT DISCHARGE ELIMINATION PERMIT.....	59
GENERAL ELECTRICAL REQUIREMENTS.....	60
GROUND ROD	62
TRENCH AND BACKFILL FOR ELECTRICAL WORK	63
UNIT DUCT	63
WIRE AND CABLE	65
MAINTENANCE OF LIGHTING SYSTEMS.....	66
DISCONNECT SIGN LIGHTING AND REMOVE WIRING TO NEAREST SPLICE.....	70
LIGHTING FOUNDATION REMOVAL.....	70
MATERIAL TRANSFER DEVICE (BDE)	71
MENTOR-PROTÉGÉ PROGRAM (BDE)	72
ALKALI - SILICA REACTION FOR CAST-IN-PLACE CONCRETE (BDE)	72

Revised 06/05/2007

HOT MIX ASPHALT (HMA) LONGITUDINAL JOINT DENSITY MODIFIED (BMPR).....	75
DISADVANTAGED BUSINESS ENTERPRISE PARTICIPATION (BDE)	76
DOWEL BARS (BDE)	83
EPOXY PAVEMENT MARKINGS (BDE).....	84
EROSION AND SEDIMENT CONTROL DEFICIENCY DEDUCTION (BDE)	85
ERRATA FOR THE 2007 STANDARD SPECIFICATIONS (BDE).....	86
HOT-MIX ASPHALT EQUIPMENT, SPREADING AND FINISHING MACHINE (BDE)	87
HOT-MIX ASPHALT - FIELD VOIDS IN THE MINERAL AGGREGATE (BDE)	88
IMPACT ATTENUATORS (BDE)	89
IMPACT ATTENUATORS, TEMPORARY (BDE).....	90
MULTILANE PAVEMENT PATCHING (BDE).....	92
PAYMENTS TO SUBCONTRACTORS (BDE)	92
PLASTIC BLOCKOUTS FOR GUARDRAIL (BDE)	93
PRECAST CONCRETE HANDLING HOLES (BDE)	94
RECLAIMED ASPHALT PAVEMENT (RAP) (BDE)	95
REFLECTIVE CRACK CONTROL TREATMENT (BDE).....	101
REFLECTIVE SHEETING ON CHANNELIZING DEVICES (BDE)	103
REINFORCEMENT BARS (BDE)	104
RETROREFLECTIVE SHEETING, NONREFLECTIVE SHEETING, AND TRANSLUCENT OVERLAY FILM FOR HIGHWAY SIGNS (BDE)	106
SEEDING (BDE)	111
SELF-CONSOLIDATING CONCRETE FOR CAST-IN-PLACE CONSTRUCTION (BDE).....	113
SELF-CONSOLIDATING CONCRETE FOR PRECAST PRODUCTS (BDE).....	117
STEEL PLATE BEAM GUARDRAIL (BDE)	118
SUBCONTRACTOR MOBILIZATION PAYMENTS (BDE)	118
SURFACE TESTING OF PAVEMENTS (BDE)	118
TEMPORARY EROSION CONTROL (BDE)	125
THERMOPLASTIC PAVEMENT MARKINGS (BDE)	125
TRAINING SPECIAL PROVISIONS	126
TYPE ZZ RETROREFLECTIVE SHEETING, NONREFLECTIVE SHEETING, AND TRANSLUCENT OVERLAY FILM FOR HIGHWAY SIGNS (BDE)	129
WATER BLASTER WITH VACUUM RECOVERY (BDE).....	133
CHANGEABLE MESSAGE SIGNS	134
CEMENT (BDE)	136
BITUMINOUS MATERIALS COST ADJUSTMENTS (BDE) (RETURN FORM WITH BID)	138
STEEL COST ADJUSTMENT (BDE) (RETURN FORM WITH BID)	142
STORM WATER POLLUTION PREVENTION PLAN.....	146
ADVANCE WORK PARTIAL DEPTH HOT- MIX ASPHALT PATCHING.....	164

GENERAL ELECTRICAL REQUIREMENTS

Effective: January 1, 2007

Add the following to Article 801 of the Standard Specifications:

"Maintenance transfer and Preconstruction Inspection:

General. Before performing any excavation, removal, or installation work (electrical or otherwise) at the site, the Contractor shall request a maintenance transfer and preconstruction site inspection, to be held in the presence of the Engineer and a representative of the party or parties responsible for maintenance of any lighting and/or traffic control systems which may be affected by the work. The request for the maintenance transfer and preconstruction inspection shall be made no less than seven (7) calendar days prior to the desired inspection date. The maintenance transfer and preconstruction inspection shall:

Establish the procedures for formal transfer of maintenance responsibility required for the construction period.

Establish the approximate location and operating condition of lighting and/or traffic control systems which may be affected by the work

Marking of Existing Cable Systems. The party responsible for maintenance of any existing lighting and/or traffic control systems at the project site will, at the Contractor's request, mark and/or stake, once per location, all underground cable routes owned or maintained by the State. A project may involve multiple "locations" where separated electrical systems are involved (i.e. different controllers). The markings shall be taken to have a horizontal tolerance of at least 304.8 mm (one (1) foot) to either side.. The request for the cable locations and marking shall be made at the same time the request for the maintenance transfer and preconstruction inspection is made. The Contractor shall exercise extreme caution where existing buried cable runs are involved. The markings of existing systems are made strictly for assistance to the Contractor and this does not relieve the Contractor of responsibility for the repair or replacement of any cable run damaged in the course of his work, as specified elsewhere herein. Note that the contractor shall be entitled to only one request for location marking of existing systems and that multiple requests may only be honored at the contractor's expense. No locates will be made after maintenance is transferred, unless it is at the contractor's expense.

Condition of Existing Systems. The Contractor shall conduct an inventory of all existing electrical system equipment within the project limits, which may be affected by the work, making note of any parts which are found broken or missing, defective or malfunctioning. Megger and load readings shall be taken for all existing circuits which will remain in place or be modified. If a circuit is to be taken out in its entirety, then readings do not have to be taken. The inventory and test

Revised 06/05/2007

data shall be reviewed with and approved by the Engineer and a record of the inventory shall be submitted to the Engineer for the record. Without such a record, all systems transferred to the Contractor for maintenance during construction shall be returned at the end of construction in complete, fully operating condition."

Delete Articles 801.11 and 801.12 of the Standard Specifications.

Revise the 6th paragraph of Article 801.05(a) of the Standard Specifications to read:

"Resubmittals. All submitted items reviewed and marked 'APPROVED AS NOTED', or 'DISAPPROVED' are to be resubmitted in their entirety with a disposition of previous comments to verify contract compliance at no additional cost to the state unless otherwise indicated within the submittal comments."

Revise Article 801.11(a) of the Standard Specifications to read:

"Lighting Operation and Maintenance Responsibility. The scope of work shall include the assumption of responsibility for the continuing operation and maintenance the of existing, proposed, temporary, sign and navigation lighting, or other lighting systems and all appurtenances affected by the work as specified elsewhere herein."

Add the following to Section 801.11(a) of the Standard Specifications:

"Energy and Demand Charges. The payment of basic energy and demand charges by the electric utility for existing lighting which remains in service will continue as a responsibility of the Owner, unless otherwise indicated. Unless otherwise indicated or required by the Engineer duplicate lighting systems (such as temporary lighting and proposed new lighting) shall not be operated simultaneously at the Owner's expense and lighting systems shall not be kept in operation during long daytime periods at the Owner's expense. Upon written authorization from the Engineer to place a proposed new lighting system in service, whether the system has passed final acceptance or not, (such as to allow temporary lighting to be removed), the Owner will accept responsibility for energy and demand charges for such lighting, effective the date of authorization. All other energy and demand payments to the utility shall be the responsibility of the Contractor until final acceptance."

Add the following to Section 801 of the Standard Specifications:

"Lighting Cable Identification. Each wire installed shall be identified with its complete circuit number at each termination, splice, junction box or other location where the wire is accessible."

"Lighting Cable Fuse Installation. Standard fuse holders shall be used on non-frangible (non-breakaway) light pole installations and quick-disconnect fuse holders shall be used on frangible (breakaway) light pole installations. Wires shall be carefully stripped only as far as needed for connection to the device."

Revised 06/05/2007

Over-stripping shall be avoided. An oxide inhibiting lubricant shall be applied to the wire for minimum connection resistance before the terminals are crimped-on. Crimping shall be performed in accordance with the fuse holder manufacturer's recommendations. The exposed metal connecting portion of the assembly shall be taped with two half-lapped wraps of electrical tape and then covered by the specified insulating boot. The fuse holder shall be installed such that the fuse side is connected to the pole wire (load side) and the receptacle side of the holder is connected to the line side."

Revise the 2nd and 3rd sentences of the second paragraph of Article 801.02 of the Standard Specifications to read:

"Unless otherwise indicated, materials and equipment shall bear the UL label, or an approved equivalent, whenever such labeling is available for the type of material or equipment being furnished."

GROUND ROD

Effective: January 1, 2007

Description. This item shall consist of furnishing, installing and connecting ground rods for the grounding of service neutral conductors and for supplementing the equipment grounding system via connection at poles or other equipment throughout the system. All materials and work shall be in accordance with Article 250 of the NEC.

Materials. Materials shall be according to the following Articles of Section 1000 - Materials

Item	Article/Section
(a) Grounding Electrodes.....	1087.01(b)
(b) Grounding Electrode Conductors.....	1087.01(a)
(c) Access Well.....	1087.01(c)

CONSTRUCTION REQUIREMENTS

General. All connections to ground rods, structural steel or fencing shall be made with exothermic welds. Where such connections are made to insulated conductors, the connection shall be wrapped with at least 4 layers of electrical tape extended 152.4 mm (six inches) onto the conductor insulation.

Ground rods shall be driven so that the tops of the rod are 609.6 mm (24 inches) below finished grade. Where indicated, ground wells shall be included to permit access to the rod connections.

Where indicated, ground rods shall be installed through concrete foundations.

Where ground conditions, such as rock, preclude the installation of the ground rod, the ground rod may be deleted with the approval of the Engineer.

Revised 06/05/2007

Where a ground field of "made" electrodes is provided, such as at control cabinets, the exact locations of the rods shall be documented by dimensioned drawings as part of the Record Drawings.

Ground rod connection shall be made by exothermic welds. Ground wire for connection to foundation steel or as otherwise indicated shall be stranded uncoated bare copper in accordance the applicable requirements of ASTM Designation B-3 and ASTM Designation B-8 and shall be included in this item. Unless otherwise indicated, the wire shall not be less than No. 2 AWG.

Where connections are made to epoxy coated reinforcing steel, the epoxy coating shall be sufficiently removed to facilitate the exothermic weld.

Method Of Measurement. Ground rods shall be counted, each. Ground wires and connection of ground rods at poles shall be included in this pay item.

Basis Of Payment. This item shall be paid at the contract unit price each for **GROUND ROD**, of the diameter and length indicated which shall be payment in full for the material and work described herein.

TRENCH AND BACKFILL FOR ELECTRICAL WORK

Effective: January 1, 2007

Revise the first sentence of Article 819.03(a) of the Standard Specifications to read:

“Trench. Trenches shall have a minimum depth of 30 in. (760 mm) or as otherwise indicated on the plans, and shall not exceed 12 in. (300 mm) in width without prior approval of the Engineer.”

UNIT DUCT

Effective: January 1, 2007

Revise the second paragraph of Article 816.03(a) to read:

“The unit duct shall be installed at a minimum depth of 760 mm (30-inches) unless otherwise directed by the Engineer.”

Revise Article 1088.01(c) to read:

“(c) Coilable Nonmetallic Conduit.

General:

The duct shall be a plastic duct which is intended for underground use and which can be manufactured and coiled or reeled in continuous transportable lengths and uncoiled for further processing and/or installation without adversely affecting its properties of

Revised 06/05/2007

performance. The duct shall be a plastic duct which is intended for underground use and can be manufactured and coiled or reeled in continuous transportable lengths and uncoiled for further processing and/or installation without adversely affecting its properties of performance.

The duct shall be made of high density polyethylene which shall meet the requirements of ASTM D 2447, for schedule 40. The duct shall be composed of black high density polyethylene meeting the requirements of ASTM D 3350, Class C, Grade P33. The wall thickness shall be in accordance with Table 2 for ASTM D 2447.

The duct shall be UL Listed per 651-B for continuous length HDPE coiled conduit. The duct shall also comply with NEC Article 354.100 and 354.120.

Submittal information shall demonstrate compliance with the details of these requirements.

Dimensions:

Duct dimensions shall conform to the standards listed in ASTM D2447. Submittal information shall demonstrate compliance with these requirements.

Nominal Size		Nominal I.D.		Nominal O.D.		Minimum Wall	
mm	in	mm	in	mm	in	mm	in
31.75	1.25	35.05	1.380	42.16	1.660	3.556 +0.51	0.140 +0.020
38.1	1.50	40.89	1.610	48.26	1.900	3.683 +0.51	0.145 +0.020

Nominal Size		Pulled Tensile	
mm	in	N	lbs
31.75	1.25	3322	747
38.1	1.50	3972	893

Marking:

As specified in NEMA Standard Publication No. TC-7, the duct shall be clearly and durably marked at least every 3.05 meters (10 feet) with the material designation (HDPE for high density polyethylene), nominal size of the duct and the name and/or trademark of the manufacturer.

Performance Tests:

Polyethylene Duct testing procedures and test results shall meet the requirements of UL 651. Certified copies of the test report shall be submitted to the Engineer prior to the installation of the duct. Duct crush test results shall meet or exceed the following requirements:

Duct Diameter		Min. force required to deform sample 50%	
mm	in	N	lbs
35	1.25	4937	1110
41	1.5	4559	1025

Revised 06/05/2007

WIRE AND CABLE

Effective: January 1, 2007

Revise the second sentence of the first paragraph of Article 1066.02(a) to read:

“The cable shall be rated at a minimum of 90°C dry and 75°C wet and shall be suitable for installation in wet and dry locations, and shall be resistant to oils and chemicals.”

Revise the second paragraph of Article 1066.02(b) to read:

“Uncoated conductors shall be according to ASTM B3, ICEA S-95-658/NEMA WC70, and UL Standard 44. Coated conductors shall be according to ASTM B 33, ASTM B 8, ICEA S-95-658/NEMA WC70 and UL Standard 44.”

Revise the third paragraph of Article 1066.02(b) to read:

“All conductors shall be stranded. Stranding meeting ASTM B 8, ICEA S-95-658/NEMA WC70 and UL Standard 44. Uncoated conductors meeting ASTM B 3, ICEA S-95-658/NEMA WC70 and UL Standard 44.”

Revise the first sentence of Article 1066.03(a)(1) to read:

“General. Cable insulation designated as XLP shall incorporate cross-linked polyethylene (XLP) insulation as specified and shall meet or exceed the requirements of ICEA S-95-658, NEMA WC70, U.L. Standard 44.”

Add the following to Article 1066.03(a)(1) of the Standard Specifications:

“The cable shall be rated 600 volts and shall be UL Listed Type RHH/RHW/USE.”

Revise the Aerial Electric Cable Properties table of Article 1066.03(a)(3) to read:

Aerial Electric Cable Properties

Phase Conductor		Messenger wire			
Size AWG	Stranding	Average Insulation Thickness		Minimum Size AWG	Stranding
		mm	mils		
6	7	1.1	(45)	6	6/1
4	7	1.1	(45)	4	6/1
2	7	1.1	(45)	2	6/1
1/0	19	1.5	(60)	1/0	6/1
2/0	19	1.5	(60)	2/0	6/1
3/0	19	1.5	(60)	3/0	6/1
4/0	19	1.5	(60)	4/0	6/1

Revised 06/05/2007

Revise the first paragraph of Article 1066.03(b) to read:

“EPR Insulation. Cable insulation shall incorporate ethylene propylene rubber (EPR) as specified and the insulation shall meet or exceed the requirements of ICEA S-95-658, NEMA Standard Publication No. WC70, and U.L. Standard 44, as applicable.”

Add the following to Article 1066.03(b) of the Standard Specifications:

“Cable sized No. 2 AWG and smaller shall be U.L. listed Type RHH/RHW and may be Type RHH/RHW/USE. Cable sized larger than No. 2 AWG shall be U.L. listed Type RHH/RHW/USE.”

Revise Article 1066.04 to read:

“Aerial Cable Assembly. The aerial cable shall be an assembly of insulated aluminum conductors according to Section 1066.02 and 1066.03. Unless otherwise indicated, the cable assembly shall be composed of three insulated conductors and a steel reinforced bare aluminum conductor (ACSR) to be used as the ground conductor. Unless otherwise indicated, the code word designation of this cable assembly is “Palomino”. The steel reinforced aluminum conductor shall conform to ASTM B-232. The cable shall be assembled according to ANSI/ICEA S-76-474.”

Revise the second paragraph of Article 1066.05 to read:

“The tape shall have reinforced metallic detection capabilities consisting of a woven reinforced polyethylene tape with a metallic core or backing.”

Revise Article 1066.08 to read:

“Electrical Tape. Electrical tape shall be all weather vinyl plastic tape resistant to abrasion, puncture, flame, oil, acids, alkalies, and weathering, conforming to Federal Specification MIL-I-24391, ASTM D1000 and shall be listed under UL 510 Standard. Thickness shall not be less than 0.215 mm (8.5 mils) and width shall not be less than 20 mm (3/4-inch).”

MAINTENANCE OF LIGHTING SYSTEMS

Effective: January 1, 2007

Replace Article 801.11 and 801.12 of the Standard Specifications with the following:

Effective the date the Contractor's activities (electrical or otherwise) at the job site begin, the Contractor shall be responsible for the proper operation and maintenance of all existing and proposed lighting systems which are part of, or which may be affected by the work until final acceptance or as otherwise determined by the Engineer.

Revised 06/05/2007

Before performing any excavation, removal, or installation work (electrical or otherwise) at the site, the Contractor shall initiate a request for a maintenance transfer and preconstruction inspection, as specified elsewhere herein, to be held in the presence of the Engineer and a representative of the party or parties responsible for maintenance of any lighting systems which may be affected by the work. The request for the maintenance preconstruction inspection shall be made no less than seven (7) calendar days prior to the desired inspection date.

Existing lighting systems, when depicted on the plans, are intended only to indicate the general equipment installation of the systems involved and shall not be construed as an exact representation of the field conditions. It remains the Contractor's responsibility to visit the site to confirm and ascertain the exact condition of the electrical equipment and systems to be maintained.

Maintenance of Existing Lighting Systems

Existing lighting systems. Existing lighting systems shall be defined as any lighting system or part of a lighting system in service prior to this contract. The contract drawings indicate the general extent of any existing lighting, but whether indicated or not, it remains the Contractor's responsibility to ascertain the extent of effort required for compliance with these specifications and failure to do so will not be justification for extra payment or reduced responsibilities.

Extent of Maintenance.

Partial Maintenance. Unless otherwise indicated, if the number of circuits affected by the contract is equal to or less than 40% of the total number of circuits in a given controller and the controller is not part of the contract work, the Contractor needs only to maintain the affected circuits. The affected circuits shall be isolated by means of in-line waterproof fuse holders as specified elsewhere and as approved by the Engineer.

Full Maintenance. If the number of circuits affected by the contract is greater than 40% of the total number of circuits in a given controller, or if the controller is modified in any way under the contract work, the Contractor shall maintain the entire controller and all associated circuits.

Maintenance of Proposed Lighting Systems

Proposed Lighting Systems. Proposed lighting systems shall be defined as any lighting system or part of a lighting system which is to be constructed under this contract.

The Contractor shall be fully responsible for maintenance of all items installed under this contract. Maintenance shall include, but not be limited to, any equipment failures or malfunctions as well as equipment damage either by the motoring public, Contractor operations, or other means. The potential cost of replacing or repairing any malfunctioning or damaged equipment shall be included in the bid price of this item and will not be paid for separately.

Revised 06/05/2007

Lighting System Maintenance Operations

The Contractor's responsibility shall include all applicable responsibilities of the Electrical Maintenance Contract, State of Illinois, Department of Transportation, Division of Highways, District One. These responsibilities shall include the maintenance of lighting units (including sign lighting), cable runs and lighting controls. In the case of a pole knockdown or sign light damage caused by normal vehicular traffic, the Contractor shall promptly clear the lighting unit and circuit discontinuity and restore the system to service.

Responsibilities shall also include weekly night-time patrol of the lighting system, with patrol reports filed immediately with the Engineer and with deficiencies corrected within 24 hours of the patrol. Patrol reports shall be presented on standard forms as designated by the Engineer. Uncorrected deficiencies may be designated by the Engineer as necessitating emergency repairs as described elsewhere herein.

The following chart lists the maximum response, service restoration, and permanent repair time the Contractor will be allowed to perform corrective action on specific lighting system equipment.

INCIDENT OR PROBLEM	SERVICE RESPONSE TIME	SERVICE RESTORATION TIME	PERMANENT REPAIR TIME
Control cabinet out	1 hour	4 hours	7 Calendar days
Hanging mast arm	1 hour to clear	na	7 Calendar days
Radio problem	1 hour	4 hours	7 Calendar days
Motorist caused damage or leaning light pole 10 degrees or more	1 hour to clear	4 hours	7 Calendar days
Circuit out – Needs to reset breaker	1 hour	4 hours	na
Circuit out – Cable trouble	1 hour	24 hours	21 Calendar days
Outage of 3 or more successive lights	1 hour	4 hours	na
Outage of 75% of lights on one tower	1 hour	4 hours	na
Outage of light nearest RR crossing approach, Islands and gores	1 hour	4 hours	na
Outage (single or multiple) found on night outage survey or reported to EMC	na	na	7 Calendar days
Navigation light outage	na	na	24 hours

- **Service Response Time** -- amount of time from the initial notification to the Contractor until a patrolman physically arrives at the location.
- **Service Restoration Time** – amount of time from the initial notification to the Contractor until the time the system is fully operational again (In cases of motorist caused damage the undamaged portions of the system are operational.)

Revised 06/05/2007

- **Permanent Repair Time** – amount of time from initial notification to the Contractor until the time permanent repairs are made if the Contractor was required to make temporary repairs to meet the service restoration requirement.

Failure to provide this service will result in liquidated damages of \$500 per day per occurrence. In addition, the Department reserves the right to assign any work not completed within this timeframe to the Electrical Maintenance Contractor. All costs associated to repair this uncompleted work shall be the responsibility of the Contractor. Failure to pay these costs to the Electrical Maintenance Contractor within one month after the incident will result in additional liquidated damages of \$500 per month per occurrence. Unpaid bills will be deducted from the cost of the Contract. Repeated failures and/or a gross failure of maintenance shall result in the State's Electrical Maintenance Contractor being directed to correct all deficiencies and the resulting costs deducted from any monies owed the contractor.

Damage caused by the Contractor's operations shall be repaired at no additional cost to the Contract.

Operation of Lighting

The lighting shall be operational every night, dusk to dawn. Duplicate lighting systems (such as temporary lighting and proposed new lighting) shall not be operated simultaneously. Lighting systems shall not be kept in operation during long daytime periods. The contractor shall demonstrate to the satisfaction of the Engineer that the lighting system is fully operational prior to submitting a pay request. Failure to do so will be grounds for denying the pay request.

Basis of Payment. Maintenance of lighting systems shall be paid for at the contract unit price per calendar month or fraction thereof for **MAINTENANCE OF LIGHTING SYSTEM**, which shall include all work as described herein.

Revised 06/05/2007

ADVANCE WORK PARTIAL DEPTH HOT- MIX ASPHALT PATCHING

Description. This work shall consist of partial depth removal of the existing bituminous concrete pavement overlay and replacement with hot-mix asphalt (HMA). This item shall be used for joint repairs between lanes 1 & 2 and between lane 2 and the outside shoulder.

Materials. Materials shall be according to the following Articles/Sections of the Standard Specifications.

Item	Article/Section
(a) Bituminous Material for Prime Coat.....	406.02
(b) Hot-Mix Asphalt (Note 1)	1030

Note 1. The HMA for partial depth patches shall be Hot Mix Asphalt Surface Course, Mix D, (IL-9.5mm).

Equipment. Equipment shall be according to the following Articles/Sections of the Standard Specifications.

Item	Article/Section
(a) Self-Propelled Milling Machine	1101.16
(b) Concrete Saw	442.03(f)
(c) Wheel Saw.....	442.03(g)
(d) Rollers	442.03
(e) Mechanical Sweeper	1101.03
(f) Air Equipment (Note 1)	

Note 1. The air equipment shall be capable of supplying compressed air at a minimum pressure of 100 psi (690 kPA) and shall have sufficient flow rate to remove all disturbed pavement debris. The equipment shall also be according to ASTM D 4285.

CONSTRUCTION REQUIREMENTS

General. The work must be performed prior to starting stage 1 work during the allowable lane closure hours (before 3rd lane is built) as indicated in the special provision for KEEPING THE EXPRESSWAY OPEN TO TRAFFIC.

Disposal of waste materials shall be according to Article 202.03 of the Standard Specifications.

Partial depth removal of the pavement shall be accomplished by the use of a milling machine and/or the wheel saw. The partial depth patch shall be 2 foot in width by 2 inches in depth unless otherwise directed by the Engineer. Debris from the milling or wheel saw operation shall be removed from the patch area by air equipment or mechanical sweeper and shall remove all disturbed pavement debris and any loose and/or unsound concrete.

Added 06/05/2007

A bituminous prime coat shall be applied according to Article 406.05(b) of the Standard Specifications.

The prepared patch shall be filled with HMA surface course in a single lift. The HMA shall be compacted to the satisfaction of the Engineer.

Patches opened to traffic which are high or become rough by rutting, shoving, or heaving shall be corrected by trimming off high areas and/or filling depressions. Filled areas shall be rolled again.

Method of Measurement. Partial depth removal of the bituminous surface will be measured for payment in place and the area computed in square yards.

HMA for partial depth patching will be measured for payment in tons according to Article 406.13 of the Standard Specifications.

Basis of Payment. Partial depth removal of the bituminous surface will be paid for at the contract unit price per square yard for PARTIAL DEPTH REMOVAL 2".

Partial depth patching will be paid for at the contract unit price per ton for PARTIAL DEPTH PATCHING.

Added 06/05/2007