



WIRING DETAIL
(NO SCALE)

GENERAL NOTES

ALL TAPED SPLICES SHALL USE 2 LAYERS OF ELECTRICAL TAPE OVER 3 LAYERS OF RUBBER TAPE AS REQUIRED BY THE STANDARD SPECIFICATIONS. COAT THE FINISHED TAPED SPLICE WITH BONDING COMPOUND.

ALL CABLE SPLICES SHALL BE TAPED UNLESS ANOTHER METHOD HAS BEEN SPECIFICALLY APPROVED BY THE ENGINEER.

FOR EXAMPLE PURPOSES, THE POLE IS SHOWN ON AN ANCHOR BASE. IF THE POLE IS REQUIRED TO BE SET ON A BREAKWAY BASE, CONSULT THE STANDARD SPECIFICATIONS.

ALL DIMENSIONS ARE IN MILLIMETERS (INCHES) UNLESS OTHERWISE SHOWN.

FILE NAME =	USER NAME = Sleglert	DESIGNED -	REVISED -	STATE OF ILLINOIS DEPARTMENT OF TRANSPORTATION	POLE HANDHOLE WIRING				F.A.U. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
ca:\pw\work\pilot\slg\slg\0203566\05xxx-shd-details.dgn		DRAWN -	REVISED -		8012	21L	SANGAMON	10	9				
PLOT SCALE = 0.0000 ' / in.		CHECKED -	REVISED -		SCALE: SHEET 1 OF 1 SHEETS STA. TO STA.				CONTRACT NO. 72F06				
PLOT DATE = Dec-16-2011 02:57:15PM		DATE -	REVISED -		ILLINOIS FED. AID PROJECT								