

# ADJUSTING SERVICE LINES SCHEDULE

PAY ITEM NUMBER		56500600	60265700	60266600	60266100	56400100		
LOCATION		DOM WAT SER BOX ADJ	VV ADJUST	VALVE BOX ADJ	VV RECONST	FIRE HYDNTS TO BE MVD	COMMENTS	ROW
STATION	OFFSET	EACH	EACH	EACH	EACH	EACH		
59+69.59	11.15' RT	1						EX
271+06.47	56.19' RT			1			HYDRANT AUXILIARY VALVE	PR
271+06.48	57.32' RT					1	REUSE EXISTING HYDRANT	PR
272+33.68	53.55' RT			1			MAIN LINE VALVE	EX
272+38.17	85.38' RT			1			HYDRANT AUXILIARY VALVE	PR
274+40.65	50.21' RT			1			MAIN LINE VALVE	EX
274+93.47	51.40' RT			1			MAIN LINE VALVE	EX
276+88.88	37.35' RT			1			HYDRANT AUXILIARY VALVE	PR
312+44.11	31.09' LT			1		1	REUSE EXISTING HYDRANT	EX
312+46.94	29.07' LT			1			HYDRANT AUXILIARY VALVE	EX
313+00.28	25.37' LT	1						EX
868+85.84	101.64' RT		1					EX
869+70.04	106.67' RT		1					EX
867+91.41	109.19' RT			1			MAIN LINE VALVE	EX
868+03.73	103.71' RT			1			MAIN LINE VALVE	EX
997+97.59	73.33' LT			1			MAIN LINE VALVE	EX
1000+84.38	49.58' LT			1			MAIN LINE VALVE	EX
1009+57.54	61.49' RT				1		MAIN LINE VALVE	EX
1009+62.16	75.82' RT			1			MAIN LINE VALVE	EX
1009+95.41	77.26' RT			1			MAIN LINE VALVE	EX
1019+13.73	30.07' RT			1			MAIN LINE VALVE	EX
1020+37.04	54.63' LT				1			EX
1021+00.09	54.58' LT				1			EX
TOTAL		2	2	14	3	2		EX

PAY ITEM NUMBER		*Z0077002	
LOCATION		WATER MAIN REMOVAL	
STATION	OFFSET	REMOVAL FOOT	COMMENTS
TO	FROM		
268+50	269+75	LT	125
TOTAL		125	EX ROW

PAY ITEM NUMBER		X6022820					
DESC.	STATION	OFFSET	MAN SAN 5 DIA T1F CL	STRUCTURE TYPE	PROP RIM ELEV	INVERT ELEV	COMMENTS
2401	1006+81.43	75.78' RT	1	SANITARY	731.05	717.12	EX ROW

PAY ITEM NUMBER		56400820	X0324449	X0323841	56105000	
LOCATION		FIRE HYD W/AUX V & VB	D I WT MNF MU 8X6 HTEE	WM LINE STOP 8	WATER VALVES 8	COMMENTS
STATION	OFFSET	EACH	EACH	EACH	EACH	
58+02.42	76.49' RT			1		EX ROW
58+22.42	64.54' RT				1	EX ROW
60+73.87	19.00' LT	1				EX ROW
268+88.20	47.50' LT		1			EX ROW
268+88.20	62.00' LT	1				PR ROW
TOTAL		2	1	1	1	

PAY ITEM NUMBER		56100700	
LOCATION		WATER MAIN 8	
STATION	OFFSET	REMOVAL FOOT	COMMENTS
TO	FROM		
268+50	269+75	LT	125
TOTAL		125	PVC/ EX ROW

PAY ITEM NUMBER		*56400810	
LOCATION		FIRE HYDRANT EXTEN	
STATION	OFFSET	FOOT	COMMENTS
271+06.48	RT	10	PR ROW
312+44.11	LT	10	EX ROW
TOTAL		20	

PAY ITEM NUMBER			X6026050	X6026051					
DESC.	STATION	OFFSET	SANITARY MANHOLE ADJ	SAN MAN RECONST	STRUCTURE TYPE	EX RIM ELEV	PROP RIM ELEV	PROP INVERT	COMMENTS
			EACH	EACH					
A7	998+86.36	31.89' RT	1		SANITARY	732.49	732.31	N/A	EX ROW
A8	997+77.16	58.97' LT	1		SANITARY	732.63	732.65	N/A	EX ROW
A9	1001+22.07	33.86' RT	1		SANITARY	732.99	733.32	N/A	EX ROW
A12	1010+77.44	47.96' RT	1		SANITARY	733.80	734.86	N/A	EX ROW
A13	1014+79.11	23.48' RT		1	SANITARY	735.16	736.65	N/A	EX ROW
A15	1018+93.78	21.09' RT		1	SANITARY	735.74	737.94	N/A	EX ROW
A16	1019+93.91	59.66' RT	1		SANITARY	735.82	735.73	N/A	EX ROW
A17	268+31.05	50.06' RT	1		SANITARY	735.27	735.70	N/A	EX ROW
A18	265+94.00	47.52' RT	1		SANITARY	735.61	736.19	N/A	EX ROW
A22	1024+60.56	61.03' RT		1	SANITARY	735.32	736.66	N/A	EX ROW
A23	866+17.94	109.07' RT	1		SANITARY	726.79	726.34	N/A	EX ROW
TOTAL			8	3					

PAY ITEM NUMBER		56400500	56500700	
LOCATION		FIRE HYDNTS TO BE REM	DOM WAT SER BOX REM	COMMENTS
STATION	OFFSET	EACH	EACH	
60+73.87	9.17' LT	1		EX ROW
269+40.94	102.32' LT	1		EX ROW
990+00.00	12.00' LT		1	EX ROW
990+00.00	17.00' LT		1	EX ROW
990+00.00	22.00' LT		1	EX ROW
TOTAL		2	3	

PAY ITEM NUMBER			60500070	
DESC.	STATION	OFFSET	REMOV MAN- MAIN FLOW	STRUCTURE TYPE
			EACH	
2400	1008+41.80	55.13' RT	1	SANITARY

**PAYMENT NOTE:**  
 WATER MODIFICATIONS WITHIN THE EXISTING ROW WILL BE PAID FOR BY THE NORTH PARK PUBLIC WATER DISTRICT (NPPWD).  
 SANITARY MODIFICATIONS WITHIN THE EXISTING ROW WILL BE PAID FOR BY THE ROCK RIVER WATER RECLAMATION DISTRICT (RRWRD).  
 WATER AND SANITARY MODIFICATIONS WITHIN THE PROPOSED ROW WILL BE PAID FOR AS ROADWAY FEDERAL/STATE.

**REMOVAL NOTE:**  
 MANHOLE 2400 IS TO BE COMPLETELY REMOVED AND FLOW IS TO BE MAINTAINED BY BYPASS PUMPING WHILE THIS OPERATION OCCURS, CONTRACTOR TO ASSUME A FLOW OF 1.6 MGD FOR BYPASS PUMPING. RECONNECT PIPES WITH 10' MINIMUM OF 21" PVC SDR 35 PIPE. CONNECTION TO THE EXISTING RCP PIPE REQUIRES 2 FERNCO COUPLINGS. THE NEW PIPE SHALL BE INSTALLED SO THAT THE FLOWLINES MATCH THE EXISTING RCP PIPE. THE CONTRACTOR WILL CONTACT TERRY STOLL, (815) 543-7983, AT LEAST 48 HOURS BEFORE BEGINNING THE WORK. THE BYPASS PUMPING, NEW PVC PIPE, COUPLINGS, AND ALL OTHER MATERIALS AND WORK NECESSARY TO COMPLETE MANHOLE REMOVAL SHALL NOT BE PAID SEPARATELY BUT WILL BE INCLUDED IN THE COST OF REMOVING MANHOLES TO MAINTAIN FLOW.