



DATE: \_\_\_\_\_  
 BY: \_\_\_\_\_  
 CHECKED: \_\_\_\_\_  
 PLOTTED: \_\_\_\_\_  
 ALIGNED: \_\_\_\_\_  
 NOTE BOOK NO.: \_\_\_\_\_  
 CAD FILE NAME: \_\_\_\_\_

DATE: \_\_\_\_\_  
 BY: \_\_\_\_\_  
 CHECKED: \_\_\_\_\_  
 PLOTTED: \_\_\_\_\_  
 ALIGNED: \_\_\_\_\_  
 NOTE BOOK NO.: \_\_\_\_\_  
 CAD FILE NAME: \_\_\_\_\_

④  
 Boring No./Sample No.: EB-07/6  
 Depth: 11.0' - 13.0'  
 Soil Classification: SAND & GRAVEL A-1-b  
 Group Index: 0  
 % Gravel (AASHTO T-311): 31.9  
 % Sand (AASHTO T-311): 52.2  
 % Silt/Clay (AASHTO T-311): 15.9  
 Cu: -  
 Cc: -  
 Plasticity Index: NP

⑤  
 Boring No./Sample No.: EB-08/10  
 Depth: 21.0' - 23.0'  
 Soil Classification: SILTY CLAY A-7  
 Group Index: 55  
 % Gravel (AASHTO T-88): 0.0  
 % Sand (AASHTO T-88): 2.4  
 % Silt (AASHTO T-88): 50.0  
 % Clay (AASHTO T-88): 47.6  
 Liquid Limit: 66  
 Plastic Limit: 15  
 Plasticity Index: 51

⑥  
 Boring No./Sample No.: EB-09/25  
 Depth: 58.5' - 60.0'  
 Soil Classification: SAND A-3  
 Group Index: 1  
 % Gravel (AASHTO T-311): 0.0  
 % Sand (AASHTO T-311): 89.9  
 % Silt/Clay (AASHTO T-311): 10.1  
 Cu: 2.9  
 Cc: 1.02  
 Plasticity Index: NP