

STATE OF ILLINOIS
DEPARTMENT OF TRANSPORTATION

DESIGN SPECIFICATIONS

2002 A.A.S.H.T.O. Specifications & Supplements

DESIGN STRESSES

Precast Units
f_y = 60,000 psi
f'c = 5,000 psi (Precast)

Field Units
f_y = 60,000 psi (Reinforcement)
f'c = 50,000 psi (AASHTO M270 Gr. 50)

TOTAL BILL OF MATERIALS

DESCRIPTION	UNIT	QTY.
Structure Excavation	Cu. Yd.	291.3
Name Plates	Each	1
Pipe Underdrains for Structures 4"	Foot	349
Concrete Gutter, Type A (Modified)	Foot	349
Furnishing Soldier Piles (HP Section)	Foot	649
Geocomposite Wall Drain	Sq. Yd.	299
Drilling & Setting Soldier Piles (In Soil)	Cu. Ft.	491
Drilling & Setting Soldier Piles (In Rock)	Cu. Ft.	1099
Retaining Wall (Special)	Sq. Ft.	3170
Staining Concrete Structures	Sq. Yd.	292

GENERAL NOTES

Reinforcement Bars shall conform to the requirements of ASTM A706 Gr 60. See Special Provisions.
Reinforcement bars designated (E) shall be epoxy coated.

Concrete shall be painted in accordance with special provisions. The color shall be selected by the engineer.

Exposed steel pile shall be painted with an inorganic zinc rich primer/ acrylic/acrylic paint system for shop and field painting except for portions located more than 4 feet below the finished grade at the front face of the wall. The finished coat shall be only applied to the exposed surfaces of the steel piles after the concrete panels have been installed. The color of the final finish coat shall be approved by the Resident Engineer and Project Engineer. See special provisions for Cleaning and Painting New Metal Structures.

After placement of bottom precast panel, fill must be placed equally on both sides in order to continue construction of wall and place additional panels. Backfill at front face of wall must be at finished grade.

All form liners required for the precast concrete panels are included in the pay item "Retaining Wall (Special)".

Installation of the name plate shall be in accordance with Highway Standard 515001-03 and Article 515 of the Standard Specifications. The location of the name plate to be determined by the Resident Engineer.

Method used for cutting piles to their final length shall result in a smooth and neat appearance. Jagged edges shall not be acceptable.

LEFT STATION 1032+10 TO 1035+60
BUILT 20__ BY
STATE OF ILLINOIS
F.A.P. RTE. 742 SEC. 37R-4
STRUCTURE NO. 071-7006

NAME PLATE
See Std. 515001

GENERAL NOTES & TOTAL BILL OF MATERIALS
STRUCTURE NO. 071-7006

DESIGNED CTH
CHECKED DFM
DRAWN CTH
CHECKED DFM

SHEET NO. 3	F.A.P. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
11 SHEETS	742	37R-4	OGLE	867	256
			CONTRACT NO. 64E17		
FED. ROAD DIST. NO. 7		ILLINOIS	FED. AID PROJECT		