



#6AWG UD=UNIT DUCT, 600V, 2-1C NO.6, 1/C NO.6 GROUND, (XLP-TYPE USE), 1" DIA. POLYETHYLENE AND ELECTRIC CABLE IN CONDUIT, 600V (XLP-TYPE USE) 3-1/C NO. 6

#4AWG UD=UNIT DUCT, 600V, 2-1C NO.4, 1/C NO.4 GROUND, (XLP-TYPE USE), 1" DIA. POLYETHYLENE

#2AWG UD=UNIT DUCT, 600V, 2-1C NO.2, 1/C NO.2 GROUND, (XLP-TYPE USE), 1 1/4" DIA.POLYETHYLENE

----- EXISTING
 _____ PROPOSED

FILE NAME =	USER NAME = prestonme	DESIGNED - - - -	REVISED - - - -	STATE OF ILLINOIS DEPARTMENT OF TRANSPORTATION	WIRING DIAGRAM 6 OF 9	F.A.I. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
c:\pwwork\pwwork\prestonme\dms65337\d876099-shr-light.dgn	DRAWN - - - -	REVISED - - - -	255			DIST. 8 LIGHT POLE 2009-			146	143
PLOT SCALE = 50.0000' / IN.	CHECKED - - - -	REVISED - - - -	CONTRACT NO. 16C09							
PLOT DATE = 5/5/2010	DATE - - - - -	REVISED - - - -	MADISON, MONROE & ST. CLAIR							
SCALE: _____ SHEET NO. ___ OF ___ SHEETS STA. _____ TO STA. _____						FED. ROAD DIST. NO. - ILLINOIS FED. AID PROJECT				