



- NOTE:**
- SEE DRAWING RL-01 FOR ELECTRICAL SYMBOLS, ABBREVIATIONS AND GENERAL NOTES.
 - FINAL LOCATIONS OF THE TEMPORARY LIGHTING UNITS AND WOOD POLES TO BE DETERMINED IN THE FIELD BY THE ENGINEER.
 - EXISTING LUMINAIRES OPERATE ON 240V (PHASE TO PHASE)
 - SETBACK SHALL BE MEASURED AS THE DISTANCE FROM THE EDGE OF EXISTING PAVEMENT TO THE CENTER OF THE POLE.

FILE NAME = *FILES*	USER NAME = *USER*	DESIGNED - WDS	REVISED - 4/25/2014 WDS	STATE OF ILLINOIS DEPARTMENT OF TRANSPORTATION	EXISTING/TEMPORARY LIGHTING AND DEMOLITION PLAN U.S. RTE 20 (SOUTH JUNCTION)			F.A.P. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.	
		DRAWN - HA	REVISED -		SCALE: 1"=50'	SHEET 2	OF 2 SHEETS	STA.	TO STA.	345	106-S-N-2	KANE	147 94
		CHECKED - WDS	REVISED -		CONTRACT NO. 60T09								
		DATE - 3/28/2014	REVISED -		ILLINOIS FED. AID PROJECT								