

SECONDARY CABLE EXTENSION WITH L-823 PLUG TYPE II, CLASS A, STYLE 1 AND L-823 RECEPTACLE, TYPE II, CLASS A, STYLE 8, TO L-867B 24" DEEP BASE CAN.

NOTE: ALL BOLTS SHALL BE TREATED WITH "NEVERSEEZ" OR EQUAL


12" HIGH PLASTIC TRANS. SUPPORT

FRONT VIEW

SIDE VIEW

NOTES

- MANDATORY = L-858R  
LOCATION = L-858L  
DIRECTION = L-858Y  
ALL SIGNS SHALL BE INCANDESCENT
- SIGN LENGTHS GIVEN ON THE SCHEDULE ARE NOMINAL, ACTUAL LENGTHS PER F.A.A. REQUIREMENT. ALL LENGTHS SHALL BE VERIFIED WITH THE SIGN MANUFACTURER BY THE CONTRACTOR.
- ALL TAXIWAY SIGNS TO BE SIZE 3, STYLE 5, CLASS 2, MODE 1.
- A YELLOW AND BLACK FRANGIBLE, RETROREFLECTIVE BARRIER SHALL BE INSTALLED. SIGN SHALL BE INTERNALLY ILLUMINATED.
- ALL BASE CANS, CONDUITS, REINFORCING, CONCRETE, ETC. SHOWN ARE INSTALLED UNDER ANOTHER CONTRACT UNLESS OTHERWISE INDICATED.
- SIGNS 32, 39, 50, AND 60 SHALL BE SIZE 3, STYLE 2, CLASS 2, MODE 1.
- EXISTING SIGNS ARE CROUSE-HINDS. REPLACEMENT SIGN PANELS SHALL BE COMPATIBLE.



ELECTRICAL CONNECTION DETAIL  
NTS

TAXIWAY GUIDANCE SIGN DETAIL  
N.T.S.

REVISIONS		
NUMBER	BY	DATE



**MIDAMERICA ST. LOUIS AIRPORT  
ST. CLAIR COUNTY, ILLINOIS**  
  
**AIRFIELD LIGHTING IMPROVEMENTS**

ONE MEMORIAL DRIVE, SUITE 500  
 ST. LOUIS, MO 63102  
 (314) 436-5500  
  
**GMT**  
 CRAWFORD, MURPHY & TILLY, INC.  
 CONSULTING ENGINEERS  
 © Copyright GMT, Inc.  
 PROFESSIONAL ENGINEERING - 184-00613

**IL PROJECT, BLV-4405  
AIP PROJECT, 3-17-SBGP-XX**

FILE: 33-36\_ELECTRICAL\_DETAILS.dwg  
 DESIGN BY: ASF  
 DRAWN BY: ASF  
 CHECKED BY: MJD/CET  
 APPROVED BY: BWG  
 DATE: JUNE 27, 2014  
 JOB No: 13098-02

**ELECTRICAL  
DETAILS 3**  
  
 SHEET 32 OF 35 SHEETS