



CONDITION 2-WITHOUT GUTTER  
 HELIX FOUNDATION

UNIT DUCT WITH CONDUCTORS AS INDICATED ON PLANS. ON MULTIPLE DUCT RUNS MAINTAIN 6" SPACE BETWEEN UNIT DUCTS. (TYP.)

CONDITION 2-WITHOUT GUTTER  
 CONCRETE FOUNDATION

UNIT DUCT WITH CONDUCTORS AS INDICATED ON PLANS. ON MULTIPLE DUCT RUNS MAINTAIN 6" SPACE BETWEEN UNIT DUCTS. (TYP.)

APPROVED: *Paul Kovacs*  
 DATE 2-7-2012

NOTE:  
 SEE SHEET 1 OF THIS SERIES FOR NOTES.

SHEET 5 OF 6

**Illinois Tollway**  
 Open Roads for a Brighter Future

LIGHT STANDARD FOUNDATION

STANDARD H1-01

s:\projects\2012\11-173 - bba\proj\set\work\disciplines\electrical\sheet\11173-11173-11173.dwg

**EJM ENGINEERING, INC.**  
 411 South Wells Street Suite 1000  
 Chicago, Illinois 60607

FILE NAME	USER NAME = rsonson	DESIGNED - RAS	REVISED -
		DRAWN - BHH	REVISED -
		CHECKED - MKR	REVISED -
		DATE - 6/19/2012	REVISED -

STATE OF ILLINOIS  
 DEPARTMENT OF TRANSPORTATION

TOLLWAY STANDARD DRAWINGS

SCALE: NONE SHEET NO. 50 OF 53 SHEETS STA. TO STA.

F.A. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
94	49-1-R-1	LAKE	677	410
CONTRACT NO. 60L77				
ILLINOIS FED. AID PROJECT				