

VERIFIED UTILITY INFORMATION

Table with 8 columns: TEST HOLE #, SIZE & TYPE, NORTHING, EASTING, TOP OF UTILITY, EXISTING CUT, REFERENCE GROUND ELEVATION, COMMENTS. Rows 53-60, 61 (Man Hole), 62-77.

VERIFIED UTILITY INFORMATION

Table with 8 columns: TEST HOLE #, SIZE & TYPE, NORTHING, EASTING, TOP OF UTILITY, EXISTING CUT, REFERENCE GROUND ELEVATION, COMMENTS. Rows 78-109.

TBE Project Information

* Size given is duct width only. TH#54 TBE could not reach utility due to depth, Clearance given. MH#61 Man Hole elevation to top of phone cables exiting man hole. TH#80 Could not expose utilities due to extremely hard clay. Clearance depth of 7.88' given. TH#81 Appears to be a 34" poured in place concrete cap over CTA conduit. TH#87 found a 16" pipe but was unable to see it due to water table. Probed another 3' down past pipe, unable to find 36" w/m electronic Depth 24' TH#89 Utility not exposed due to excessive water in hole. TH#90 Utility not exposed, clearance depth of 13.65'. TH#96 Utility not exposed, clearance depth of 10.80'. TH#97 Reference point destroyed by construction crews before survey could be completed. Material was unidentifiable. TH#104 Concrete cap poured over utility. TH#107 Utility not exposed, clearance depth of 16.79'.

ALL INFORMATION SHOWN WAS OBTAINED FROM A LOCATION SURVEY.

Illinois Department of Transportation

I-90 /94 (NB & SB of Dan Ryan Expressway) Chicago-Cook County Sec No: (2122-921 PT1) R, (2021-922 PT1,2) Contract No. 62586, 62589, 62693, 62694, 62695 TBE Project No.: IL09500164, 167, 168, 170, 171, 179, 180, 182, 204, 205, 206, 211, 212, 219, 221, 225, 226, 227, 228, 230, 232

Table with 12 columns: DATE, BY, DESCRIPTION, DATE, BY, DESCRIPTION, DATE, BY, DESCRIPTION, DATE, BY, DESCRIPTION. Row 1: 6-15-05, KLC, REMOVE QL "A" FROM TH#87 & 89.

J. Johnson E-9802



TBE GROUP, INC. SOUTHERN REGION: FL, GA, SC, NC NORTHERN REGION: IL, IN, MI, OH, MO, WI, NY PA, VA, CANADA WESTERN REGION: AZ, NV, NM, TX, CA, OR, UT, WA

VERIFIED UTILITY LOCATIONS