



**NOTES:**

1. INSTALL IN EXISTING 2" CONDUIT 1 EA POWER AND CONTROL CABLE TYPE TC. SEE WIRING DIAGRAM SHEET 8.
2. INSTALL IN EXISTING 2" CONDUIT 2 EA POWER AND CONTROL CABLE TYPE TC. SEE WIRING DIAGRAM SHEET 8.
3. EXTEND 2" CONDUIT TO NEW CONTROL PANEL LOCATION.



**RICHARD W. HASSMAN**  
#30973  
REGISTERED  
PROFESSIONAL  
ENGINEER  
OF  
ILLINOIS

*Exp 11/30/05*



REV.	DATE	BY	APPR.	DESCRIPTION	PLOT FILE	REV.	DATE	BY	APPR.	DESCRIPTION	PLOT FILE	DATE:
												6/10/05

DESIGNED BY: RWH  
DRAWN BY: CS  
CHECKED BY: RWH



ACTIVATE GLYCOL  
COLLECTION SYSTEM

1075 Eastgate Drive  
O'Fallon, Illinois 62269  
PH 618-624-2525  
FAX 618-624-2730



**ELECTRICAL SITE PLAN**

DWG. FILE NAME  
84723-E-09

SHEET NO.  
9