



NOTES:

1. THE CONTRACTOR SHALL VERIFY IN THE FIELD THE CONNECTIONS AND WIRING OF ALL EXISTING LIGHT POLES TO BE REMOVED.
2. THE TEMPORARY LIGHTING SYSTEM MUST BE INSTALLED AND FULLY OPERATIONAL BEFORE ANY EXISTING LIGHTING UNITS ARE DISCONNECTED OR REMOVED.
3. ANY LIGHTING UNIT TO BE REMOVED SHALL BE DISCONNECTED AT THE CONTROLLER FIRST. THE CONTRACTOR SHALL VERIFY THAT ANY WIRING THAT IS DISCONNECTED DOES NOT ADVERSELY AFFECT ANY EXISTING LIGHTING EQUIPMENT THAT IS TO REMAIN IN PLACE AND OPERATIONAL.
4. ALL REMOVED LIGHTING UNITS AND LIGHTING CONTROLLER SHALL BE DELIVERED TO THE CITY OF ELGIN, PUBLIC WORKS DEPARTMENT.

AARON NEAL, TRAFFIC CREW LEADER
 CITY OF ELGIN, PUBLIC WORKS DEPT.
 TRAFFIC DIVISION
 1900 HOLMES ROAD
 ELGIN, IL 60123
 (847)931-6099

EXISTING LIGHTING
 CONTROLLER TO BE
 REMOVED, 120/240V
 EXISTING SERVICE

GA GANDHI AND ASSOCIATES, INC.
 ENGINEERS AND PLANNERS
 6035 N. NORTHWEST HIGHWAY
 SUITE 306
 CHICAGO, ILLINOIS 60631 TEL. (773)774-5910

FILE NAME =	USER NAME = .GAI.	DESIGNED - PKG	REVISED -
#FILE#		DRAWN - MAA, SHM	REVISED -
	PLOT SCALE = #SCALE#	CHECKED - PKG	REVISED -
	PLOT DATE = 5/12/2011	DATE - 05/18/2011	REVISED -

**STATE OF ILLINOIS
 DEPARTMENT OF TRANSPORTATION**

**LIGHTING REMOVAL PLAN
 (SHEET 1 OF 2)**

SCALE: 1"= 50' SHEET NO. OF SHEETS STA. TO STA.

F.A.P. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
345	BR-HB-2-BY-1	KANE	434	233
CONTRACT NO. 60K90				
FED. ROAD DIST. NO. 1 ILLINOIS FED. AID PROJECT				

MATCH LINE STA. 104+00
 (SEE SHEET 2 OF 2)