

SEQUENCE OF CONSTRUCTION:

- 1. CLOSE EXISTING VALVE.
- 2. REMOVE EXISTING HYDRANT.
- 3. INSTALL HYDRANT EXTENSION AND NEW VALVE.
- 4. RELOCATE EXISTING HYDRANT.
- 5. OPEN EXISTING VALVE, REMOVE BOX.
- 6. BACKFILL.
- 7. FLUSH AND TEST FOR CHLORIDE RESIDUAL AND PROVIDE TEST.

ALL WORK TO BE DONE IN ACCORDANCE WITH ARTICLE 564 OF THE STANDARD SPECIFICATIONS. NEW VALVE AND BOX SHALL BE SAME MAKE AND MODEL AS EXISTING.

FIRE HYDRANT TO BE MOVED

ALL DIMENSIONS ARE IN INCHES (MILLIMETERS) UNLESS

FILE NAME : v:\2791\IDOT1COMBINED.pdf	USER NAME = gaglianobt	DESIGNED -	REVISED - R. SHAH 09-09-94		FIRE HYDRANT TO BE MOVED					F.A.U. RTE.	SECTION	COUNTY	TOTAL SHEET SHEETS NO.	
		DRAWN -	REVISED - R. SHAH 10-25-94	STATE OF ILLINOIS								94-00302-00-FP	DU PAGE	240 165
	PLOT SCALE = 50.0000 '/ IN.	CHECKED -	REVISED -	DEPARTMENT OF TRANSPORTATION								BD-36	CONTRACT NO. 63609	
	PLOT DATE = 1/4/2008	DATE -	REVISED -		SCALE: NONE	SHEET NO. 1 O	F 1 SHEE	ETS	STA.	TO STA.	FED. ROA	D DIST. NO. 1 ILLINOIS FED.		