


**1** SPLITFITTER LUMINAIRE KEEPER PHYSICAL INSTALLATION DETAIL  
NOT TO SCALE

- NOTES:
1. THE LUMINAIRE SAFETY CABLE ASSEMBLY SHALL BE FURNISHED AND INSTALLED BY THE CONTRACTOR, AND SHALL BE INCIDENTAL TO THE CONTRACT.
  2. CONTRACTOR SHALL ADJUST THE WIRE CLIP TO ELIMINATE ANY SLACK FROM THE WIRE ROPE.
  3. THE 3/16" NYLON JACKETED STAINLESS STEEL AIRCRAFT CABLE SHALL REMAIN VISIBLE FROM THE GROUND LEVEL.
  4. THE BREAKING STRENGTH OF THE CABLE SHALL BE 2000 lbs. MIN.




**3** SPLICING ELECTRIC CABLES  
BASIC MATERIALS AND METHODS  
NOT TO SCALE



REVISIONS	
NAME	DATE
ADDENDUM 1 - NEW SHEET	8/28/08

INTERSECTION IMPROVEMENT  
WASHINGTON STREET - 75th STREET  
ELECTRICAL DETAILS  
SHEET 4 OF 4

CONSULTANT  
**TYLIN INTERNATIONAL**

City of  **Naperville**

DRAWN: JRH	SHEET NO.
CHECKED: FO	
APPROVED: DEM	
DATE: 04/11/08	
SCALE:	
JOB NO.: P-91-494-00	PROJECT NO.: CMM-7003 (983)

C:\DRAWING\PROJECTS\91494\91494-00-PV.dwg 8/28/08 10:05 AM