


F.A.P. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
326	(111CS) W&RS-21	GRUNDY	85	85-P
STA.		TO STA.		
FED. ROAD DIST. NO.		ILLINOIS FED. AID PROJECT		



The Subsurface Utility Engineering Company
449 Marrow Falls Road
Tallmadge, OH 44278
(330) 794-4455

So-Deep Test Hole Certification Form

© So-Deep 1988, 1991

So-Deep, Corporate Office
8397 Euclid Avenue
Manassas Park, VA 20111
(703)361-6005

Contract # 98.0455
Test Hole # 528
Plan Scale 1"=20'
Sheet # 3
Proposed GRADE CHANGE
Date JULY 18, 2008

City, County, State CITY OF MORRIS, IL
Gen. Loc. DIVISION ST SOUTH OF CHAPIN ST
Recorded Size/Material/Type 8-WAY UNK. TYPE (AT&T) TELE DUCT
Foreman/Trucker/Form By J. CLINE / 219 / P. REYNOLDS

Condition of paving prior to work
NO PAVING

B.M. 1 Elev. = 528.70' Description: (BM #109) TOP OF SURVEY NAIL FOUND, @ STA. 28+19.6, DIVISION ST.
is GIVEN

B.M. 2 Elev. = 528.89' Description: (BM #104) CMS "C" FOUND NE CAP BOLT OF P.H., 41'2" RT OF STA. 21+33.2, DIVISION ST.
is GIVEN

SO-DEEP will attempt to use the SMITH test applicable to your design. If however, SMs differ by more than .05', resulting differences could cause design conflicts.

Benchmarks check BY 8&F
Elevations are referenced to B.M.#2

Recorded Size/Type of utility WAS FOUND

There WERE additional utilities in the test hole

The utility WAS in good condition.

Paving Thickness and type NO PAVING

Color of ribbon installed ORANGE

Soil Type MOIST SAND


Field Condition GRASS R/W

T.H. tied to PEG

"(2) 4 1/2" PLA (AT&T) TELE. CONDUITS 1.18" H.
Size/Material/Type
Portion of pipe exposed for D.D. measurement:
OTHER (SEE REMARKS)

Remarks: "ALSO FOUND IN TEST HOLE A 1.18" H PRE-CAST CONCRETE (AT&T) TELE DUCT, (2) 4 1/2" TRANSMITTE (AT&T) TELE CONDUITS. RR #4 WAS TAKEN ON THE SOUTHERN MOST EDGE OF THE TELEPHONE VAULT. TELE DUCT CONTAINS FIBER OPTICS AT THIS LOCATION.

PREPARED WITHOUT AT&T RECORDS. WE ACCEPT NO LIABILITY FOR FACILITIES OTHER THAN THOSE DEPICTED ON THIS CERTIFICATION FORM.



TH DUG 30.4'2" RT OF CL STA 23+71.24, ILL. RTE. 47

- R/W = Right of Way
- M.S. = Not to Scale
- W = Not Shown on Plan
- P.C. = Precast Concrete
- CONC. = Concrete
- O.D. = Outside Diameter
- C.I. = Cast Iron
- D.I. = Ductile Iron
- M.P. = Rough Pipe Concrete
- CL = Centeline

- T.C. = Terra Cotta
- P.P.S. = Plastic
- BL = Brass Line
- ELCC = Electric
- TELE = Telephone
- T.H. = Test Hole
- SH = Sewer
- DW = Driveway
- SM = Sewer Manhole
- C.B. = Catch Basin
- GV = Gas Valve

Performing out-of-sight work...with vision™
Note: To eliminate mistakes and check this work, SO-DEEP suggests you audit and plot all dimensions onto the plans and review all elevations carefully. SO-DEEP is responsible only for information shown on our forms.

- 08" - 1"
- 16" - 2"
- 20" - 2"
- 24" - 2"
- 30" - 2"
- 36" - 2"
- 42" - 2"
- 48" - 2"
- 54" - 2"
- 60" - 2"
- 66" - 2"
- 72" - 2"
- 78" - 2"
- 84" - 2"
- 90" - 2"

- Sewer Manhole
- Test Hole
- Fire Hydrant
- Pole
- Electric Manhole
- T.S. = Tension Station
- Valve
- Water Meter
- Telephone Manhole
- Telephone Pedestal

REVISIONS	
NAME	DATE

ILLINOIS DEPARTMENT OF TRANSPORTATION

SUBSURFACE UTILITY
ENGINEERING
TEST HOLES

SCALE: NONE
DATE: 09/2007

DRAWN BY: KIH
CHECKED BY: FML