



WIRING DETAIL
NO SCALE

GENERAL NOTES

All taped splices shall use 2 layers of electrical tape over 3 layers of rubber tape as required by the Standard Specifications. Coat the finished taped splice with bonding compound.

All cable splices shall be taped unless another method has been specifically approved by the Engineer.

For example purposes the pole is shown on an anchor base. If the pole is required to be set on a breakaway base, consult the Standard Specifications.

FILE NAME =	USER NAME = \$USER\$	DESIGNED - VG	REVISED -	STATE OF ILLINOIS DEPARTMENT OF TRANSPORTATION	POLE HANDHOLE WIRING, FAI ROUTE 57/70			F.A.I. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
S:\Projects\403-00072-57-70\dgn\W Tr\LV\lighting_detail.dgn		DRAWN - PDB	REVISED -					57/70	(25-4R)	EFFINGHAM	1760	479
PLOT SCALE = \$SCALE\$		CHECKED - BRM	REVISED -		SCALE:			SHEET NO. 32 OF 35 SHEETS		STA.	TO STA.	
PLOT DATE = \$DATE\$		DATE - 10-30-12	REVISED -					FED. ROAD DIST. NO.	ILLINOIS FED. AID PROJECT	CONTRACT NO. 74295		