

MUNICIPALITY	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
QUINCY	06-00300-00-LS	ADAMS	69	23

CIRCUIT X - 240 VOLT	PVC CONDUIT 2" IN TRENCH	PVC CONDUIT 2" AUGERED	USE EXISTING CONDUIT	EL CABLE 4 WIRES #8 - 1C	ORNAMENTAL LIGHT POLE	150 WATT HPS LUMINAIRE	EL CABLE 5 WIRES #12 - 1C	CONCRETE FOUNDATION	JUNCTION BOX	TRENCH & BACKFILL
PEDESTRIAN MALL - MAINE - 6TH TO 7TH - SOUTH SIDE	FOOT	FOOT		FOOT	EACH	EACH	FOOT	FOOT	EACH	FOOT
SERVICE BOX E IN PEDESTRIAN WALKWAY										
SOUTH SIDE OF MAINE - 6TH TO 7TH										
TO HH 27				28						
HH 27 TO JB 78	14			56						14
JB 78				6					1	
JB 78 TO LIGHT 78	5			20						5
LIGHT 78				12	1	1	85	3		
JB 78 TO JB 79	49			196						49
JB 79				6					1	
JB 79 TO LIGHT 79	5			20						5
LIGHT 79				12	1	1	85	3		
JB 79 TO JB 80	49			196						49
JB 80				6					1	
JB 80 TO LIGHT 80	14			56						14
LIGHT 80				12	1	1	85	3		
JB 80 TO JB 81	49			196						49
JB 81				6					1	
JB 81 TO LIGHT 81	5			20						5
LIGHT 81				12	1	1	85	3		
TOTALS	190			860	4	4	340	12	4	190

CIRCUIT XI - 240 VOLT	PVC CONDUIT 2" IN TRENCH	PVC CONDUIT 2" AUGERED	USE CIRCUIT III CONDUIT	EL CABLE 4 WIRES #8 - 1C	ORNAMENTAL LIGHT POLE	150 WATT HPS LUMINAIRE	EL CABLE 5 WIRES #12 - 1C	CONCRETE FOUNDATION	JUNCTION BOX	TRENCH & BACKFILL
6TH STREET	FOOT	FOOT		FOOT	EACH	EACH	FOOT	FOOT	EACH	FOOT
SPLICE AT HH 9 - TO JB 20			X	228						
JB 20 THRU JB 19			X	264						
JB 19 THRU JB 18			X	236						
JB 18 TO HH 10			X	96						
HH 10			X	26						
SPLICE AT HH 10 THRU JB 17			X	184						
JB 17 TO EXISTING CONDUIT WEST SIDE 6TH STR			X	48						
END OF LINE JUNCTION BOX			X	6						
SPLICE TO EXISTING WEST SIDE LIGHT CIRCUIT										
			USE CIRCUIT V CONDUIT							
SPLICE AT HH 10 TO HH 13				220						
HH 13 THRU JB 25			X	24						
JB 25 TO EXISTING CONDUIT EAST SIDE 6TH STR			X	228						
END OF LINE JUNCTION BOX			X	6						

CIRCUIT XII - 240 VOLT	PVC CONDUIT 3" IN TRENCH	PVC CONDUIT 3" AUGERED	EL CABLE 600V XLP 3 WIRES 1C - 3/0	EL CABLE 600V XLP 1 WIRE 1C - NO 4	TRENCH & BACKFILL
POWER TO ELECT SERVICE BOX - 6TH STREET	FOOT	FOOT	FOOT	FOOT	FOOT
SERVICE F TO HH 27	7		21	7	7
HH27			18	6	
HH 27 TO HH 16			558	186	
HH 16			18	6	
HH 16 TO HH 15	258		774	258	258
HH 15			18	6	
HH 15 TO HH 13	37	42	237	79	37
HH 13			18	6	
HH 13 TO HH 10 (USE SIGNAL CONDUIT)			165	55	
HH 10			18	6	
HH 10 TO NEW ELECTRIC PANEL BOX	24		72	24	24
AT ELECTRIC PANEL BOX			18	6	
TOTALS	326	42	1935	645	326