



**NOTES:**

1. Use 6" for the 4 downspouts at the abutments. This dimension will be determined by the Contractor to allow discharge to downspouts attached to the piers.
2. Core and set #5 d<sub>3</sub>(E) bar according to Article 509.06 of the Standard Specifications. Cored holes shall be roughened or scored per manufacturer's recommendations. Maximum depth of hole shall not exceed 6".
3. Cut longitudinal reinforcement to clear Drainage Scuppers.
4. Cost of anchor rods, nuts and washers for light poles and conduit is included with Concrete Superstructure. See Electrical Plans for details and payment of other electrical components.
5. \*Notch Parapet 11" X 2" to allow placement of Scuppers and future removal of grate. 2" dimension may be reduced if Scupper can be moved closer to fascia beam.
6. Anchor Rods for Light Poles shall be ASTM F1554, Grade 105 and shall be fully hot dip galvanized.
7. Electrical conduit in parapet shall have a minimum clearance of 1/2" from reinforcement bars.

P:\10522010\20103003\cadd\structural\045-0039\_find\00\DI60133-e034-super-dtl.dgn  
 6/14/2012 6:06:45 PM

USER NAME =	DESIGNED - R.K.-Z. 6/15/2012	REVISED -
PLOT SCALE =	CHECKED - J.Z. 6/15/2012	REVISED -
PLOT DATE =	DRAWN - R.K.-Z. 6/15/2012	REVISED -
	CHECKED - J.J.C. 6/15/2012	REVISED -

F.A.P. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
349	(10 & 11VB) R-3	KANE	507	255
CONTRACT NO. 60133				
ILLINOIS FED. AID PROJECT				