



PLAN  
 SURVEYED BY: [ ]  
 CHECKED BY: [ ]  
 DATE: [ ]  
 NOTE BOOK NO. [ ]  
 DRAWN BY: [ ]  
 CHECKED BY: [ ]  
 DATE: [ ]

PROFILE  
 SURVEYED BY: [ ]  
 CHECKED BY: [ ]  
 DATE: [ ]  
 NOTE BOOK NO. [ ]  
 DRAWN BY: [ ]  
 CHECKED BY: [ ]  
 DATE: [ ]

Boring No./Sample No.	EB-15/7	EB-15/33	EB-17/2&3
Depth:	13.5' - 15.5'	78.5' - 80.0'	1.0' - 5.0'
Soil Classification:	CLAY A-7	SAND & GRAVEL A-1-b	SILTY LOAM A-7
Group Index:	93	1	20
% Gravel (AASHTO T-88):	0.0	5.0	0.4
% Sand (AASHTO T-88):	0.2	87.8	14.9
% Silt (AASHTO T-88):	41.9	7.2	66.7
% Clay (AASHTO T-88):	57.9	4.3	17.9
Liquid Limit:	108	2.4	50
Plastic Limit:	30	NP	19
Plasticity Index:	78		21

\*NOTE: ACTUAL STATION OF BORING EB17 HAS BEEN OFFSET TO ACCOMMODATE SPACE AVAILABLE