

| F.A.I. RTE. | SECTION | COUNTY | TOTAL SHEETS | SHEET NO. |
|--------------------------------|-------------|----------|--------------|-----------|
| 412 | (62-2VB)1-1 | MARSHALL | 19 | 11 |
| FED. ROAD DIST. NO. - ILLINOIS | | PROJECT | | |



NOTES

Bar splicer assemblies shall be of an approved type and shall develop in tension at least 125 percent of the yield strength of the lapped reinforcement bars.
 Splicer rods shall be of minimum 60 ksi yield strength, threaded or coiled full length.
 All reinforcement bars shall be lapped and tied to the splicer rods or dowel bars.
 Bar splicer assemblies shall be epoxy coated according to the requirements for reinforcement bars.
 Other systems of similar design may be submitted to the Engineer for approval. Approval shall be based on certified test results from an approved testing laboratory that the proposed bar splicer assembly satisfies the following requirements:

- ① Minimum Capacity (Tension in kips) = $1.25 \times f_y \times A_L$
 - ② Minimum Pull-out Strength (Tension in kips) = $1.25 \times f_{sallow} \times A_L$
- Where f_y = Yield strength of lapped reinforcement bars in ksi.
 f_{sallow} = Allowable tensile stress in lapped reinforcement bars in ksi (Service Load)
 A_L = Tensile stress area of lapped reinforcement bars.
 * = 28 day concrete

| Bar Size to be Spliced | Splicer Rod or Dowel Bar Length | Strength Requirements | |
|------------------------|---------------------------------|------------------------------|---------------------------------------|
| | | Min. Capacity kips - tension | Min. Pull-Out Strength kips - tension |
| #4 | 1'-8" | 14.7 | 5.9 |
| #5 | 2'-0" | 23.0 | 9.2 |
| #6 | 2'-7" | 33.1 | 13.3 |
| #7 | 3'-5" | 45.1 | 18.0 |
| #8 | 4'-6" | 58.9 | 23.6 |
| #9 | 5'-9" | 75.0 | 30.0 |
| #10 | 7'-3" | 95.0 | 38.0 |
| #11 | 9'-0" | 117.4 | 46.8 |


Bar splicer assemblies shall be according to Section 508 of the Standard Specifications, except as noted. The furnishing and installation of bar splicer assemblies will be measured and paid for at the contract unit price each for "BAR SPLICERS."



INSTALLATION AND SETTING METHODS


"A": Set bar splicer assembly by means of a template bolt.
 "B": Set bar splicer assembly by nailing to wood forms or cementing to steel forms.
 (E) : Indicates epoxy coating.

4 - Bar Splicers @ 12" cts. for #6 (ME) bars



FOR INTEGRAL OR SEMI-INTEGRAL ABUTMENTS


| |
|---|
| Bar Splicer for #5 bar |
| Min. Capacity = 23.0 kips - tension |
| Min. Pull-out Strength = 9.2 kips - tension |
| No. Required = |



FOR PILE BENT ABUTMENTS

| |
|---|
| Bar Splicer for #5 bar |
| Min. Capacity = 23.0 kips - tension |
| Min. Pull-out Strength = 9.2 kips - tension |
| No. Required = |

| Size | No. Assemblies Required | Location |
|------|-------------------------|-----------|
| #4 | 41 | BACK WALL |



STANDARD

| Size | No. Assemblies Required | Location |
|------|-------------------------|----------------------------------|
| #6 | 4 | END DAM |
| #5 | 6 | BACK WALL |
| #4 | 8 | Approach Pavement |
| #5 | 30 | Approach Pavement |
| #4 | 24 | Approach Pavement (Concrete Pad) |
| #6 | 28 | Approach Pavement Connector |

BAR SPLICER ASSEMBLY DETAILS

| REVISIONS | |
|-----------|------|
| NAME | DATE |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |

ILLINOIS DEPARTMENT OF TRANSPORTATION
BAR SPLICER ASSEMBLY DETAIL
 FAI 412 (I-39)
 SECTION (62-2VB)1-1
 STA. 165+90.23
 MARSHALL COUNTY

SCALE: VERT. DATE 04/26/2005
 HORIZ. DATE
 DRAWN BY R.L.W.
 CHECKED BY

BSD-1 9-01-03