



WIRING DIAGRAM

- BE GALVANIZED RIGID METALIC CONDUIT, PVC COATED (GRMC, PVC)
- 3. THE USE OF LIQUID TIGHT METAL CONDUIT (TYPE LFMC) SHALL BE LIMITED TO LOCATIONS WHERE MOVEMENT IS ANTICIPATED AND SHALL NOT EXCEED 5' (1.5 m) IN LENGTH
- 4. ALL WORK INDICATED SHALL BE INCLUDED IN THE PAY ITEM FOR ELECTRIC CONNECTION TO SIGN STRUCTURE
- 5. THE SAFETY SWITCH SHALL BE LOCATED ON THE SIDE OF THE SIGN STRUCTURE WHICH IS CLOSEST TO THE SHOULDER, OR EDGE OF PAVEMENT.

	F.A.   SECTION	COUNTY SHEET NO
W:\diststd\22x34\be6000.dgn  ELECTRIC CONNECTION TO SIGN STRUCTURE  REVISED -  STATE OF ILLINOIS	NIL.	311213 1102
PLOT SCALE = 50.0000 '/ IN. CHECKED - REVISED - DEPARTMENT OF TRANSPORTATION	BE-600	CONTRACT NO.
PLOT DATE = 1/4/2008 DATE - REVISED - SCALE: NONE SHEET NO. 1 OF 2 SHEETS STA. TO STA.		IS FED. AID PROJECT

DETAIL A