



- Notes:**
- Steel Trash Rack shall be galvanized after shop fabrication according to AASHTO M 111 and ASTM A 385. All bolts, nuts, washers, and anchor rods shall be galvanized according to AASHTO M 232 except Stainless steel bolts as noted. Vent holes for galvanizing shall be placed in the 4" log of the angles.
  - Work this sheet with Drwg. S3 OF S12 & S4 OF S12.

**BILL OF MATERIAL**

Item	Unit	Total
Slide Gate	each	1
Steel Trash Rack	each	1

Described By TCU Checked By TKL  
 Drawn By JER Checked By TCU  
 10/09/2007 4:56:25 PM