



BAR LIST				
Bar	No.	Size	Length	Shape
h12(E)	14	#6	46'-6"	—
h13(E)	12	#6	6'-8"	—
h14(E)	10	#6	3'-4"	—
h15(E)	16	#6	5'-6"	—
v5(E)	30	#6	7'-5"	—
v6(E)	22	#6	4'-10"	—
v7(E)	94	#6	8'-6"	U
v8(E)	42	#7	5'-10"	U
v9(E)	84	#6	4'-3"	—

BILL OF MATERIAL		
Item	Unit	Total
Concrete Structures	Cu yd	28.4
Reinforcement Bars, Epoxy Coated	lb	4,010

- Notes:**
- All lap lengths shall be 2'-10" min.
 - Reinforcement designated (E) shall be epoxy coated.
 - The minimum typical clearance shall be 3" unless noted.
 - Non-radiused corners shall be chamfered 3/4" x 3/4".
 - Anchor dowels to RCC with cementitious grout in accordance with Section 1024 of the Specifications. Cost included with Concrete Structures.

DESIGNED BY TCU CHECKED BY TKL
 DRAWN BY JEG CHECKED BY TCU
 4:54:51 PM
 10/09/2007
 e:\document\22849891\yorkville\plan\stoplog\stoplog.dgn