


**NOTES:**

1. EACH PROPOSED LIGHTING UNIT SHALL BE EQUIPPED WITH BANNER ARMS 120V RECEPTACLE AND FLAG MOUNTING BRACKET, SEE DETAIL SHEET LTC-12.
2. UNIT DUCT SHALL BE BORED AND PULLED.
3. POLE SHALL BE INSTALLED WITHOUT BREAKAWAY COUPLINGS.
4. SET BACKS INDICATED ARE FROM BACK OF CURB TO CENTER OF POLE.

PROPOSED LIGHTING UNIT: 40 FT MH, 6 FT MA, 400W, 120V METAL HALIDE LUMINAIRE AND 16 FT MH, 2 FT MA LED LUMINAIRE 66W, 120V (TYP)



LTG-04



FILE NAME =	USER NAME = #USER#	DESIGNED - BL	REVISED -	<b>STATE OF ILLINOIS DEPARTMENT OF TRANSPORTATION</b>	<b>CITY OF PALOS HEIGHTS LIGHTING IMPROVEMENTS PROPOSED LIGHTING PLAN</b>	F.A.P. RITE	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.	
#FILE#		DRAWN - RV	REVISED -			348	09-00046-00-LT	COOK	20	5	
PLOT SCALE = #SCALE#		CHECKED - SA	REVISED -			<b>CONTRACT NO. 63518</b>					
PLOT DATE = #DATE#		DATE - 06-03-11	REVISED -			ILLINOIS FED. AID PROJECT					