

## (SEE GENERAL NOTE 3)

- 1. Article 509.04 of the Standard Specifications
  - be continuous welding or with using standard
  - in place of anchor shown. Anchor bolt holes shall be  $\frac{3}{4}(20)$  in diameter and 5(125) deep. They shall be predrilled with an electric hammer drill to a depth of 4(100) prior to use of a pnuematic drill for the remaining 4(100). A two component encapsulated epoxy such as "Parabond" or an equivalent shall be used. Installation shall be according to
- 4. The pipe handrail shall be galvanized by the hot

## All dimensions are in inches (millimeters) unless otherwise noted.

RAIL FASTENING		SECTION			COUNTY	TOTAL SHEETS	SHEET NO.	
						CONTRACT	NO.	
CADD STD. 510001-D4	FED. RO	DAD DIST.	NO.	ILLINOIS	FED. AI	D PROJECT		