



**INDEX OF SHEETS**

SHEET NO.	DESCRIPTION
<b>ROADWAY PLANS – SN 013-2009</b>	
1.	COVER SHEET
2.	GENERAL NOTES AND INDEX
3.	STANDARDS AND SUMMARY OF QUANTITIES
4.	SUMMARY OF QUANTITIES
5.	TYPICAL SECTIONS
6.	SCHEDULES OF QUANTITIES
7.	FAP RTE 328 (US 45) PLAN AND PROFILE
8.-9.	STAGE CONSTRUCTION PLANS
10.	STAGE CONSTRUCTION DETAILS
11.	EROSION CONTROL AND DRAINAGE PLAN
12.	MISCELLANEOUS DETAILS
<b>STRUCTURE PLANS – SN 013-2009</b>	
13.	GENERAL PLAN
14.	STAGE CONSTRUCTION DETAILS
15.	BOX CULVERT DETAILS
16.	BAR SPLICER ASSEMBLY DETAILS
17.	SOIL BORING LOGS
18.	TEMPORARY CONCRETE BARRIER FOR STAGE CONSTRUCTION
<b>EXISTING STRUCTURE PLANS – SN 013-2009</b>	
19.-23.	EXISTING STRUCTURE PLANS
<b>CROSS SECTIONS – SN 013-2009</b>	
24.-28.	FAP RTE 328 (US 45) CROSS SECTIONS
<b>ROADWAY PLANS – SN 013-2010</b>	
29.	TYPICAL SECTIONS
30.	SCHEDULES OF QUANTITIES
31.	FAP RTE 328 (US 45) PLAN AND PROFILE
32.-33.	STAGE CONSTRUCTION PLANS
34.	STAGE CONSTRUCTION DETAILS
35.	EROSION CONTROL AND DRAINAGE PLAN
36.	MISCELLANEOUS DETAILS
<b>STRUCTURE PLANS – SN 013-2010</b>	
37.	GENERAL PLAN
38.	STAGE CONSTRUCTION DETAILS
39.	BOX CULVERT DETAILS
40.	BAR SPLICER ASSEMBLY DETAILS
41.	SOIL BORING LOGS
42.	TEMPORARY CONCRETE BARRIER FOR STAGE CONSTRUCTION
<b>EXISTING STRUCTURE PLANS – SN 013-2010</b>	
43.-49.	EXISTING STRUCTURE PLANS
<b>CROSS SECTIONS – SN 013-2010</b>	
50.-53.	FAP RTE 328 (US 45) CROSS SECTIONS
<b>ROADWAY PLANS – SN 013-2011 &amp; SN 013-0043</b>	
54.	TYPICAL SECTIONS
55.-56.	SCHEDULES OF QUANTITIES
57.-59.	FAP RTE 328 (US 45) PLAN AND PROFILE
60.-61.	STAGE CONSTRUCTION PLANS
62.-63.	STAGE CONSTRUCTION DETAILS
64.	EROSION CONTROL AND DRAINAGE PLAN
65.	MISCELLANEOUS DETAILS
<b>STRUCTURE PLANS – SN 013-2011</b>	
66.	GENERAL PLAN
67.	STAGE CONSTRUCTION DETAILS
68.	BOX CULVERT DETAILS
69.	BAR SPLICER ASSEMBLY DETAILS
70.	SOIL BORING LOGS
71.	TEMPORARY CONCRETE BARRIER FOR STAGE CONSTRUCTION
72.	STEEL RAILING, TYPE 2399
<b>EXISTING STRUCTURE PLANS – SN 013-2011</b>	
73.-77.	EXISTING STRUCTURE PLANS
<b>STRUCTURE PLANS – SN 013-0043</b>	
78.	GENERAL PLAN
79.	GENERAL DATA
80.	STAGE CONSTRUCTION DETAILS
81.	TEMPORARY CONCRETE BARRIER
82.	TOP OF SLAB ELEVATIONS
83.	TOP OF NORTH APPROACH SLAB ELEVATIONS
84.	TOP OF SOUTH APPROACH SLAB ELEVATIONS
85.	SUPERSTRUCTURE
86.-87.	SUPERSTRUCTURE DETAILS
88.	NORTH ABUTMENT
89.	SOUTH ABUTMENT
90.	PIER 1
91.	PIER 2
92.	BAR SPLICER ASSEMBLY DETAILS
93.	STEEL H-PILE DETAILS
94.	CONCRETE PARAPET SLIP FORMING OPTION
95.	BORING LOGS
<b>EXISTING STRUCTURE PLANS – SN 013-0043</b>	
96.-102.	EXISTING STRUCTURE PLANS
<b>CROSS SECTIONS – SN 013-2011 &amp; SN 013-0043</b>	
103.-109.	FAP RTE 328 (US 45) CROSS SECTIONS

**GENERAL NOTES**

- THE ENGINEER SHALL BE THE SOLE JUDGE CONCERNING CURING TIME FOR THE VARIOUS HMA LIFTS.
- EXCEPT AS NOTED ON THE PLANS, PAVEMENT GRADES SHOWN ARE AT THE TOP OF PAVEMENT SURFACES.
- ALL SAWCUTTING OF EXISTING PAVEMENT SHALL BE CONSIDERED INCLUDED IN THE PAY ITEMS INVOLVED. THE MINIMUM SAW DEPTH IN THE PAVEMENT SHALL BE 1/2" UNLESS OTHERWISE NOTED.
- WHERE SECTION OR SUBSECTION MONUMENTS ARE ENCOUNTERED, THE ENGINEER SHALL BE NOTIFIED BEFORE SUCH MONUMENTS ARE REMOVED. THE CONTRACTOR SHALL PROTECT AND CAREFULLY PRESERVE ALL MONUMENTS UNTIL AN AUTHORIZED SURVEYOR OR AGENT HAS WITNESSED OR OTHERWISE REFERENCED THEIR LOCATION. THE CONTRACTOR SHALL BE RESPONSIBLE FOR HAVING AN AUTHORIZED SURVEYOR REESTABLISH ANY SECTION OR SUBSECTION MONUMENTS DESTROYED BY HIS OPERATIONS.
- THE THICKNESS OF HMA MIXTURES SHOWN ON THE PLANS IS THE NOMINAL THICKNESS. DEVIATIONS FROM THE NOMINAL THICKNESS WILL BE PERMITTED WHEN SUCH DEVIATIONS OCCUR DUE TO IRREGULARITIES IN THE EXISTING SURFACE OR BASE ON WHICH THE HMA MIXTURE IS PLACED.
- ANY REFERENCE TO A STANDARD IN THESE PLANS SHALL BE INTERPRETED TO MEAN THE EDITION AS INDICATED BY THE SUBNUMBER LISTED ON THE INDEX OF SHEETS OR THE COPY OF THE STANDARD INCLUDED IN THESE PLANS.
- FACTORS USED FOR ESTIMATING PLAN QUANTITIES ARE AS FOLLOWS AND SHALL NOT BE USED FOR THE BASIS OF FINAL QUANTITIES:
 

ALL HOT-MIX ASPHALT	2.016 TONS/CU YD
ALL AGGREGATE	2.05 TONS/CU YD
BITUMINOUS MATERIALS:	
ON PAVEMENT	0.09 GAL/SQ YD
INTERMEDIATE LIFTS (FOG COAT)	0.04 GAL/SQ YD
ON AGGREGATE SURFACE	0.32 GAL/SQ YD
AGGREGATE (PRIME COAT)	0.0015 TONS/SQ YD
- ABANDONED UNDERGROUND UTILITIES THAT CONFLICT WITH CONSTRUCTION SHALL BE DISPOSED OF OUTSIDE THE LIMITS OF THE RIGHT OF WAY ACCORDING TO ARTICLE 202.03 OF THE STANDARD SPECIFICATIONS AND AS DIRECTED BY THE ENGINEER. THIS WORK WILL NOT BE PAID FOR SEPARATELY BUT SHALL BE INCLUDED IN THE COST OF EARTH EXCAVATION.
- ALL DISTURBED AREAS WITHIN THE CONSTRUCTION LIMITS SHALL BE FERTILIZED AND SEEDED. SEEDING SHALL BE CLASS 2A ACCORDING TO THE APPLICABLE ARTICLES OF SECTION 250 OF THE STANDARD SPECIFICATIONS. SEEDING SHALL NOT BE PERMITTED AT ANY TIME WHEN THE GROUND IS FROZEN, WET, OR IN AN UNTILLABLE CONDITION. LOCATIONS TO BE SEEDED WILL BE DETERMINED BY THE ENGINEER.
- THE CONTRACTOR SHALL BE RESPONSIBLE FOR PROTECTING UTILITY PROPERTY FROM CONSTRUCTION OPERATIONS AS OUTLINED IN ARTICLE 107.31 OF THE STANDARD SPECIFICATIONS. THE JULIE NUMBER IS 800-892-0123. A MINIMUM OF 48 HOURS ADVANCE NOTICE IS REQUIRED.
- EXISTING TRAFFIC BARRIER TERMINALS TO BE REMOVED SHALL BE PAID FOR AS GUARDRAIL REMOVAL.
- ALL ELEVATIONS REFERRING TO U.S.C.S. MEAN SEA LEVEL DATUM.
- TREES SHALL BE PRESERVED THROUGHOUT THIS SECTION EXCEPT AS SHOWN ON THE PLANS AND AS DIRECTED BY THE ENGINEER. GENERALLY, TREES OUTSIDE THE CLEAR ZONE, AND WHICH DO NOT INTERFERE WITH CONSTRUCTION, SHALL NOT BE DISTURBED.
- FOR STABILIZATION, ALL TYPE III BARRICADES SHALL REQUIRE A MINIMUM OF FOUR SANDBAGS PER BARRICADE.
- THE QUANTITY OF SHORT TERM PAVEMENT MARKING SHOWN IN THE PLANS IS BASED ON ONE APPLICATION EACH FOR THE INITIAL OPENING OF THE COMPLETED STRUCTURE TO TWO LANE TRAFFIC, THE PRIME COAT, BINDER COURSE, AND SURFACE COURSE.
- SHORT TERM PAVEMENT MARKING ON MILLED SURFACES SHALL BE PAINT.
- THE ADVANCE DETECTOR LOOPS ARE TYPICALLY LOCATED 275 FEET IN ADVANCE OF THE STOP BAR. THE BUREAU OF OPERATIONS SHALL APPROVE THE LOOP LOCATIONS PRIOR TO INSTALLATION.
- THE CENTERLINE PAVEMENT MARKING SHOULD BE REMOVED FROM THE STOP BAR TO THE SAND ATTENUATORS OR DRUMS. EDGE LINE PAVEMENT MARKING SHOULD BE REMOVED IF A 10 FOOT LANE WIDTH CANNOT BE MAINTAINED. TEMPORARY EDGE LINES SHOULD BE INSTALLED WHEN THE EDGE LINES ARE REMOVED.
- THE CONTRACTOR SHALL PROVIDE INTERNET ACCESSIBILITY TO THE HMA PLANT QUALITY CONTROL LAB SO THAT HMA PLANT REPORTS CAN BE EMAILED TO THE DISTRICT HEADQUARTERS. THIS WORK SHALL BE INCLUDED IN THE COST OF ALL HOT-MIX ASPHALT ITEMS.
- ANY TIME THE CONCRETE BARRIER IS NOT IN THE PROPER POSITION, FLAGGERS SHALL BE IN PLACE TO CONTROL TRAFFIC AND THE TEMPORARY TRAFFIC SIGNALS SHALL BE TURNED OR COVERED.
- THE CONTRACTOR SHALL USE EITHER RC-70 OR AN EMULSIFIED POLYMER PRIME SS-1HP FOR THE PAY ITEM BITUMINOUS MATERIALS (PRIME COAT).
- THE TOP 4 IN. OF TOPSOIL SHALL BE STRIPPED FROM ALL AREAS WITHIN THE CONSTRUCTION LIMITS. THIS MATERIAL SHALL BE STOCKPILED AT A LOCATION APPROVED BY THE ENGINEER AND REPLACED AFTER MAJOR GRADING OPERATIONS ARE COMPLETED. THIS WORK WILL BE PAID FOR AS TOPSOIL EXCAVATION AND PLACEMENT. ADDITIONAL TOPSOIL REQUIRED WILL BE PAID FOR AS TOPSOIL FURNISH AND PLACE, 4 IN.
- BASE COURSE WIDENING EXCEEDING 6' IN WIDTH WILL BE PAID FOR AS BASE COURSE WIDENING OF THE THICKNESS SPECIFIED.
- AGGREGATE SHOULDERS, TYPE B SHALL BE CRUSHED STONE, CRUSHED CONCRETE, OR RAP.
- ALL WORK NECESSARY TO ATTACH THE PIPE DRAIN TO THE ABUTMENT DRAIN PIPE, TRENCHING IN THE PIPE DRAINS AND INSTALLING THE PIPE DRAIN TO THE CONCRETE HEADWALLS IS INCLUDED IN THE PAY ITEM OF PIPE DRAINS OF THE DIAMETER SPECIFIED.

**COMMITMENTS**

- NONE AS OF AUGUST 15, 2008. REFER TO COMMITMENT FILE FOR ANY COMMITMENTS AFTER THIS DATE.

CONTRACT NO. 74107				
FAP RTE	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
328	*	CLAY	109	2
STA.		TO STA.		
FED. ROAD DIST. NO.		ILLINOIS	FED. AID PROJECT	
*6BR-1, 6BR-3, 8BR-3, 8BR-4B-1				

STATE OF ILLINOIS  
DEPARTMENT OF TRANSPORTATION

PREPARED BY: \_\_\_\_\_  
DISTRICT STUDIES & PLANS ENGINEER

EXAMINED BY: \_\_\_\_\_  
DISTRICT LAND ACQUISITION ENGINEER

EXAMINED BY: \_\_\_\_\_  
DISTRICT PROGRAM DEVELOPMENT ENGINEER

EXAMINED BY: \_\_\_\_\_  
DISTRICT OPERATIONS ENGINEER

EXAMINED BY: \_\_\_\_\_  
DISTRICT CONSTRUCTION ENGINEER

EXAMINED BY: \_\_\_\_\_  
DISTRICT MATERIALS ENGINEER

EXAMINED BY: \_\_\_\_\_  
DISTRICT PROJECT IMPLEMENTATION ENGINEER

EXAMINED BY: \_\_\_\_\_  
ASSISTANT REGIONAL ENGINEER

APPROVED BY: \_\_\_\_\_  
DEPUTY DIRECTOR OF HIGHWAYS, REGION ENGINEER

20

DATE

**HMA MIXTURES REQUIREMENTS**

LOCATION(S):	HOT MIX ASPHALT SURFACE COURSE AND LEVELING BINDER	BASE COURSE AND BASE COURSE WIDENING	HOT MIX ASPHALT SHOULDERS AND INC. HMA SURFACING
MIXTURE USE(S):	HOT MIX ASPHALT SURFACE COURSE, MIX C, N90	HOT MIX ASPHALT BINDER COURSE, N90, IL-19.0	HOT MIX ASPHALT SHOULDERS
AC/PG:	PG64-22	PG64-22	PG58-22
RAP % (MAX): ***	10	10	50
DESIGN AIR VOIDS:	4.0%, 90 GYRATION DESIGN	4.0%, 90 GYRATION DESIGN	2.0%, 30 GYRATION DESIGN
MIXTURE COMPOSITION: (GRADATION MIXTURE)	IL-9.5 OR IL-12.5	IL-19.0	HMA SHOULDERS
FRICTION AGGREGATE:	C SURFACE	NONE	NONE

\*\*\* IF RAP OPTION IS SELECTED, THE ASPHALT CEMENT GRADE MAY NEED TO BE ADJUSTED. THIS WILL BE DETERMINED BY THE ENGINEER.

**ESCA**  
CONSULTANTS, INC.

DESIGNED BY:	DAJ	04/08
DRAWN BY:	HAS	04/08
CHECKED BY:	MTD	05/08
APPROVED BY:	RDP	08/08

**GENERAL NOTES AND INDEX**  
**FAP RTE 328 (US 45)**  
**SECTIONS (6BR-1, 6BR-3,**  
**8BR-3, 8BR-4)B-1**  
**CLAY COUNTY**