

104-61E18

Response to question #2

The railing material is stated in the Special Provisions.

The special provision for "Pedestrian Railing and Pedestrian Rail (Special)" refers to Section 509 of the Standard Specifications. Section 509 of the standard specs indicates that "Steel Posts for Railings" shall be per Section 1006.34(a) and that "Tubular Steel Rail for Railings" shall be per Article 1006.34(b). Per the Special Provision, the railing posts and top rail shall be painted steel.

Reference to galvanized posts in note 4 on "Railing Details 1" sheet shall be disregarded per Article 105.05 of the Standard Specifications Hierarchy of Contract Documents, (Special Provisions hold over Plans)."