



FOUNDATION DETAIL

NOTES

TOP VIEW

- 1. ALL DIMENSIONS ARE IN INCHES (MILLIMETERS) UNLESS OTHERWISE SHOWN.
- 2. THE ANCHOR RODS AND RACEWAYS SHALL BE PROPERLY SECURED IN PLACE BEFORE THE CONCRETE IN PLACED.
- 3. THE FOUNDATION SHALL NOT PROTRUDE MORE THAN 100MM (4 IN.) ABOVE THE FINISHED GRADE WITHIN A 60 IN. 11.5 m) CHORD ACROSS THE FOUNDATION, WITH ANCHOR RODS INCLUDED, IN ACCORDANCE WITH ASSITIO GLIDELINES. IF THE FOUNDATION HEIGHT, INCLUDING ANCHOR RODS, EXTENDS BEYOND THESE SPECIFIED LIMITS, THE FOUNDATION SHALL BE REPLACED AT THE CONTRACTOR'S EXPENSE. SEE FOUNDATION EXTENSION DETAIL.
- 4. THE HOLE FOR THE FOUNDATION SHALL BE MADE BY DRILLING WITH AN AUGER, OF THE SAME DIAMETER AS THE FOUNDATION. IF SOIL CONDITIONS REQUIRE THE USE OF A LINER TO FORM THE HOLE, THE LINER SHALL BE WITHORAWN AS THE CONCRETE IS DEPOSITED.
- THE TOP OF THE FOUNDATION SHALL BE CONSTRUCTED LEVEL. A LIMER OR FORM SHALL BE USED TO PRODUCE A UNIFIDRY SMOOTH SIDE TO THE TOP OF THE FOUNDATION. FOUNDATION TOP SHALL BE CHAMFERED \(\frac{7}{4}\)-IN. (20 mm).
- THE CONCRETE SHALL BE CLASS SIL CONCRETE SHALL CURE ACCORDING TO ARTICLE 1020.13 BEFORE LIGHT POLES ARE INSTALLED.
- T. THE ANCHOR ROD SHALL BE A HODK ROD TYPE. COLD BENDONG OF THE ANCHOR ROD WILL NOT BE ALLOWED. THE RADIUS OF THE HOOK BEND SHALL NOT BE LESS THAN 4 TIMES THE HOMINAL DIAMETER OF THE ANCHOR ROD. A TACK WELDED ANCHOR ROD MAY BE SUBSTITUTED WITH THE APPROVAL OF THE ENGINEER.
- 8. THE ANCHOR RODS SHALL BE ACCORDING TO ASTM F1554 GRADE 725 (GRADE 105), NUTS SHALL BE HEXAGON MUTS ACCORDING TO ASTM A 194 2H OR ASTM A 563 DH, AND WASHERS SHALL BE ACCORDING TO ASTM F 438.
- 9. ANCHOR RODS, MUTS AND WASHERS SHALL BE COMPLETELY GALVANIZED BY EITHER THE HOT-DEPPED PROCESS CONFORMING WITH ASSITO M 232, THE MECHANICAL PLATING METHOD CONFORMING TO ASSITO M 298, CLASS 50 WITH A MAXIMUM COATING THICKNESS OF 150 UM 6 MILS) OR THE ELECTROLYTIC PROCESS ACCORDING TO ASTM F 1136.
- THE ANCHOR RODS SHALL BE THREADED A MINIMUM OF 6 INCHES (150 mm) WITH A NINIMUM OF 3 INCHES 175 mm) OF THREADED ANCHOR ROD EMBEDDED IN THE FOUNDATION.
- 11. ANCHOR RODS SHALL PROJECT 2¾4" (89.9 mm) ABOVE THE TOP OF THE FOUNDATION. IF BREAKAWAY COUPLINGS ARE SPECIFIED, THE CONTRACTOR SHALL CAREFULLY COORDINATE THE ANCHOR ROUP PROJECTION WITH THE INSTALLATION REQUIREMENTS OF THE BREAKAWAY COUPLINGS.
- 12. THE CONTRACTOR SHALL USE A *3 SPIRAL AT 6" (152.4 mm) PITCH OR MAY SUBSTITUTE *3 TIES AT 12" (304.8 mm) O.C. WITH THE APPROVAL OF THE ENGINEER.
- THE CABLE TRENCHES AND FOUNDATION SHALL BE BACK FILLED AND COMPACTED AS SPECIFIED BEFORE THE LIGHT FOLE IS ERECTED.
- 14. THE RACEWAYS SHALL PROJECT 1" (25.4 mm) ABOVE THE TOP OF THE FOUNDATION.

١				
١	FILE NAME =	USER NAME = gaglianobt	DESIGNED	REVISED - 04/22/02
١	W:\diststd \ 22x34\be30Ldgn		DRAWN	REVISED -
I		PLOT SCALE = 20.000 '/ IN.	CHECKED	REVISED -
١		PLOT DATE = 11/4/2011	DATE	REVISED -

60" (1500)

FOUNDATION EXTENSION DETAIL

TOP OF ANCHOR ROD

STATE OF ILLINOIS
DEPARTMENT OF TRANSPORTATION

DISTRICT ONE – LIGHT POLE FOUNDATION			SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
40' TO 47 1/2' M.H. 15" BOLT CIRCLE		350	00-00243-00-CH	COOK	142	97
TO 10 T/ VZ WI.II. IS BOLI GINGLE			BE-301	CONTRACT	NO.	63566
T.S. SHEET NO. 7 OF 12 SHEETS STA.	TO STA.	FED. ROAD DIST. NO. 7 ILLINOIS FED. AID PROJECT				