



NOTE:  
SEE SHEET 264 FOR REMOVALS.

- LEGEND:
- EXISTING UNIT DUCT, TO BE REMOVED UNLESS NOTED OTHERWISE
  - PROPOSED UNIT DUCT
  - CONDUIT PUSHED, 4" DIA., PVC SCHEDULE 80 (PAID AS UNDERGROUND CONDUIT, PVC, 4" DIA.)
  - EXISTING LIGHT POLE TO REMAIN UNLESS NOTED OTHERWISE
  - PROPOSED LIGHT POLE, WEATHERING STEEL, 45 FT. M.H., TENON MOUNT WITH (1) 250W HPS MM VAPOR FIXTURE
  - PROPOSED HAND HOLE
  - PROPOSED SIGNAL/LIGHT COMBO POLE (SEE SIGNAL SHEETS)
  - UNIT DUCT, 600V, 2-1C NO.2, 1/C NO.2 GROUND, (XLP-TYPE USE), 1/4" DIA. POLYETHYLENE

0 50' 100'  
SCALE: 1" = 50'

Rev. 1-9-12

**McClure LOCHNER**  
Engineering Associates, Inc.  
**RVA**  
QUADRO ENGINEERING INC.

USER NAME = .USERNAME.	DESIGNED - BLM	REVISED -
PLOT SCALE = 50.0000' / IN.	DRAWN - JPW	REVISED -
PLOT DATE = 12/22/2011	CHECKED - BLM	REVISED -
	DATE - 12/22/11	REVISED -

**STATE OF ILLINOIS  
DEPARTMENT OF TRANSPORTATION**

**LIGHTING PLAN  
ROCKTON RD ENTRANCE RAMP**

SCALE:	SHEET NO.	OF	SHEETS	STA.	TO	STA.
--------	-----------	----	--------	------	----	------

F.A.I. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
90	(X2)-1R	WINNEBAGO	510	274
CONTRACT NO. 64C29				
ILLINOIS FED. AID PROJECT				