

 F.A.I. RTE.	SE	CTIO	Ŋ		COUN	ITY	TOTAL	SHEE NO.
90/94	200	3-03	11		COC	K	976	150
STA.	1518+0	0.00		ТО	STA.	1529	+50.00	
EED BU	AD DECT	NO 1	BIIN	2301	EED	- 410	PROJECT	

## 62583

## NOTES:

- 1. SEE DRAWINGS ME-01 AND ME-02 FOR ELECTRICAL SYMBOLS AND ABBREVIATIONS.
- 2. UNLESS NOTED OTHERWISE, ALL ITEMS AND WORK SHOWN IN HEAVY LINE WEIGHT ON THIS DRAWING ARE PROPOSED ITEMS AND WORK.
- 3. PROVIDE A TEMPORARY POWER FEED TO THE EXISTING SIGN TRUSS STRUCTURE LIGHTING UNITS. SEE DRAWING ME-25 FOR TEMPORARY POWER FEED TO SIGN STRUCTURE DETAILS.
- 4. SPLICE NEW LIGHTING CIRCUIT CABLES TO THE CORRESPONDING EXISTING LIGHTING CIRCUITS LOCATED WITHIN THE EXISTING JUNCTION BOX.
- 5. CONTRACTOR MUST DRILL AN ACCESS HOLE ON THE BOTTOM OF THE EXISTING JUNCTION BOX FOR THE TEMPORARY AERIAL CABLES. PROVIDE A WEATHERTIGHT SEAL WHERE THE AERIAL CABLES ENTER THE JUNCTION BOX.
- 6. PROVIDE A TEMPORARY POWER FEED TO HIGH MAST LIGHT TOWER 7 UCDI. SEE DRAWING ME-16 FOR TEMPORARY ROADWAY LIGHTING WOOD POLE DETAILS.
- 7. PROVIDE A TEMPORARY POWER FEED TO THE TEMPORARY LIGHTING UNIT AT STA. 2530+88. SEE DRAWING ME-16 FOR TEMPORARY ROADWAY LIGHTING WOOD POLE DETAILS.

0 50' 100'

RL05-37

31		REVISION
, ć	DATE	NAME
г		
SCALE:		
SUALES		
DATE.	1	

ILLINOIS DEPARTMENT OF TRANSPORTATION F.A.I. 90/94 (DAN RYAN EXPRESSWAY) 31st STREET TO 1-57

ROADWAY LIGHTING PLANS PROPOSED IMPROVEMENTS 2005

SCALE: 1"=50"

DRAWN BY: CJM

CIE ENGINEERS
CONSOER TOWNSEND ENVIRODME ENGINEERS, INC.
303 EAST WACKER DRIVE, SUITE 600
CHICAGO ILLINOIS 60601-5212, PHONE: (312) 938-0300

ATE: October 29, 2004

CHECKED BY: WDS